




# PROBLEM SUMMARY

Sample Rating Trend

VISCOSITY




Machine Id  
**#7 NH3 Compressor**  
Component  
**Screw Compressor**  
Fluid  
**NOCO NOCOCHILL OIL ISO 68 (700 LTR)**




## COMPONENT CONDITION SUMMARY

### ▲ Viscosity @ 40°C



### ▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>10000	▲ <b>21092</b>	▲ 14349	▲ 18088
Particles >6µm	ASTM D7647	>2500	▲ <b>4736</b>	▲ 2588	▲ 4310
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ <b>22/19/14</b>	▲ 21/19/13	▲ 21/19/14
Visc @ 40°C	cSt	ASTM D7279(m)	54.4	▲ <b>82.1</b>	▲ 87.8
				▲ 87.0	

Customer Id: MOLETO  
Sample No.: PP  
Lab Number: 02589332  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

## HISTORICAL DIAGNOSIS

### 14 Oct 2022 Diag: Kevin Marson

#### VISCOSITY



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. Viscosity of sample indicates oil is within ISO 100 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service. NOTE: The color of the oil is darker then previous samples.

[view report](#)



### 23 Jan 2022 Diag: Kevin Marson

#### VISCOSITY



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. Viscosity of sample indicates oil is within ISO 100 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 18 Jul 2021 Diag: Kevin Marson

#### VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. Viscosity of sample indicates oil is within ISO 100 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


[view report](#)





# OIL ANALYSIS REPORT

Sample Rating Trend



## VISCOSITY



Machine Id  
**#7 NH3 Compressor**  
 Component  
**Screw Compressor**  
 Fluid  
**NOCO NOCOCHILL OIL ISO 68 (700 LTR)**

### DIAGNOSIS

#### Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

#### Wear

All component wear rates are normal.

#### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.

#### Fluid Condition

The viscosity of the oil is higher than normal, possibly indicating the addition of a heavier grade of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

### SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PP</b>	PP	PP
Sample Date	Client Info	<b>07 Oct 2023</b>	14 Oct 2022	23 Jan 2022
Machine Age	hrs	<b>0</b>	0	0
Oil Age	hrs	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

### WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m) >60	<b>1</b>	2	2
Chromium	ppm	ASTM D5185(m) >4	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>&lt;1</b>	0	<1
Aluminum	ppm	ASTM D5185(m) >5	<b>0</b>	0	0
Lead	ppm	ASTM D5185(m) >10	<b>0</b>	0	<1
Copper	ppm	ASTM D5185(m) >30	<b>&lt;1</b>	0	<1
Tin	ppm	ASTM D5185(m) >15	<b>0</b>	0	<1
Antimony	ppm	ASTM D5185(m)	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

### ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	<b>&lt;1</b>	0	<1
Barium	ppm	ASTM D5185(m)	<b>1</b>	0	0
Molybdenum	ppm	ASTM D5185(m)	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Calcium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1
Phosphorus	ppm	ASTM D5185(m)	<b>0</b>	0	<1
Zinc	ppm	ASTM D5185(m)	<b>&lt;1</b>	1	<1
Sulfur	ppm	ASTM D5185(m)	<b>116</b>	156	151
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1






### CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m) >50	<b>1</b>	3	3
Sodium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Potassium	ppm	ASTM D5185(m) >20	<b>0</b>	0	<1
Water	%	ASTM D6304* >0.1	<b>0.001</b>	0.00	0.001
ppm Water	ppm	ASTM D6304* >1000	<b>5.9</b>	0.00	14.2

### FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	<b>▲ 21092</b>	▲ 14349	▲ 18088
Particles >6µm	ASTM D7647 >2500	<b>▲ 4736</b>	▲ 2588	▲ 4310
Particles >14µm	ASTM D7647 >320	<b>116</b>	42	154
Particles >21µm	ASTM D7647 >80	<b>12</b>	6	22
Particles >38µm	ASTM D7647 >20	<b>1</b>	0	0
Particles >71µm	ASTM D7647 >4	<b>1</b>	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/15	<b>▲ 22/19/14</b>	▲ 21/19/13	▲ 21/19/14

# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		<b>0.04</b>	0.09	0.02





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>LIGHT</b>	NONE	LIGHT
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	54.4	<b>▲ 82.1</b>	▲ 87.8	▲ 87.0

### SAMPLE IMAGES



### GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PP  
**Lab Number** : 02589332  
**Unique Number** : 5658398  
**Test Package** : IND 2 ( Additional Tests: KF, TAN Man )

**MOLSON TORONTO**  
 1 CARLINGVIEW DRIVE  
 TORONTO, ON  
 CA M9W 5E5  
 Contact: Heath Bagby  
 heath.bagby@molsoncoors.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.