




# PROBLEM SUMMARY

Sample Rating Trend




ISO



Area  
**BOF/OG SYSTEM**  
 Machine Id  
**D - O.G. Fan Lube System # 7**  
 Component  
**Tank Lube System**  
 Fluid  
**PETRO CANADA HYDREX AW 100 (135 GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>5000	▲ <b>29160</b>	▲ 25867	▲ 27247
Particles >6µm	ASTM D7647	>1300	▲ <b>7646</b>	▲ 6974	▲ 8394
Particles >14µm	ASTM D7647	>160	▲ <b>502</b>	▲ 451	▲ 582
Particles >21µm	ASTM D7647	>40	▲ <b>109</b>	▲ 117	▲ 132
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ <b>22/20/16</b>	▲ 22/20/16	▲ 22/20/16

Customer Id: LEWBOSC  
 Sample No.: WC0871202  
 Lab Number: 02589773  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

## HISTORICAL DIAGNOSIS

### WATER



#### 16 Aug 2023 Diag: Kevin Marson

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. Free water present. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### ISO



#### 13 Jul 2023 Diag: Kevin Marson

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### ISO



#### 20 Jun 2023 Diag: Kevin Marson

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**BOF/OG SYSTEM**  
 Machine Id  
**D - O.G. Fan Lube System # 7**  
 Component  
**Tank Lube System**  
 Fluid  
**PETRO CANADA HYDREX AW 100 (135 GAL)**

## DIAGNOSIS

### Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates (2 to 100 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0871202</b>	WC0850091	WC0838949
Sample Date	Client Info		<b>16 Oct 2023</b>	16 Aug 2023	13 Jul 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*	>99999	<b>0</b>	0	0
Iron	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	1	<1
Chromium	ppm	ASTM D5185(m) >20	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	0
Aluminum	ppm	ASTM D5185(m) >20	<b>0</b>	<1	<1
Lead	ppm	ASTM D5185(m) >20	<b>2</b>	1	<1
Copper	ppm	ASTM D5185(m) >20	<b>6</b>	3	2
Tin	ppm	ASTM D5185(m) >20	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0	<b>&lt;1</b>	0	0
Barium	ppm	ASTM D5185(m) 0	<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m) 0	<b>&lt;1</b>	<1	<1
Calcium	ppm	ASTM D5185(m) 50	<b>30</b>	34	37
Phosphorus	ppm	ASTM D5185(m) 330	<b>274</b>	315	333
Zinc	ppm	ASTM D5185(m) 430	<b>301</b>	347	372
Sulfur	ppm	ASTM D5185(m) 760	<b>2880</b>	2706	2707
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1

## CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	<b>3</b>	3	3
Sodium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1
Potassium	ppm	ASTM D5185(m) >20	<b>0</b>	<1	<1

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>▲ 29160</b>	▲ 25867	▲ 27247
Particles >6µm	ASTM D7647	>1300	<b>▲ 7646</b>	▲ 6974	▲ 8394
Particles >14µm	ASTM D7647	>160	<b>▲ 502</b>	▲ 451	▲ 582
Particles >21µm	ASTM D7647	>40	<b>▲ 109</b>	▲ 117	▲ 132
Particles >38µm	ASTM D7647	>10	<b>6</b>	4	2
Particles >71µm	ASTM D7647	>3	<b>2</b>	1	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>▲ 22/20/16</b>	▲ 22/20/16	▲ 22/20/16



# OIL ANALYSIS REPORT








FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.60	<b>0.45</b>	0.58	0.52

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>VLITE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	VLITE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	▲ WGOIL	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>5	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	▲ 1%	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	101	<b>99.6</b>	99.5	98.1

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **STELCO - BOSC - Basic Oxygen Slab Caster**  
**Sample No.** : WC0871202 **Received** : 17 Oct 2023 2330 Regional Road #3, Door: BOSC8  
**Lab Number** : 02589773 **Diagnosed** : 18 Oct 2023 NANTICOKE, ON  
**Unique Number** : 5658839 **Diagnostician** : Kevin Marson CA N0A 1L0  
**Test Package** : IND 2 ( Additional Tests: PQ, TAN Man )  
 Contact: Tom Walden  
 Thomas.Walden@stelco.com  
 T: (519)587-4541  
 F: (519)587-7702

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.