




PROBLEM SUMMARY

Sample Rating Trend





DEGRADATION

Area
RHOB/HYDRAULICS
 Machine Id
E - Ladle Lift Hydraulics

Component
Tank Hydraulic System
 Fluid
FORSYTHE NO FIRE WG 200R (1320 GAL)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Due to the low reserve alkalinity it is advised that you contact FORSYTHE to assist in restoring the proper amine concentration. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Copper	ppm	ASTM D5185(m)	>20	▲ 24	▲ 23
Particles >21µm		ASTM D7647	>40	▲ 71	2
Particles >38µm		ASTM D7647	>10	▲ 17	0
					▲ 99
					▲ 48

Customer Id: LEWBOSC
 Sample No.: WC0871214
 Lab Number: 02589792
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Contact Required	---	---	?	Due to the low reserve alkalinity it is advised that you contact FORSYTHE to assist in restoring the proper amine concentration.

HISTORICAL DIAGNOSIS

DEGRADATION



16 Aug 2023 Diag: Kevin Marson

Due to the low reserve alkalinity it is advised that you contact FORSYTHE to assist in restoring the proper amine concentration. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Copper and silver ppm levels are abnormal. A sharp increase in the copper level is noted. A sharp increase in the silver level is noted. Oil cooler core leaching or motor piston wear is indicated. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The reserve alkalinity of this fluid is lower than acceptable. Viscosity of sample indicates oil is within ISO 32 range, advise investigate. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The water concentration level is acceptable for this fluid.

view report



DEGRADATION



13 Jul 2023 Diag: Kevin Marson

view report



COOL CHEMICALS



20 Jun 2023 Diag: Kevin Marson

Due to the low reserve alkalinity it is advised that you contact FORSYTHE to assist in restoring the proper amine concentration. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Component wear rates appear to be normal (unconfirmed). The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The reserve alkalinity of this fluid is lower than acceptable. Viscosity of sample indicates oil is within ISO 32 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The water concentration level is acceptable for this fluid.


view report





COOLANT REPORT

Sample Rating Trend



DEGRADATION



Area
RHOB/HYDRAULICS
 Machine Id
E - Ladle Lift Hydraulics
 Component
Tank Hydraulic System
 Fluid
FORSYTHE NO FIRE WG 200R (1320 GAL)

DIAGNOSIS

Recommendation

Due to the low reserve alkalinity it is advised that you contact FORSYTHE to assist in restoring the proper amine concentration. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear

Copper ppm levels are abnormal. Oil cooler core leaching or motor piston wear is indicated.

Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The reserve alkalinity of this fluid is lower than acceptable. Viscosity of sample indicates oil is within ISO 32 range, advise investigate. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The water concentration level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0871214	WC0850110	WC0838978
Sample Date	Client Info	16 Oct 2023	16 Aug 2023	13 Jul 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

CORROSION INHIBITORS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	<1	0	<1
Phosphorus	ppm	ASTM D5185(m)	<1	0	0
Boron	ppm	ASTM D5185(m)	<1	<1	<1
Molybdenum	ppm	ASTM D5185(m)	0	0	<1

CORROSION

method	limit/base	current	history1	history2		
Iron	ppm	ASTM D5185(m)	>20	0	0	<1
Aluminum	ppm	ASTM D5185(m)	>20	0	0	0
Copper	ppm	ASTM D5185(m)	>20	▲ 24	▲ 23	1
Lead	ppm	ASTM D5185(m)	>20	0	0	<1
Tin	ppm	ASTM D5185(m)	>20	0	0	0
Silver	ppm	ASTM D5185(m)		<1	▲ 2	0
Zinc	ppm	ASTM D5185(m)		6	10	0

CONTAMINANTS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>5000	3252	963	4770
Particles >6µm	ASTM D7647	>1300	939	271	▲ 1465
Particles >14µm	ASTM D7647	>160	157	27	▲ 190
Particles >21µm	ASTM D7647	>40	▲ 71	2	▲ 99
Particles >38µm	ASTM D7647	>10	▲ 17	0	▲ 48
Particles >71µm	ASTM D7647	>3	0	0	29
Oil Cleanliness	ISO 4406 (c)	>19/17/14	19/17/14	17/15/12	▲ 19/18/15

CARRIER SALTS

method	limit/base	current	history1	history2	
Sodium	ppm	ASTM D5185(m)	153	176	138
Potassium	ppm	ASTM D5185(m)	21	12	0


SCALE POTENTIAL

method	limit/base	current	history1	history2	
Calcium	ppm	ASTM D5185(m)	<1	6	<1
Magnesium	ppm	ASTM D5185(m)	0	<1	<1



COOLANT REPORT


Reserve Alkalinity




VISUAL

Color

Bottom




Particle Trend




GRAPHS


Ferrous Alloys




Particle Count




Water (KF)




Non-ferrous Metals




PQ




Viscosity @ 40°C



Particle Trend



Acid Number



ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **STELCO - BOSC - Basic Oxygen Slab Caster**
Sample No. : WC0871214 **Received** : 17 Oct 2023 2330 Regional Road #3, Door: BOSC8
Lab Number : 02589792 **Diagnosed** : 19 Oct 2023 NANTICOKE, ON
Unique Number : 5658858 **Diagnostician** : Kevin Marson CA N0A 1L0
Test Package : IND 2 (Additional Tests: KF, pH, PQ, ReserveAlk, TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Contact: Tom Walden
 Thomas.Walden@stelco.com
 T: (519)587-4541
 F: (519)587-7702