



OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
57-5032

Component
3 Turbine

Fluid
IRVING D & E ISO 32 (--- LTR)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

Wear

{not applicable}

Contamination

{not applicable}

Fluid Condition

{not applicable}

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PP	---	---
Sample Date	Client Info		06 Oct 2023	---	---
Machine Age	hrs	Client Info	0	---	---
Oil Age	hrs	Client Info	0	---	---
Oil Changed		Client Info	N/A	---	---
Sample Status			NORMAL	---	---



VISUAL

	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	---

FLUID PROPERTIES


	method	limit/base	current	history1	history2
Oxidation Test (RPVOT)	minutes	ASTM D2272*	663	787	---

SAMPLE IMAGES




	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image



OIL ANALYSIS REPORT



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **IRVING BLENDING & PACKAGING**
Sample No. : PP **Received** : 17 Oct 2023 P.O.BOX 1169, 555 COURTENAY CAUSEWAY
Lab Number : 02589820 **Diagnosed** : 24 Oct 2023 Saint John, NB
Unique Number : 5658886 **Diagnostician** : Kevin Marson CA E2L 4E6
Test Package : TEST (Additional Tests: RPVOT)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Contact: Blaine Sherwood
 Blaine.Sherwood@irvingoil.com
 T: (506)202-7730
 F: (506)632-7001