




PROBLEM SUMMARY

Sample Rating Trend

ADDITIVES


Area
Saugeen Shores SP-17701
Machine Id
ECW #4

Component
Wind Turbine Gearbox
Fluid
MOBIL MOBILGEAR SHC XMP 320 (260 LTR)



COMPONENT CONDITION SUMMARY

▲ Additives



RECOMMENDATION

The oil is near the end of its useful service life, recommend schedule an oil change. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Phosphorus	ppm	ASTM D5185(m)	485	▲ 255	▲ 287	▲ 287

Customer Id: VESTAS
Sample No.: WC0835235
Lab Number: 02590757
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Bill Quesnel CLS,OMA II,MLA-III,LLA-I +1
(289)291-4641 x4641
Bill.Quesnel@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Service/change Fluid	---	---	?	The oil is near the end of it's useful service life, recommend schedule an oil change.

HISTORICAL DIAGNOSIS

27 Sep 2022 Diag: Kevin Marson

ADDITIVES



The oil is near the end of it`s useful service life, recommend schedule an oil change. The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >6µm and oil cleanliness are abnormally high. The water content is negligible. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. Phosphorus ppm levels are abnormally low. The AN level is acceptable for this fluid.

view report



05 Oct 2021 Diag: Bill Quesnel

ADDITIVES



The oil is near the end of it`s useful service life, recommend schedule an oil change. Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. Phosphorus ppm levels are abnormally low. The AN level is acceptable for this fluid.

view report



08 Oct 2020 Diag: Bill Quesnel

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ADDITIVES



Area
Saugen Shores SP-17701

Machine ID
ECW #4

Component
Wind Turbine Gearbox

Fluid
MOBIL MOBILGEAR SHC XMP 320 (260 LTR)

DIAGNOSIS

Recommendation

The oil is near the end of its useful service life, recommend schedule an oil change. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

Fluid Condition

Phosphorus ppm levels are abnormally low. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0835235	WC0577983	WC0546451
Sample Date	Client Info		27 Sep 2023	27 Sep 2022	05 Oct 2021
Machine Age	yrs	Client Info	15	14	0
Oil Age	yrs	Client Info	15	14	0
Oil Changed	Client Info		Not Chngd	Not Chngd	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*	>50	0	0	0
Iron	ppm	ASTM D5185(m)	>75	70	70
Chromium	ppm	ASTM D5185(m)	>5	<1	<1
Nickel	ppm	ASTM D5185(m)	>10	<1	<1
Titanium	ppm	ASTM D5185(m)	>10	0	0
Silver	ppm	ASTM D5185(m)		<1	0
Aluminum	ppm	ASTM D5185(m)	>10	0	0
Lead	ppm	ASTM D5185(m)	>15	0	0
Copper	ppm	ASTM D5185(m)	>5	2	2
Tin	ppm	ASTM D5185(m)	>10	0	0
Antimony	ppm	ASTM D5185(m)	>5	0	0
Vanadium	ppm	ASTM D5185(m)		0	0
Beryllium	ppm	ASTM D5185(m)		0	0
Cadmium	ppm	ASTM D5185(m)		0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<1	<1
Barium	ppm	ASTM D5185(m)		0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)		0	<1
Magnesium	ppm	ASTM D5185(m)		0	0
Calcium	ppm	ASTM D5185(m)	0	0	<1
Phosphorus	ppm	ASTM D5185(m)	485	▲ 255	▲ 287
Zinc	ppm	ASTM D5185(m)	0	11	13
Sulfur	ppm	ASTM D5185(m)		3389	3674
Lithium	ppm	ASTM D5185(m)		<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>40	5	6
Sodium	ppm	ASTM D5185(m)	>10	<1	0
Potassium	ppm	ASTM D5185(m)	>20	0	0
Water	%	ASTM D6304*	>0.02	0.005	0.006
ppm Water	ppm	ASTM D6304*	>200	50.0	67.8


INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*		0	0
Nitration	Abs/cm	ASTM D7624*		2.2	2.3
Sulfation	Abs/.1mm	ASTM D7415*		47.9	47.5




OIL ANALYSIS REPORT


Additives




Particle Count




Acid Number



Water (KF)



Viscosity @ 100°C




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		1138	83416	1808
Particles >6µm	ASTM D7647	>10000	290	▲ 30142	395
Particles >14µm	ASTM D7647	>1300	20	836	30
Particles >21µm	ASTM D7647	>320	5	153	9
Particles >38µm	ASTM D7647	>80	1	3	0
Particles >71µm	ASTM D7647	>20	1	0	0
Oil Cleanliness	ISO 4406 (c)	>--/20/17	17/15/11	▲ 24/22/17	18/16/12

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm ASTM D7414*		55.0	54.2	54.1
Acid Number (AN)	mg KOH/g ASTM D974*	0.85	0.51	0.55	0.52

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar Visual*	NONE	NONE	NONE	NONE
Silt	scalar Visual*	NONE	NONE	NONE	NONE
Debris	scalar Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar Visual*	NONE	NONE	NONE	NONE
Appearance	scalar Visual*	NORML	NORML	NORML	NORML
Odor	scalar Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar Visual*	>0.02	NEG	NEG	NEG
Free Water	scalar Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D7279(m)	335	312	313	312
Visc @ 100°C	cSt ASTM D7279(m)	38.3	35.7	36.0	35.8
Viscosity Index (VI)	Scale ASTM D2270*	164	161	162	161

SAMPLE IMAGES



ISO 17025:2017
Accredited
Laboratory

Laboratory
Sample No.
Lab Number
Unique Number
Test Package

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Vestas American Wind Technology Inc.
: WC0835235
: **02590757**
: 5659823
: IND 2 (Additional Tests: FT-IR, KF, KV100, PQ, TAN Man, VI)

Received : 20 Oct 2023
Diagnosed : 23 Oct 2023
Diagnostician : Bill Quesnel

1417 NW Everett Street
Portland, OR
US 97209
Contact: Nicole Philippi
NiPhi@vestas.com
T: (503)327-7683
F: (503)327-0247

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.