

No relevant graphs to display

RECOMMENDATION	PROBLEMATIC TEST RESULTS						
We recommend an early resample to monitor this	Sample Status				SEVERE	ABNORMAL	
condition.	NLGI Consistency	NLGI Scale SKF	F Method*	1	000-00	▲ 00	
	PrtFilter				•		no image

Customer Id: VESTAS Sample No.: PP0835285 Lab Number: 02590808 Test Package: GRS 1



To manage this report scan the QR code

To discuss the diagnosis or test data: Bill Quesnel CLS,OMA II,MLA-III,LLA-I +1 (289)291-4641 x4641 Bill.Quesnel@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Resample			?	We recommend an early resample to monitor this condition.		

HISTORICAL DIAGNOSIS

VISCOSITY



02 Sep 2021 Diag: Bill Quesnel

We recommend an early resample to monitor this condition.All component wear rates are normal. There is no indication of any contamination in the grease. The grease consistency has dropped 2 NLGI grades. The condition of the grease is acceptable for the time in service.





GREASE ANALYSIS

Sample Rating Trend

VISCOSITY

 \mathbf{X}

Area Saugeen Shores SP-17701 12K02A Component

Grease Fluid SKF LGWM 1 (--- LTR)

DIAGNOSIS

Recommendation

We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Grease Condition

Grease consistency has changed by 2-1/2 NLGI grades from NLGI 1 to 000-00.

Contaminants

There is no indication of any contamination in the grease.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PP0835285	PP0546463	
Sample Date		Client Info		13 Sep 2023	02 Sep 2021	
Machine Age	yrs	Client Info		15	0	
Grease Age	yrs	Client Info		15	0	
Grease Serviced		Client Info		Not Changd	N/A	
Sample Status				SEVERE	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*	>200	200	170	
Iron	ppm	ASTM D5185(m)	>250	44	69	
Chromium	ppm	ASTM D5185(m)	>10	<1	<1	
Nickel	ppm	ASTM D5185(m)	>5	<1	<1	
Cadmium	ppm	ASTM D5185(m)		0	0	
Titanium	ppm	ASTM D5185(m)		0	0	
Vanadium	ppm	ASTM D5185(m)		0	0	
Lead	ppm	ASTM D5185(m)	>25	0	<1	
Copper	ppm	ASTM D5185(m)	>75	<1	<1	
Tin	ppm	ASTM D5185(m)	>5	0	0	
Silver	ppm	ASTM D5185(m)	>5	<1	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<1	2	
Magnesium	ppm	ASTM D5185(m)	0	0	<1	
Manganese	ppm	ASTM D5185(m)	0	0	<1	
Molybdenum	ppm	ASTM D5185(m)	0	0	0	
Phosphorus	ppm	ASTM D5185(m)	5	4	7	
Zinc	ppm	ASTM D5185(m)	20	13	17	
Antimony	ppm	ASTM D5185(m)	0	0	<1	
THICKENER/SOA	۱P	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185(m)	0	0	0	
Barium	ppm	ASTM D5185(m)	0	<1	0	
Calcium	ppm	ASTM D5185(m)	40	24	31	
Sodium	ppm	ASTM D5185(m)	2	3	2	
Lithium	ppm	ASTM D5185(m)	120	103	113	
Sulfur	ppm	ASTM D5185(m)	650	649	682	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>150	<1	<1	
Potassium	ppm	ASTM D5185(m)		<1	<1	
GREASE CONDI	ΓΙΟΝ	method	limit/base	current	history1	history2
Grease Color		Visual*	Brown	Brown	Tan	
Texture		In-house*		Buttery	Short fiber	
NLGI Consistency	NLGI Scale	SKF Method*	1	• 000-00	▲ 00	



GREASE ANALYSIS

71

60

50

40

20


10

0


ppm

n

Sep2/21









: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Vestas American Wind Technology Inc. Laboratory CALA Sample No. : PP0835285 Received : 20 Oct 2023 1417 NW Everett Street Lab Number : 02590808 Diagnosed : 23 Oct 2023 Portland, OR ISO 17025:2017 Accredited Laboratory Unique Number : 5659874 Diagnostician : Bill Quesnel US 97209 Test Package : GRS 1 (Additional Tests: BottomAnalysis) Contact: Eric German To discuss this sample report, contact Customer Service at 1-800-268-2131. erger@vestas.com Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: (519)368-7500 Validity of results and interpretation are based on the sample and information as supplied. F: (519)368-7535