




PROBLEM SUMMARY

Area
System 72 - Essential Power Generation
 Machine Id
Z-7201C Essential Power Diesel Engine Lube Oil
 Component
Diesel Engine
 Fluid
IRVING IDO UNIVERSAL SAE 15W40 (830 LTR)



Sample Rating Trend



FUEL



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check the fuel injection system. We recommend that you change the oil at the next available stoppage or outage. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	SEVERE
Fuel	%	ASTM D7593*	>5	10.2	9.5	9.2
Visc @ 100°C	cSt	ASTM D7279(m)	15.2	11.0	11.0	11.3

Customer Id: HIBSTJ
 Sample No.: PP
 Lab Number: 02590883
 Test Package: MAR 3



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you change the oil at the next available stoppage or outage.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Fuel/injector System	---	---	?	We advise that you check the fuel injection system.

HISTORICAL DIAGNOSIS

31 Aug 2023 Diag: Kevin Marson



We advise that you check the fuel injection system. We recommend that you change the oil at the next available stoppage or outage. We recommend an early resample to monitor this condition. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. There is a high amount of fuel present in the oil. The water content is negligible. Tests confirm the presence of fuel in the oil. The BN result indicates that there is suitable alkalinity remaining in the oil. Fuel is present in the oil and is lowering the viscosity. The oil is no longer serviceable due to the presence of contaminants.



01 Jun 2023 Diag: Kevin Marson



We advise that you check the fuel injection system. We recommend that you change the oil at the next available stoppage or outage. We recommend an early resample to monitor this condition. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. There is a high amount of fuel present in the oil. The water content is negligible. Tests confirm the presence of fuel in the oil. The BN result indicates that there is suitable alkalinity remaining in the oil. Viscosity of sample indicates oil is within SAE 30 range, advise investigate. The oil is no longer serviceable due to the presence of contaminants.



29 Apr 2023 Diag: Kevin Marson




We advise that you check the fuel injection system. We recommend that you change the oil at the next available stoppage or outage. We recommend an early resample to monitor this condition. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. There is a high amount of fuel present in the oil. The water content is negligible. Tests confirm the presence of fuel in the oil. The BN result indicates that there is suitable alkalinity remaining in the oil. Viscosity of sample indicates oil is within SAE 30 range, advise investigate. The oil is no longer serviceable due to the presence of contaminants.





OIL ANALYSIS REPORT

Sample Rating Trend



FUEL



Area
System 72 - Essential Power Generation
 Machine Id
Z-7201C Essential Power Diesel Engine Lube Oil

Component
Diesel Engine
 Fluid
IRVING IDO UNIVERSAL SAE 15W40 (830 LTR)

DIAGNOSIS

Recommendation

We advise that you check the fuel injection system. We recommend that you change the oil at the next available stoppage or outage. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal. The ferrography results are normal indicating no abnormal wear in the system.

Contaminants

There is a high amount of fuel present in the oil. The water content is negligible. Tests confirm the presence of fuel in the oil.

Oil Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. Viscosity of sample indicates oil is within SAE 30 range, advise investigate. The oil is no longer serviceable due to the presence of contaminants.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PP	PP	WC0774324
Sample Date	Client Info	06 Oct 2023	31 Aug 2023	01 Jun 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		SEVERE	SEVERE	SEVERE

CONTAMINATION

method	limit/base	current	history1	history2
Glycol	WC Method	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184*	0	0	0	
Iron	ppm	ASTM D5185(m) >100	8	8	8
Chromium	ppm	ASTM D5185(m) >20	0	0	0
Nickel	ppm	ASTM D5185(m) >4	0	0	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m) >3	<1	0	0
Aluminum	ppm	ASTM D5185(m) >20	1	1	1
Lead	ppm	ASTM D5185(m) >40	2	2	2
Copper	ppm	ASTM D5185(m) >330	26	26	26
Tin	ppm	ASTM D5185(m) >15	<1	<1	<1
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	37	37	40
Barium	ppm	ASTM D5185(m)	<1	0	0
Molybdenum	ppm	ASTM D5185(m)	2	2	2
Manganese	ppm	ASTM D5185(m)	0	<1	<1
Magnesium	ppm	ASTM D5185(m)	10	10	10
Calcium	ppm	ASTM D5185(m)	1974	1975	1979
Phosphorus	ppm	ASTM D5185(m)	878	937	917
Zinc	ppm	ASTM D5185(m) 1300	1032	1034	1031
Sulfur	ppm	ASTM D5185(m)	2783	2834	2807
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS






method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m) >25	2	2	2
Sodium	ppm	ASTM D5185(m)	2	2	2
Potassium	ppm	ASTM D5185(m) >20	<1	<1	<1
Fuel	%	ASTM D7593* >5	10.2	9.5	9.2
Water	%	ASTM D6304* >0.2	0.058	0.057	0.035
ppm Water	ppm	ASTM D6304* >2000	582.4	575.8	350.8

INFRA-RED

method	limit/base	current	history1	history2	
Soot %	%	ASTM D7844* >3	0.1	0.1	0.1
Nitration	Abs/cm	ASTM D7624* >20	9.7	9.6	9.5
Sulfation	Abs./1mm	ASTM D7415* >30	20.5	20.5	20.6



OIL ANALYSIS REPORT








FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*	>25	16.7	16.7	16.9
Base Number (BN)	mg KOH/g	ASTM D2896*	11.3	5.13	5.24	5.16

VISUAL		method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	15.2	▲ 11.0	▲ 11.0	▲ 11.3

GRAPHS






Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **HIBERNIA MGMT & DEVELOPMENT CO. LTD**
Sample No. : PP **Received** : 23 Oct 2023 SUITE 1000,, 100 NEW GOWER STREET
Lab Number : 02590883 **Diagnosed** : 27 Oct 2023 ST.JOHNS, NL
Unique Number : 5667962 **Diagnostician** : Kevin Marson CA A1C 6K3
Test Package : MAR 3 (Additional Tests: KF, PercentFuel)
 Contact: Christopher Michelau
 christopher.j.michelau@exxonmobil.com
 T: (709)722-3766
 F: (709)722-3766

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.



FERROGRAPHY REPORT

Area
System 72 - Essential Power Generation
 Machine Id
Z-7201C Essential Power Diesel Engine Lube Oil
 Component
Diesel Engine
 Fluid
IRVING IDO UNIVERSAL SAE 15W40 (830 LTR)




DR-FERROGRAPHY		method	limit/base	current	history1	history2
Large Particles		DR-Ferr*		12.8	4.1	7.0
Small Particles		DR-Ferr*		6.0	1.5	6.4
Total Particles		DR-Ferr*	>---	18.8	5.6	13.4
Large Particles Percentage	%	DR-Ferr*		36.2	46.4	4.5
Severity Index		DR-Ferr*		87	11	4

FERROGRAPHY		method	limit/base	current	history1	history2
Ferrous Rubbing	Scale 0-10	ASTM D7684*		2	3	3
Ferrous Sliding	Scale 0-10	ASTM D7684*				
Ferrous Cutting	Scale 0-10	ASTM D7684*				
Ferrous Rolling	Scale 0-10	ASTM D7684*			1	1
Ferrous Break-in	Scale 0-10	ASTM D7684*				
Ferrous Spheres	Scale 0-10	ASTM D7684*				
Ferrous Black Oxides	Scale 0-10	ASTM D7684*		1	1	
Ferrous Red Oxides	Scale 0-10	ASTM D7684*				
Ferrous Corrosive	Scale 0-10	ASTM D7684*				
Ferrous Other	Scale 0-10	ASTM D7684*				
Nonferrous Rubbing	Scale 0-10	ASTM D7684*				
Nonferrous Sliding	Scale 0-10	ASTM D7684*				
Nonferrous Cutting	Scale 0-10	ASTM D7684*				
Nonferrous Rolling	Scale 0-10	ASTM D7684*				
Nonferrous Other	Scale 0-10	ASTM D7684*				
Carbonaceous Material	Scale 0-10	ASTM D7684*				
Lubricant Degradation	Scale 0-10	ASTM D7684*				
Sand/Dirt	Scale 0-10	ASTM D7684*		1	1	1
Fibres	Scale 0-10	ASTM D7684*				
Spheres	Scale 0-10	ASTM D7684*				
Other	Scale 0-10	ASTM D7684*		1	1	1

WEAR

All component wear rates are normal.
 The ferrography results are normal indicating no abnormal wear in the system.



This page left intentionally blank