




PROBLEM SUMMARY


Sample Rating Trend



Area
Site Services - TEMTEMMD
 Machine Id
N/A TM-465-315-501 #2 Allis Chalmers Compressor Motor
 Component
Drive End Bearing
 Fluid
ESSO NUTO H ISO 32 (1000 LTR)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	SEVERE	---
Particles >6µm	ASTM D7647	>320	▲ 2348	● 10296	---
Oil Cleanliness	ISO 4406 (c)	>--/15/13	▲ 22/18/12	● 23/21/15	---

Customer Id: TEMTEMMD
 Sample No.: WC0836635
 Lab Number: 02591028
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

ISO



10 Aug 2023 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Please note that this is a corrected copy for data entry updates. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report






OIL ANALYSIS REPORT

Sample Rating Trend

ISO



Area
Site Services - TEMTEMMD
 Machine Id
N/A TM-465-315-501 #2 Allis Chalmers Compressor Motor
 Component
Drive End Bearing
 Fluid
ESSO NUTO H ISO 32 (1000 LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0836635	WC	---
Sample Date	Client Info		18 Oct 2023	10 Aug 2023	---
Machine Age	mths	Client Info	0	0	---
Oil Age	mths	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			ABNORMAL	SEVERE	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	0	<1
Chromium	ppm	ASTM D5185(m)	>20	0	0
Nickel	ppm	ASTM D5185(m)	>20	0	0
Titanium	ppm	ASTM D5185(m)		0	0
Silver	ppm	ASTM D5185(m)		<1	0
Aluminum	ppm	ASTM D5185(m)	>20	<1	<1
Lead	ppm	ASTM D5185(m)	>20	<1	<1
Copper	ppm	ASTM D5185(m)	>20	1	6
Tin	ppm	ASTM D5185(m)	>20	<1	2
Antimony	ppm	ASTM D5185(m)		0	0
Vanadium	ppm	ASTM D5185(m)		0	0
Beryllium	ppm	ASTM D5185(m)		0	0
Cadmium	ppm	ASTM D5185(m)		0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<1	<1
Barium	ppm	ASTM D5185(m)	0	<1	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)		0	0
Magnesium	ppm	ASTM D5185(m)	5	0	<1
Calcium	ppm	ASTM D5185(m)	50	52	57
Phosphorus	ppm	ASTM D5185(m)	330	351	360
Zinc	ppm	ASTM D5185(m)	420	444	440
Sulfur	ppm	ASTM D5185(m)	2700	4585	4487
Lithium	ppm	ASTM D5185(m)		<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	0	0
Sodium	ppm	ASTM D5185(m)		0	<1
Potassium	ppm	ASTM D5185(m)	>20	0	<1
Water	%	ASTM D6304*	>2	0.003	0.001
ppm Water	ppm	ASTM D6304*		36.9	10.9


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		20646	57082	---
Particles >6µm	ASTM D7647	>320	2348	10296	---
Particles >14µm	ASTM D7647	>80	27	244	---
Particles >21µm	ASTM D7647	>20	4	45	---
Particles >38µm	ASTM D7647	>4	0	1	---
Particles >71µm	ASTM D7647	>3	0	0	---
Oil Cleanliness	ISO 4406 (c)	>--/15/13	22/18/12	23/21/15	---




OIL ANALYSIS REPORT


Particle Trend




Water (KF)




Acid Number



Water (KF)



Viscosity @ 40°C



FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN) mg KOH/g	ASTM D974*	.40	0.50	0.47	---


VISUAL

method	limit/base	current	history1	history2		
White Metal	scalar	Visual*	NONE	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	NORML	---
Emulsified Water	scalar	Visual*	>2	NEG	NEG	---
Free Water	scalar	Visual*		NEG	NEG	---

FLUID PROPERTIES

method	limit/base	current	history1	history2	
Visc @ 40°C cSt	ASTM D7279(m)	32.6	31.7	31.4	---

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals



Viscosity @ 40°C



Particle Count



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0836635 **Received** : 23 Oct 2023
Lab Number : 02591028 **Diagnosed** : 25 Oct 2023
Unique Number : 5668107 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Rayonier Advanced Materials
 P.O.Box 6000, 33 Kipawa Road
 Temiscaming, QC
 CA J0Z 3R0
 Contact: Adouniss El Yaqoti
 Adouniss.Elyaqoti@rayonieram.com
 T: (819)627-4931
 F: (819)627-1507