




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
EHG3 CENTRAK

Component
Bearing

Fluid
MOBIL DTE EXCEL ISO 68 (70 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal. The ferrography results are normal indicating no abnormal wear in the system.

Contaminants

There is no indication of any contamination in the oil.

Oil Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0815814	WC0736162	---
Sample Date	Client Info		19 Oct 2023	18 May 2023	---
Machine Age	mths	Client Info	31	26	---
Oil Age	mths	Client Info	5	26	---
Oil Changed	Client Info		Not Changed	Changed	---
Sample Status			NORMAL	ABNORMAL	---

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	0	---
Iron	ppm	ASTM D5185(m) >20	0	1	---
Chromium	ppm	ASTM D5185(m) >20	0	0	---
Nickel	ppm	ASTM D5185(m) >20	0	<1	---
Titanium	ppm	ASTM D5185(m)	0	0	---
Silver	ppm	ASTM D5185(m)	<1	0	---
Aluminum	ppm	ASTM D5185(m) >20	<1	0	---
Lead	ppm	ASTM D5185(m) >20	<1	2	---
Copper	ppm	ASTM D5185(m) >20	4	10	---
Tin	ppm	ASTM D5185(m) >20	0	1	---
Antimony	ppm	ASTM D5185(m)	0	<1	---
Vanadium	ppm	ASTM D5185(m)	0	0	---
Beryllium	ppm	ASTM D5185(m)	0	0	---
Cadmium	ppm	ASTM D5185(m)	0	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	<1	---
Barium	ppm	ASTM D5185(m)	<1	0	---
Molybdenum	ppm	ASTM D5185(m)	0	0	---
Manganese	ppm	ASTM D5185(m)	0	0	---
Magnesium	ppm	ASTM D5185(m)	0	0	---
Calcium	ppm	ASTM D5185(m)	0	0	---
Phosphorus	ppm	ASTM D5185(m)	133	132	---
Zinc	ppm	ASTM D5185(m)	75	56	---
Sulfur	ppm	ASTM D5185(m)	334	589	---
Lithium	ppm	ASTM D5185(m)	<1	<1	---

CONTAMINANTS




	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	0	2	---
Sodium	ppm	ASTM D5185(m)	0	<1	---
Potassium	ppm	ASTM D5185(m) >20	0	<1	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974* .2	0.13	0.12	---




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	---
Silt	scalar	Visual*	NONE	VLITE	---
Debris	scalar	Visual*	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	▲ LAYRD
Odor	scalar	Visual*	NORML	NORML	---
Emulsified Water	scalar	Visual*	>2	NEG	1%
Free Water	scalar	Visual*		NEG	▲ >10%

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	68	68.0	69.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **Chaudiere Hydro LP - Energy Ottawa**
Sample No. : WC0815814 **Received** : 23 Oct 2023 4 Booth Street
Lab Number : 02591045 **Diagnosed** : 30 Oct 2023 Ottawa, ON
Unique Number : 5668124 **Diagnostician** : Kevin Marson CA K1R 6K8
Test Package : IND 3




To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Contact: Cheryl Gharib
 info@portagepower.com
 T:
 F: x:



FERROGRAPHY REPORT

Machine Id
EHG3 CENTRAK
 Component
Bearing
 Fluid
MOBIL DTE EXCEL ISO 68 (70 LTR)




DR-FERROGRAPHY		method	limit/base	current	history1	history2
Large Particles		DR-Ferr*		1.0	0.5	---
Small Particles		DR-Ferr*		0.4	0.9	---
Total Particles		DR-Ferr*	>---	1.4	1.4	---
Large Particles Percentage	%	DR-Ferr*		42.9	0	---
Severity Index		DR-Ferr*		1	0	---

FERROGRAPHY		method	limit/base	current	history1	history2
Ferrous Rubbing	Scale 0-10	ASTM D7684*		2	2	
Ferrous Sliding	Scale 0-10	ASTM D7684*				
Ferrous Cutting	Scale 0-10	ASTM D7684*			▲ 1	
Ferrous Rolling	Scale 0-10	ASTM D7684*		■ 1	■ 1	
Ferrous Break-in	Scale 0-10	ASTM D7684*				
Ferrous Spheres	Scale 0-10	ASTM D7684*				
Ferrous Black Oxides	Scale 0-10	ASTM D7684*				
Ferrous Red Oxides	Scale 0-10	ASTM D7684*				
Ferrous Corrosive	Scale 0-10	ASTM D7684*				
Ferrous Other	Scale 0-10	ASTM D7684*				
Nonferrous Rubbing	Scale 0-10	ASTM D7684*				
Nonferrous Sliding	Scale 0-10	ASTM D7684*				
Nonferrous Cutting	Scale 0-10	ASTM D7684*				
Nonferrous Rolling	Scale 0-10	ASTM D7684*				
Nonferrous Other	Scale 0-10	ASTM D7684*				
Carbonaceous Material	Scale 0-10	ASTM D7684*				
Lubricant Degradation	Scale 0-10	ASTM D7684*				
Sand/Dirt	Scale 0-10	ASTM D7684*		■ 1	■ 1	
Fibres	Scale 0-10	ASTM D7684*				
Spheres	Scale 0-10	ASTM D7684*				
Other	Scale 0-10	ASTM D7684*		■ 1	■ 1	

WEAR

All component wear rates are normal. The ferrography results are normal indicating no abnormal wear in the system.



This page left intentionally blank