




# PROBLEM SUMMARY

Sample Rating Trend


ISO

Area  
**M13**  
 Machine Id  
**71-GG-3300A MAIN POWER GAS GENERATOR A (71-T-3390A) (S/N Maint Plan 22480)**  
 Component  
**Jet Turbine**  
 Fluid  
**MOBIL JET OIL II (924 LTR)**



## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ABNORMAL	ATTENTION
Particles >4µm	ASTM D7647	>2500	<b>▲ 7893</b>	▲ 8972	▲ 3693
Particles >6µm	ASTM D7647	>640	<b>▲ 2415</b>	▲ 2254	▲ 654
Particles >14µm	ASTM D7647	>80	<b>▲ 142</b>	▲ 119	22
Oil Cleanliness	ISO 4406 (c)	>18/16/13	<b>▲ 20/18/14</b>	▲ 20/18/14	▲ 19/17/12

Customer Id: SPESTJ  
 Sample No.: PP  
 Lab Number: 02591387  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

## HISTORICAL DIAGNOSIS

### 23 Aug 2023 Diag: Bill Quesnel

#### WATER



We advise that you check for the source of water entry. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)



### 18 Jul 2023 Diag: Kevin Marson

#### ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 23 Jun 2023 Diag: Kevin Marson

#### ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


[view report](#)





# OIL ANALYSIS REPORT

Sample Rating Trend



Area  
**M13**  
 Machine Id  
**71-GG-3300A MAIN POWER GAS GENERATOR A (71-T-3390A) (S/N Maint Plan 22480)**  
 Component  
**Jet Turbine**  
 Fluid  
**MOBIL JET OIL II (924 LTR)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PP</b>	PP	PP
Sample Date	Client Info	<b>11 Sep 2023</b>	23 Aug 2023	18 Jul 2023
Machine Age	hrs	<b>0</b>	0	0
Oil Age	hrs	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ATTENTION

## WEAR METALS

method	limit/base	current	history1	history2		
Iron	ppm	ASTM D5185(m)	>8	<1	2	1
Chromium	ppm	ASTM D5185(m)	>2	0	0	0
Nickel	ppm	ASTM D5185(m)	>2	<1	<1	0
Titanium	ppm	ASTM D5185(m)	>2	0	0	0
Silver	ppm	ASTM D5185(m)	>2	<1	<1	<1
Aluminum	ppm	ASTM D5185(m)	>2	0	<1	0
Lead	ppm	ASTM D5185(m)	>3	<1	0	0
Copper	ppm	ASTM D5185(m)	>3	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>2	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

## ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185(m)		<1	<1	
Barium	ppm	ASTM D5185(m)		0	0	
Molybdenum	ppm	ASTM D5185(m)		0	0	
Manganese	ppm	ASTM D5185(m)		0	0	
Magnesium	ppm	ASTM D5185(m)		0	<1	
Calcium	ppm	ASTM D5185(m)		0	<1	
Phosphorus	ppm	ASTM D5185(m)		<b>2971</b>	3004	2887
Zinc	ppm	ASTM D5185(m)		<1	2	2
Sulfur	ppm	ASTM D5185(m)		0	<1	1
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

## CONTAMINANTS






method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185(m)	>8	0	<1	<1
Sodium	ppm	ASTM D5185(m)		<1	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	0	1	<1
Water	%	ASTM D6304*	>.1	<b>0.097</b>	▲ 0.125	0.079
ppm Water	ppm	ASTM D6304*	>1000	<b>976.0</b>	▲ 1253.2	797.3

## FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>2500	▲ <b>7893</b>	▲ 8972	▲ 3693
Particles >6µm	ASTM D7647	>640	▲ <b>2415</b>	▲ 2254	▲ 654
Particles >14µm	ASTM D7647	>80	▲ <b>142</b>	▲ 119	22
Particles >21µm	ASTM D7647	>20	<b>25</b>	▲ 32	7
Particles >38µm	ASTM D7647	>4	<b>2</b>	5	1
Particles >71µm	ASTM D7647	>3	<b>1</b>	1	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ <b>20/18/14</b>	▲ 20/18/14	▲ 19/17/12



# OIL ANALYSIS REPORT



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 HUSKY SEA ROSE /AKER SOLUTIONS  
**Sample No.** : PP  
**Lab Number** : 02591387  
**Unique Number** : 5668466  
**Test Package** : IND 2

**Received** : 24 Oct 2023  
**Diagnosed** : 25 Oct 2023  
**Diagnostician** : Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

PO BOX 20  
 ST. JOHN'S, NL  
 CA A1C 6C9  
 Contact: Nick Fewer  
 nick.fewer@akersolutions.com  
 T: (709)757-4582  
 F: (709)722-8730

FLUID DEGRADATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.03	<b>0.09</b>	0.10	0.13

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	VLITE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>.1	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	27.6	<b>25.8</b>	25.6	25.7

SAMPLE IMAGES	method	limit/base	current	history1	history2	
Color						
Bottom						
PrtFilter				no image	no image	no image