PROBLEM SUMMARY

Sample Rating Trend



ISO

Area
M13
Machine Id
71-GG-3300C MAIN POWER GAS GENERATOR C (71-T-3390C) (S/N Maint Plan 22480)
Component
Jet Turbine
Fluid
MOBIL JET OIL II (924 LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	NORMAL
Particles >4µm		ASTM D7647	>2500	▲ **3200**	▲ 4959	1534
Particles >6µm		ASTM D7647	>640	▲ **895**	▲ 1239	283
Particles >14µm		ASTM D7647	>80	▲ **111**	▲ 98	20
Particles >21µm		ASTM D7647	>20	▲ **43**	26	7
Particles >38µm		ASTM D7647	>4	▲ **10**	2	1
Particles >71µm		ASTM D7647	>3	▲ **6**	2	0
Oil Cleanliness		ISO 4406 (c)	>18/16/13	▲ **19/17/14**	▲ 19/17/14	18/15/11

Customer Id: SPESTJ
Sample No.: PP
Lab Number: 02591393
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

23 Aug 2023 Diag: Bill Quesnel

WATER

We advise that you check for the source of water entry. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report

18 Jul 2023 Diag: Kevin Marson

NORMAL

Resample at the next service interval to monitor.All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

23 May 2023 Diag: Kevin Marson

ISO

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.All component wear rates are normal. There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Area
M13
Machine Id
71-GG-3300C MAIN POWER GAS GENERATOR C (71-T-3390C) (S/N Maint Plan 22480)
Component
Jet Turbine
Fluid
MOBIL JET OIL II (924 LTR)

DIAGNOSIS

Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**PP**	PP	PP
Sample Date		Client Info		**11 Sep 2023**	23 Aug 2023	18 Jul 2023
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ABNORMAL**	ABNORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>8	**0**	<1	<1
Chromium	ppm	ASTM D5185(m)	>2	**0**	0	0
Nickel	ppm	ASTM D5185(m)	>2	**0**	0	0
Titanium	ppm	ASTM D5185(m)	>2	**0**	0	0
Silver	ppm	ASTM D5185(m)	>2	**<1**	0	0
Aluminum	ppm	ASTM D5185(m)	>2	**0**	0	0
Lead	ppm	ASTM D5185(m)	>3	**<1**	<1	0
Copper	ppm	ASTM D5185(m)	>3	**<1**	0	<1
Tin	ppm	ASTM D5185(m)	>2	**0**	0	0
Antimony	ppm	ASTM D5185(m)		**0**	0	0
Vanadium	ppm	ASTM D5185(m)		**0**	0	0
Beryllium	ppm	ASTM D5185(m)		**0**	0	0
Cadmium	ppm	ASTM D5185(m)		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		**<1**	0	<1
Barium	ppm	ASTM D5185(m)		**0**	0	2
Molybdenum	ppm	ASTM D5185(m)		**0**	0	0
Manganese	ppm	ASTM D5185(m)		**0**	0	0
Magnesium	ppm	ASTM D5185(m)		**0**	0	<1
Calcium	ppm	ASTM D5185(m)		**<1**	7	<1
Phosphorus	ppm	ASTM D5185(m)		**2945**	3012	2950
Zinc	ppm	ASTM D5185(m)		**1**	3	2
Sulfur	ppm	ASTM D5185(m)		**0**	17	2
Lithium	ppm	ASTM D5185(m)		**<1**	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>8	**3**	4	4
Sodium	ppm	ASTM D5185(m)		**<1**	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	**<1**	1	<1
Water	%	ASTM D6304*	>.1	**0.092**	▲ 0.116	0.080
ppm Water	ppm	ASTM D6304*	>1000	**925.2**	▲ 1169.7	802.9

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	▲ **3200**	▲ 4959	1534
Particles >6µm		ASTM D7647	>640	▲ **895**	▲ 1239	283
Particles >14µm		ASTM D7647	>80	▲ **111**	▲ 98	20
Particles >21µm		ASTM D7647	>20	▲ **43**	26	7
Particles >38µm		ASTM D7647	>4	▲ **10**	2	1
Particles >71µm		ASTM D7647	>3	▲ **6**	2	0
Oil Cleanliness		ISO 4406 (c)	>18/16/13	▲ **19/17/14**	▲ 19/17/14	18/15/11

OIL ANALYSIS REPORT

Particle Trend



Water (KF)



Acid Number



Water (KF)



Viscosity @ 40°C



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.03	**0.08**	0.08	0.09

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Precipitate	scalar	Visual*	NONE	**NONE**	NONE	NONE
Silt	scalar	Visual*	NONE	**VLITE**	NONE	NONE
Debris	scalar	Visual*	NONE	**NONE**	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	**NONE**	NONE	NONE
Appearance	scalar	Visual*	NORML	**NORML**	NORML	NORML
Odor	scalar	Visual*	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	Visual*	>.1	**NEG**	NEG	NEG
Free Water	scalar	Visual*		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	27.6	**25.1**	24.9	25.7

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **HUSKY SEA ROSE /AKER SOLUTIONS**
Sample No. : PP
Lab Number : 02591393
Unique Number : 5668472
Test Package : IND 2

Received : 24 Oct 2023
Diagnosed : 25 Oct 2023
Diagnostician : Kevin Marson

PO BOX 20
ST. JOHN`S, NL
CA A1C 6C9
Contact: Nick Fewer
nick.fewer@akersolutions.com
T: (709)757-4582
F: (709)722-8730

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.