




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
ENGINE ROOM 2ND DECK
 Machine Id
55-K-6140B INSTRUMENT & G/S AIR (S/N Maint Plan 22480)
 Component
2 Compressor
 Fluid
COMPRESSOR OIL (PAG) ISO 46 (114 LTR)



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PP	PP	PP
Sample Date	Client Info	11 Sep 2023	23 Aug 2023	18 Jul 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	NORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184*	0	0	0
Iron	ppm	ASTM D5185(m) >50	<1	1
Chromium	ppm	ASTM D5185(m) >5	0	0
Nickel	ppm	ASTM D5185(m)	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0
Silver	ppm	ASTM D5185(m)	<1	0
Aluminum	ppm	ASTM D5185(m) >15	0	<1
Lead	ppm	ASTM D5185(m) >65	1	1
Copper	ppm	ASTM D5185(m) >65	6	6
Tin	ppm	ASTM D5185(m) >10	0	0
Antimony	ppm	ASTM D5185(m)	0	0
Vanadium	ppm	ASTM D5185(m)	0	0
Beryllium	ppm	ASTM D5185(m)	0	0
Cadmium	ppm	ASTM D5185(m)	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 2	3	1
Barium	ppm	ASTM D5185(m) 525	748	789
Molybdenum	ppm	ASTM D5185(m) 10	0	0
Manganese	ppm	ASTM D5185(m)	0	0
Magnesium	ppm	ASTM D5185(m) 5	3	4
Calcium	ppm	ASTM D5185(m) 10	6	7
Phosphorus	ppm	ASTM D5185(m) 250	4	2
Zinc	ppm	ASTM D5185(m) 100	72	60
Sulfur	ppm	ASTM D5185(m) 400	261	267
Lithium	ppm	ASTM D5185(m)	<1	<1

CONTAMINANTS





method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >35	1	2
Sodium	ppm	ASTM D5185(m)	48	45
Potassium	ppm	ASTM D5185(m) >20	5	5
Water	%	ASTM D6304* >0.8	0.556	0.674
ppm Water	ppm	ASTM D6304* >8000	5568.0	6742.4

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.54	0.46



OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	VLITE	NONE	VLITE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	VLITE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.8	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	46	52.9	55.4	47.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 HUSKY SEA ROSE /AKER SOLUTIONS
Sample No. : PP **Received** : 24 Oct 2023
Lab Number : 02591453 **Diagnosed** : 26 Oct 2023
Unique Number : 5668532 **Diagnostician** : Wes Davis
Test Package : IND 2 (Additional Tests: KF, TAN Man)
 To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

PO BOX 20
 ST. JOHN'S, NL
 CA A1C 6C9
 Contact: Maintenance Supervisor
 maintsuper.searose@huskyenergy.ca
 T: x:
 F: x: