



# PROBLEM SUMMARY


Sample Rating Trend

ISO




Area  
**Saugeen Shores SP-17701**  
Machine ID  
**04K14**

Component  
**Wind Turbine Gearbox**  
Fluid  
**MOBIL MOBILGEAR SHC XMP 320 (320 LTR)**



## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	NORMAL	NORMAL
Particles >6µm	ASTM D7647	>10000	▲ 53930	665	1786
Particles >14µm	ASTM D7647	>1300	▲ 7277	48	142
Particles >21µm	ASTM D7647	>320	▲ 1902	12	32
Oil Cleanliness	ISO 4406 (c)	>--/20/17	▲ 24/23/20	19/17/13	20/18/14

Customer Id: VESTAS  
Sample No.: WC0835306  
Lab Number: 02591543  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

## HISTORICAL DIAGNOSIS

### 17 Oct 2022 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 25 Oct 2021 Diag: Bill Quesnel

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 28 Oct 2020 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






# OIL ANALYSIS REPORT

Sample Rating Trend

ISO



Area  
**Saugen Shores SP-17701**

Machine ID  
**04K14**

Component  
**Wind Turbine Gearbox**

Fluid  
**MOBIL MOBILGEAR SHC XMP 320 (320 LTR)**

## DIAGNOSIS

### Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0835306</b>	WC0632935	WC0546333
Sample Date	Client Info		<b>20 Oct 2023</b>	17 Oct 2022	25 Oct 2021
Machine Age	yrs	Client Info	<b>15</b>	14	13
Oil Age	yrs	Client Info	<b>15</b>	14	13
Oil Changed	Client Info		<b>Not Changed</b>	Not Changed	Filtered
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*	>50	<b>0</b>	0	0
Iron	ppm	ASTM D5185(m)	>75	<b>13</b>	10
Chromium	ppm	ASTM D5185(m)	>5	<b>0</b>	0
Nickel	ppm	ASTM D5185(m)	>10	<b>&lt;1</b>	0
Titanium	ppm	ASTM D5185(m)	>10	<b>0</b>	0
Silver	ppm	ASTM D5185(m)		<b>&lt;1</b>	0
Aluminum	ppm	ASTM D5185(m)	>10	<b>0</b>	<1
Lead	ppm	ASTM D5185(m)	>15	<b>&lt;1</b>	0
Copper	ppm	ASTM D5185(m)	>5	<b>2</b>	2
Tin	ppm	ASTM D5185(m)	>10	<b>0</b>	0
Antimony	ppm	ASTM D5185(m)	>5	<b>0</b>	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<b>1</b>	<1
Barium	ppm	ASTM D5185(m)		<b>0</b>	0
Molybdenum	ppm	ASTM D5185(m)	0	<b>0</b>	0
Manganese	ppm	ASTM D5185(m)		<b>0</b>	0
Magnesium	ppm	ASTM D5185(m)		<b>&lt;1</b>	0
Calcium	ppm	ASTM D5185(m)	0	<b>0</b>	0
Phosphorus	ppm	ASTM D5185(m)	485	<b>336</b>	368
Zinc	ppm	ASTM D5185(m)	0	<b>21</b>	6
Sulfur	ppm	ASTM D5185(m)		<b>3704</b>	3714
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1

## CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>40	<b>5</b>	6
Sodium	ppm	ASTM D5185(m)	>10	<b>1</b>	<1
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	0
Water	%	ASTM D6304*	>0.02	<b>0.01</b>	0.006
ppm Water	ppm	ASTM D6304*	>200	<b>100.0</b>	65.9

## INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*		<b>0</b>	0
Nitration	Abs/cm	ASTM D7624*		<b>2.1</b>	2.0
Sulfation	Abs/.1mm	ASTM D7415*		<b>47.3</b>	31.1



# OIL ANALYSIS REPORT



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Vestas American Wind Technology Inc.  
**Sample No.** : WC0835306  
**Lab Number** : 02591543  
**Unique Number** : 5668622  
**Test Package** : IND 2 ( Additional Tests: FT-IR, KF, KV100, PQ, TAN Man, VI )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>107279</b>	4290	5841
Particles >6µm	ASTM D7647	>10000	<b>▲ 53930</b>	665	1786
Particles >14µm	ASTM D7647	>1300	<b>▲ 7277</b>	48	142
Particles >21µm	ASTM D7647	>320	<b>▲ 1902</b>	12	32
Particles >38µm	ASTM D7647	>80	<b>97</b>	1	1
Particles >71µm	ASTM D7647	>20	<b>4</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/20/17	<b>▲ 24/23/20</b>	19/17/13	20/18/14

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*	<b>54.9</b>	27.5	54.4
Acid Number (AN)	mg KOH/g	ASTM D974*	<b>1.17</b>	0.87	0.74

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	<b>VLITE</b>	NONE	VLITE
Sand/Dirt	scalar	Visual*	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*	<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	<b>315</b>	318	328
Visc @ 100°C	cSt	ASTM D7279(m)	<b>35.8</b>	35.9	37.1
Viscosity Index (VI)	Scale	ASTM D2270*	<b>160</b>	159	161

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

