




PROBLEM SUMMARY


Sample Rating Trend



Area
(ZONE3) BRUCE B/7/34330
 Machine Id
7-34330-MV3 Actuator-OIL
 Component
Hydraulic System
 Fluid
ESSO NUTO H ISO 46 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

| Sample Status | | ATTENTION | ABNORMAL | NORMAL |
|-----------------|------------------------|------------|------------|----------|
| Particles >6µm | ASTM D7647 >320 | ▲ 410 | ▲ 889 | 994 |
| Oil Cleanliness | ISO 4406 (c) >19/15/12 | ▲ 18/16/12 | ▲ 21/17/13 | 19/17/14 |

Customer Id: BRUTIV
 Sample No.: WC0845477
 Lab Number: 02591780
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|----------------------|--------|------|---------|--|
| Change Filter | --- | --- | ? | We recommend you service the filters on this component. |
| Information Required | --- | --- | ? | NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. |

HISTORICAL DIAGNOSIS

12 Sep 2022 Diag: Kevin Marson

WEAR PARTICLES



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Wear particle analysis indicates that the ferrous rolling and ferrous other particles are abnormal. Oil Cleanliness are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. Particles >14µm are notably high. The water content is negligible. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



18 Aug 2021 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



04 Jan 2021 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






OIL ANALYSIS REPORT

Sample Rating Trend

ISO

Area
(ZONE3) BRUCE B/7/34330
 Machine Id
7-34330-MV3 Actuator-OIL
 Component
Hydraulic System
 Fluid
ESSO NUTO H ISO 46 (--- GAL)



DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | WC0845477 | WC0711364 | WC0603528 |
| Sample Date | Client Info | | 11 Oct 2023 | 12 Sep 2022 | 18 Aug 2021 |
| Machine Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Changed | Client Info | | N/A | N/A | N/A |
| Sample Status | | | ATTENTION | ABNORMAL | NORMAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|-------------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185(m) >10 | 0 | 0 | 0 |
| Chromium | ppm | ASTM D5185(m) >5 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185(m) >5 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185(m) >5 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185(m) | <1 | 0 | 0 |
| Aluminum | ppm | ASTM D5185(m) >5 | 0 | 0 | 0 |
| Lead | ppm | ASTM D5185(m) >5 | 0 | 1 | <1 |
| Copper | ppm | ASTM D5185(m) >5 | <1 | <1 | <1 |
| Tin | ppm | ASTM D5185(m) >5 | 0 | 0 | <1 |
| Antimony | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Vanadium | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Beryllium | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185(m) | 0 | 1 | <1 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|--------------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185(m) 0 | <1 | <1 | <1 |
| Barium | ppm | ASTM D5185(m) 0 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185(m) 0 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185(m) | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185(m) 5 | 0 | <1 | <1 |
| Calcium | ppm | ASTM D5185(m) 50 | 53 | 42 | 44 |
| Phosphorus | ppm | ASTM D5185(m) 330 | 330 | 352 | 360 |
| Zinc | ppm | ASTM D5185(m) 410 | 431 | 432 | 464 |
| Sulfur | ppm | ASTM D5185(m) 2700 | 5777 | 2540 | 2600 |
| Lithium | ppm | ASTM D5185(m) | <1 | <1 | <1 |

CONTAMINANTS






| | method | limit/base | current | history1 | history2 |
|-----------|--------|--------------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185(m) >5 | 0 | 2 | 2 |
| Sodium | ppm | ASTM D5185(m) >5 | <1 | <1 | 0 |
| Potassium | ppm | ASTM D5185(m) >20 | 0 | <1 | <1 |
| Water | % | ASTM D6304* >0.005 | 0.003 | 0.001 | 0.001 |
| ppm Water | ppm | ASTM D6304* >50 | 29.7 | 7.3 | 4.7 |

FLUID CLEANLINESS

| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|-------------------|------------|----------|
| Particles >4µm | ASTM D7647 | >5000 | 1533 | ▲ 12326 | 4016 |
| Particles >6µm | ASTM D7647 | >320 | ▲ 410 | ▲ 889 | 994 |
| Particles >14µm | ASTM D7647 | >40 | 29 | ▲ 42 | 82 |
| Particles >21µm | ASTM D7647 | >10 | 8 | 9 | 21 |
| Particles >38µm | ASTM D7647 | >3 | 1 | 0 | 1 |
| Particles >71µm | ASTM D7647 | >3 | 0 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >19/15/12 | ▲ 18/16/12 | ▲ 21/17/13 | 19/17/14 |



OIL ANALYSIS REPORT



| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|------------|------------|--------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D974* | 0.45 | 0.50 | 0.60 | 0.59 |
| VISUAL | | method | limit/base | current | history1 | history2 |
| White Metal | scalar | Visual* | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar | Visual* | NONE | NONE | NONE | NONE |
| Precipitate | scalar | Visual* | NONE | NONE | NONE | NONE |
| Silt | scalar | Visual* | NONE | NONE | NONE | NONE |
| Debris | scalar | Visual* | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar | Visual* | NONE | NONE | NONE | NONE |
| Appearance | scalar | Visual* | NORML | NORML | NORML | NORML |
| Odor | scalar | Visual* | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | Visual* | >0.005 | NEG | NEG | NEG |
| Free Water | scalar | Visual* | | NEG | NEG | NEG |

| FLUID PROPERTIES | | method | limit/base | current | history1 | history2 |
|------------------|-----|---------------|------------|-------------|----------|----------|
| Visc @ 40°C | cSt | ASTM D7279(m) | 46 | 43.2 | 46.0 | 46.0 |

| SAMPLE IMAGES | | method | limit/base | current | history1 | history2 |
|---------------|--|--------|------------|---------|----------|----------|
| Color | | | | | | |
| Bottom | | | | | | |
| PrtFilter | | | | | | |



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0845477
Lab Number : 02591780
Unique Number : 5668859
Test Package : IND 2 (Additional Tests: TAN Man)

Bruce Power - Bruce A PdM
 P.O.Box 1540, 177 Tie Road., RM-222 U2 Column 2N11 615
 Tiverton, ON
 CA N0G 2T0
 Contact: Pierre Adouki
 pierre.adouki@brucepower.com
 T: (519)361-2673
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.