




# FUEL REPORT

Sample Rating Trend



**NORMAL**



Area  
**[98898]**  
 Machine Id  
**280 SLATER**

Component  
**Diesel Fuel**  
 Fluid  
**No.2 DIESEL FUEL (LOW-SULPHUR) (--- GAL)**

## DIAGNOSIS

### Recommendation

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. Resample at the next service interval to monitor.

### Corrosion

{not applicable}

### Contaminants

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. There is no indication of any contamination in the diesel fuel.

### Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>CU0020744</b>	CU0016219	CU0014778
Sample Date	Client Info			<b>21 Oct 2023</b>	23 Jun 2020	05 May 2019
Machine Age	hrs	Client Info		<b>250</b>	0	184
Sample Status				<b>NORMAL</b>	ABNORMAL	NORMAL

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	<b>0.821</b>	0.827	0.820
Fuel Color	text	Visual Screen*	Yllow	<b>Pink</b>	Pink	Pink
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	<b>2</b>	2.0	2.1
Pensky-Martens Flash Point	°C	ASTM D7215*	52	<b>54.8</b>	61	56

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	250	<b>12</b>	20	21

DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	<b>163</b>	168	159
5% Distillation Point	°C	ASTM D2887*		<b>180</b>	187	180
10% Distill Point	°C	ASTM D2887*	201	<b>187</b>	195	189
15% Distillation Point	°C	ASTM D2887*		<b>194</b>	199	196
20% Distill Point	°C	ASTM D2887*	216	<b>201</b>	208	203
30% Distill Point	°C	ASTM D2887*	230	<b>213</b>	220	216
40% Distill Point	°C	ASTM D2887*	243	<b>227</b>	233	228
50% Distill Point	°C	ASTM D2887*	255	<b>240</b>	245	242
60% Distill Point	°C	ASTM D2887*	267	<b>254</b>	262	255
70% Distill Point	°C	ASTM D2887*	280	<b>269</b>	272	270
80% Distill Point	°C	ASTM D2887*	295	<b>286</b>	288	286
85% Distillation Point	°C	ASTM D2887*		<b>297</b>	301	295
90% Distill Point	°C	ASTM D2887*	310	<b>308</b>	309	307
95% Distillation Point	°C	ASTM D2887*		<b>328</b>	327	324
Final Boiling Point	°C	ASTM D2887*	341	<b>349</b>	346	336
Distillation Residue	%	ASTM D86(e)*	3.0	<b>---</b>	---	1.4
Distillation Loss	%	ASTM D86(e)*	3.0	<b>---</b>	---	0.5


IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	<b>40</b>	---	41.1
Cetane Index		ASTM D4737*	<40.0	<b>50</b>	49	51.6

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	<b>0</b>	0	0
Sodium	ppm	ASTM D5185(m)	<0.1	<b>0</b>	<1	<1
Potassium	ppm	ASTM D5185(m)	<0.1	<b>&lt;1</b>	<1	0
Water	%	ASTM D6304*	<0.05	<b>0.001</b>	0.002	0.002
ppm Water	ppm	ASTM D6304*	<500	<b>14.0</b>	17.3	24.0




# FUEL REPORT

Fuel Distillation Curve




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	<b>1882</b>	▲ 7892	8900
Particles >6µm	ASTM D7647	>640	<b>332</b>	▲ 2280	1377
Particles >14µm	ASTM D7647	>80	<b>8</b>	▲ 251	29
Particles >21µm	ASTM D7647	>20	<b>1</b>	▲ 113	5
Particles >38µm	ASTM D7647	>4	<b>0</b>	▲ 7	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	<b>18/16/10</b>	▲ 20/18/15	20/18/12

Particle Count




HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185(m)	<0.1	<b>0</b>	0
Nickel	ppm	ASTM D5185(m)	<0.1	<b>0</b>	0
Lead	ppm	ASTM D5185(m)	<0.1	<b>0</b>	0
Vanadium	ppm	ASTM D5185(m)	<0.1	<b>0</b>	0
Iron	ppm	ASTM D5185(m)	<0.1	<b>&lt;1</b>	<1
Calcium	ppm	ASTM D5185(m)	<0.1	<b>0</b>	0
Magnesium	ppm	ASTM D5185(m)	<0.1	<b>0</b>	0
Phosphorus	ppm	ASTM D5185(m)	<0.1	<b>0</b>	0
Zinc	ppm	ASTM D5185(m)	<0.1	<b>0</b>	0

Water (KF)



SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color




Bottom



Viscosity @ 40°C



Particle Trend



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : CU0020744 **Received** : 25 Oct 2023  
**Lab Number** : **02591880** **Diagnosed** : 30 Oct 2023  
**Unique Number** : 5668959 **Diagnostician** : Kevin Marson  
**Test Package** : FUEL ( Additional Tests: CC Flash, GC-PercFuel, PrtCount )

**CUMMINS EASTERN CANADA LP**  
 3189 SWANSEA CRESCENT  
 OTTAWA, ON  
 CA K1G 3W5  
 Contact: Cindy Harrison  
 cindy.harrison@cummins.com  
 T: (613)736-1146  
 F: x:

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.