


### **PROBLEM SUMMARY**

## Area TURRET

## 06-WY-7654 ANCHOR MOORING WINCH (S/N Maint Plan 22466)


1 Hydraulic System

**SAE 10W (--- GAL)** 





### **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use offline filtration to improve the cleanliness of the system fluid. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. DISCLAIMER: Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified.

**Customer Id: SPESTJ** Sample No.: PP Lab Number: 02592096 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

PROBLEMATIC TEST RESULTS							
Sample Status				ΑI	BNORMAL	ABNORMAL	NORMAL
Particles >4µm		ASTM D7647	>5000		8986	<u>19137</u>	1349
Particles >6µm		ASTM D7647	>1300		1698	<b>▲</b> 3024	235
Oil Cleanliness		ISO 4406 (c)	>19/17/14		20/18/13	<u>^</u> 21/19/14	18/15/10
Debris	scalar	Visual*	NONE		VLITE	VLITE	NONE
PrtFilter						no image	no image

### **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Filter			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Alert			?	Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any perfinent information to allow for a more accurate assessment. We suspect that the abnormal contamination is the result of incorrect sampling technique. DISCLAIMER: Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified.
Information Required			?	Please specify the brand, type, and viscosity of the oil on your next sample. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Dirt Access			?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

### HISTORICAL DIAGNOSIS

WATER



#### 27 Jul 2023 Diag: Kevin Marson

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. Free water present. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



NODMAL



### 22 May 2023 Diag: Kevin Marson

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



NORMAL



### 05 Feb 2023 Diag: Wes Davis

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





### **OIL ANALYSIS REPORT**

## Sample Rating Trend

SAMPLE INFORMATION

Sample Number

method


Client Info

# Area TURRET

### 06-WY-7654 ANCHOR MOORING WINCH (S/N Maint Plan 22466)

1 Hydraulic System

**SAE 10W (--- GAL)** 



PP

current

limit/base



PP

history2

history1

PP

### **DIAGNOSIS**

#### Recommendation

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use offline filtration to improve the cleanliness of the system fluid. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique.

DISCLAIMER: Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified.

#### Wear

All component wear rates are normal.


### Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil. Light concentration of visible dirt/debris present in the oil. The water content is negligible.

### **Fluid Condition**

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


Sample Date		Client Info		18 Sep 2023	27 Jul 2023	22 May 2023
Machine Age	days	Client Info		0	0	0
Oil Age	days	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				<b>ABNORMAL</b>	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	<1	<1	<1
Chromium	ppm	ASTM D5185(m)	>10	0	0	0
Nickel	ppm	ASTM D5185(m)	>10	<1	<1	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		<1	<1	0
Aluminum	ppm	ASTM D5185(m)	>10	0	<1	0
Lead	ppm	ASTM D5185(m)	>20	<1	0	<1
Copper	ppm	ASTM D5185(m)	>20	1	1	1
Tin	ppm	ASTM D5185(m)	>10	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		1	<1	<1
Barium	ppm	ASTM D5185(m)		<1	0	0
Molybdenum	ppm	ASTM D5185(m)		0	0	0
Manganese	ppm	ASTM D5185(m)		0	0	0
Magnesium	ppm	ASTM D5185(m)		1	1	2
Calcium	ppm	ASTM D5185(m)		127	126	132
Phosphorus	ppm	ASTM D5185(m)		491	545	532
Zinc	ppm	ASTM D5185(m)		650	669	655
Sulfur	ppm	ASTM D5185(m)		3805	3912	4015
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	<1	<1	<1
Sodium	ppm	ASTM D5185(m)		2	2	2
Potassium	ppm	ASTM D5185(m)	>20	0	<1	0
Water	%	ASTM D6304*	>0.05	0.025		
ppm Water	ppm	ASTM D6304*	>500	250.8		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	<b>A</b> 8986	<b>▲</b> 19137	1349
Particles >6µm		ASTM D7647	>1300	<u> </u>	▲ 3024	235
Particles >14µm		ASTM D7647	>160	71	88	8
Particles >21µm		ASTM D7647	>40	13	20	2
Particles >38um		ACTM D7647	× 10	4	1	1



FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4μm	ASTM D7647	>5000	<b>A</b> 8986	<u></u> 19137	1349
Particles >6µm	ASTM D7647	>1300	<u> </u>	▲ 3024	235
Particles >14μm	ASTM D7647	>160	71	88	8
Particles >21µm	ASTM D7647	>40	13	20	2
Particles >38μm	ASTM D7647	>10	1	1	1
Particles >71μm	ASTM D7647	>3	1	0	1
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>20/18/13</b>	<u>\$\lambda\$\$ 21/19/14</u>	18/15/10



### **OIL ANALYSIS REPORT**



FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		1.06	0.86	1.01
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	▲ VLITE	VLITE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	▲ WGOIL	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	Visual*	>0.05	.2%	.2%	NEG
Free Water	scalar	Visual*		NEG	<b>△</b> 1%	NEG
FLUID PROPERT	TES	method	limit/base	current	history1	history2
FLUID PROPERT Visc @ 40°C	TIES cSt	method ASTM D7279(m)	limit/base 35.0	current 33.2	history1 32.4	history2 33.3
	cSt				,	,
Visc @ 40°C	cSt	ASTM D7279(m)	35.0	33.2	32.4	33.3
Visc @ 40°C SAMPLE IMAGES	cSt	ASTM D7279(m)	35.0	33.2	32.4	33.3



CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number **Unique Number** 

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 HUSKY SEA ROSE /AKER SOLUTIONS : PP

: 02592096 : 5669175

Received Diagnosed

: 26 Oct 2023 : 01 Nov 2023

Diagnostician : Kevin Marson

PO BOX 20 ST. JOHN'S, NL CA A1C 6C9

Test Package : IND 2 ( Additional Tests: BottomAnalysis, FILTERPATCH, KF, PrtF@entact: Maintenance Supervisor To discuss this sample report, contact Customer Service at 1-800-268-2131. maintsuper.searose@huskyenergy.ca

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

T: x: F: x: