

# **PROBLEM SUMMARY**

# Sample Rating Trend

ISO




SAB2
Machine Id
SAB2 G25

Component
Thrust Bearing

ESSO TERESSO ISO 46 (3182 LTR)

## **COMPONENT CONDITION SUMMARY**



## RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

PROBLEMATIC TEST RESULTS							
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL		
Particles >4μm	ASTM D7647	>10000	<b>33194</b>	<b>4</b> 0385	<u>^</u> 22913		
Particles >6μm	ASTM D7647	>1300	<b>2085</b>	<b>▲</b> 3236	1020		
Oil Cleanliness	ISO 4406 (c)	>20/17/14	<u>22/18/11</u>	<b>23/19/13</b>	<u>^</u> 22/17/11		
PrtFilter			***				

Customer Id: ONTQUE Sample No.: WC0858108 Lab Number: 02592138 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

### RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.
Resample			?	We recommend an early resample to monitor this condition.
Contact Required			?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert			?	NOTE: We recommend using IND 3 test kits,

## HISTORICAL DIAGNOSIS

### 31 Jul 2023 Diag: Kevin Marson

 $\Lambda$ 

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.Component wear rates appear to be normal (unconfirmed). There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



## 05 Jun 2023 Diag: Kevin Marson



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.Component wear rates appear to be normal (unconfirmed). There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



#### 26 Jan 2023 Diag: Kevin Marson





We advise that you check for visible metal particles in the oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Light concentration of visible metal present. Particles >4µm and oil cleanliness are abnormally high. Particles >6µm are notably high. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid.





# **OIL ANALYSIS REPORT**

Manganese

Magnesium

**Phosphorus** 

**CONTAMINANTS** 

Calcium

Zinc

Sulfur

Lithium

# Sample Rating Trend



ISO



# SAB2 Machine Id SAB2 G25

Thrust Bearing

ESSO TERESSO ISO 46 (3182 LTR)

## DIAGNOSIS

#### Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

#### Wear

Component wear rates appear to be normal (unconfirmed).

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.

## **Fluid Condition**

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0858108	WC0830408	WC0780482
Sample Date		Client Info		25 Oct 2023	31 Jul 2023	05 Jun 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>85	6	7	6
Chromium	ppm	ASTM D5185(m)	>20	0	0	0
Nickel	ppm	ASTM D5185(m)	>20	<1	<1	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		<1	0	0
Aluminum	ppm	ASTM D5185(m)	>40	<1	0	0
Lead	ppm	ASTM D5185(m)	>60	0	<1	0
Copper	ppm	ASTM D5185(m)	>7	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>40	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<1	0	<1
Barium	ppm	ASTM D5185(m)		<1	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0

0

0

<1

2

<1

689

<1

ASTM D5185(m)

ASTM D5185(m) O

ASTM D5185(m) O

ASTM D5185(m) O

ASTM D5185(m)

ASTM D5185(m)

ASTM D5185(m) 2.4

ppm

ppm

ppm

ppm

ppm

ppm

ppm

0

0

<1

2

2

753

<1


<1

0

<1

700

<1




Silicon	ppm	ASTM D5185(m)	>20	<1	<1	<1
Sodium	ppm	ASTM D5185(m)		0	0	<1
Potassium	ppm	ASTM D5185(m)	>20	0	<1	<1
FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<b>33194</b>	<b>▲</b> 40385	<u>22913</u>
Particles >6µm		ASTM D7647	>1300	<b>2085</b>	<b>▲</b> 3236	1020
Particles >14µm		ASTM D7647	>160	15	63	18
Particles >21µm		ASTM D7647	>40	4	15	5
Particles >38µm		ASTM D7647	>10	1	0	0
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>20/17/14	<u>22/18/11</u>	<b>△</b> 23/19/13	<u>22/17/11</u>
FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.02	0.11	0.03	0.05

limit/base



# **OIL ANALYSIS REPORT**







Laboratory Sample No. Lab Number **Unique Number** 

: WC0858108 : 02592138

: 5669217

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received

: 26 Oct 2023 Diagnosed : 30 Oct 2023 Diagnostician : Kevin Marson

**Ontario Power Generation** NIAGARA PLANT GROUP,, 14000 NIAGARA PKWY NIAGARA ON THE LAKE, ON

CA LOS 1J0

Test Package : IND 2 ( Additional Tests: BottomAnalysis, FilterPatch, PrtFilter, TAN Macontact: Alex Courtemanche To discuss this sample report, contact Customer Service at 1-800-268-2131.

alex.courtemanche@opg.com T: (905)357-0322

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Submitted By: ?