




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
GENERAL ELECTRIC SLSMC G2

Component
Circulating Turbine

Fluid
ESSO NUTO H ISO 68 (450 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0690616	WC0690614	WC0690612
Sample Date	Client Info		26 Oct 2023	26 Apr 2023	26 Oct 2022
Machine Age	mths	Client Info	0	0	0
Oil Age	mths	Client Info	192	186	179
Oil Changed	Client Info		Not Changed	Not Changd	Not Changed
Sample Status			NORMAL	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>15	2	2	2
Chromium	ppm	ASTM D5185(m)	>4	0	0	0
Nickel	ppm	ASTM D5185(m)	>2	0	<1	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		<1	0	<1
Aluminum	ppm	ASTM D5185(m)	>10	0	0	0
Lead	ppm	ASTM D5185(m)		7	6	6
Copper	ppm	ASTM D5185(m)	>5	85	86	87
Tin	ppm	ASTM D5185(m)	>5	0	<1	<1
Antimony	ppm	ASTM D5185(m)		0	<1	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	0	<1	<1	0
Barium	ppm	ASTM D5185(m)	0	<1	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)		0	<1	<1
Magnesium	ppm	ASTM D5185(m)	5	0	<1	0
Calcium	ppm	ASTM D5185(m)	50	39	41	42
Phosphorus	ppm	ASTM D5185(m)	330	325	376	376
Zinc	ppm	ASTM D5185(m)	420	411	416	417
Sulfur	ppm	ASTM D5185(m)	3100	3647	3801	3835
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS





	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	<1	<1	<1
Sodium	ppm	ASTM D5185(m)		<1	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	<1	0	<1
Water	%	ASTM D6304*	>0.03	0.001	0.002	0.002
ppm Water	ppm	ASTM D6304*	>300	5.2	17.8	21.6

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	326	335	174
Particles >6µm	ASTM D7647	>640	115	127	65
Particles >14µm	ASTM D7647	>80	8	15	8
Particles >21µm	ASTM D7647	>20	2	6	2
Particles >38µm	ASTM D7647	>4	1	1	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	16/14/10	16/14/11	15/13/10




OIL ANALYSIS REPORT



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	.40	0.53	0.46	0.41
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.03	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	68.8	66.8	67.2	67.2

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **ST. LAWRENCE SEAWAY AUTHORITY**
Sample No. : WC0690616 **Received** : 27 Oct 2023 508 GLENDALE AVENUE, P.O. BOX 370
Lab Number : **02592408** **Diagnosed** : 30 Oct 2023 ST. CATHARINES, ON
Unique Number : 5669487 **Diagnostician** : Kevin Marson CA L2R 6V8
Test Package : IND 2

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.
 Contact: Scott Frick
 sfrick@seaway.ca
 T: (905)641-1932
 F: (905)641-1745