PROBLEM SUMMARY

Sample Rating Trend



WEAR

Machine Id
FPD G THBR 02
Component
Bearing
Fluid
ESSO TERESSO ISO 68 (5 LTR)

COMPONENT CONDITION SUMMARY

Non-ferrous Metals



Additives



RECOMMENDATION

We recommend that you drain the oil from the component if this has not already been done. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ATTENTION	NORMAL
Lead	ppm	ASTM D5185(m)	>161	▲ **175**	121	163
Phosphorus	ppm	ASTM D5185(m)	0.7	▲ **48**	▲ 57	0
Zinc	ppm	ASTM D5185(m)	0	▲ **27**	▲ 32	3

Customer Id: NEWSTJ
Sample No.: WC0328082
Lab Number: 02592414
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil from the component if this has not already been done.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.

HISTORICAL DIAGNOSIS

20 Mar 2023 Diag: Bill Quesnel

ADDITIVES

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

17 Oct 2022 Diag: Kevin Marson

NORMAL

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

20 Oct 2021 Diag: Kevin Marson

NORMAL

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

OIL ANALYSIS REPORT

Sample Rating Trend



WEAR

Machine Id
FPD G THBR 02
Component
Bearing
Fluid
ESSO TERESSO ISO 68 (5 LTR)

DIAGNOSIS

Recommendation
We recommend that you drain the oil from the component if this has not already been done. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

Wear
Lead ppm levels are abnormal. Bearing wear is indicated.

Contamination
There is no indication of any contamination in the oil.

Fluid Condition
Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0328082**	WC0328080	WC0445249
Sample Date		Client Info		**11 Oct 2023**	20 Mar 2023	17 Oct 2022
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**Not Changd**	Not Changd	Not Changd
Sample Status				**ABNORMAL**	ATTENTION	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*		**0**	0	0
Iron	ppm	ASTM D5185(m)	>63	**3**	2	2
Chromium	ppm	ASTM D5185(m)	>20	**0**	0	0
Nickel	ppm	ASTM D5185(m)	>20	**0**	<1	0
Titanium	ppm	ASTM D5185(m)		**0**	0	0
Silver	ppm	ASTM D5185(m)		**<1**	0	0
Aluminum	ppm	ASTM D5185(m)	>2	**0**	<1	<1
Lead	ppm	ASTM D5185(m)	>161	▲ **175**	121	163
Copper	ppm	ASTM D5185(m)	>13	**<1**	<1	<1
Tin	ppm	ASTM D5185(m)	>27	**5**	6	5
Antimony	ppm	ASTM D5185(m)		**4**	6	4
Vanadium	ppm	ASTM D5185(m)		**0**	0	0
Beryllium	ppm	ASTM D5185(m)		**0**	0	0
Cadmium	ppm	ASTM D5185(m)		**<1**	<1	<1

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	4.5	**<1**	<1	<1
Barium	ppm	ASTM D5185(m)	0.4	**<1**	0	<1
Molybdenum	ppm	ASTM D5185(m)	0	**0**	0	0
Manganese	ppm	ASTM D5185(m)		**0**	0	0
Magnesium	ppm	ASTM D5185(m)	0	**0**	<1	0
Calcium	ppm	ASTM D5185(m)	0	**<1**	0	0
Phosphorus	ppm	ASTM D5185(m)	0.7	▲ **48**	▲ 57	0
Zinc	ppm	ASTM D5185(m)	0	▲ **27**	▲ 32	3
Sulfur	ppm	ASTM D5185(m)	1315	**2307**	2330	2275
Lithium	ppm	ASTM D5185(m)		**<1**	<1	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>12	**<1**	<1	0
Sodium	ppm	ASTM D5185(m)		**<1**	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	**0**	0	<1

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.02	**0.18**	0.18	0.19

OIL ANALYSIS REPORT

Additives



Additives



Acid Number



Viscosity @ 40°C



PQ



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	**NONE**	NONE	NONE
Precipitate	scalar	Visual*	NONE	**NONE**	NONE	NONE
Silt	scalar	Visual*	NONE	**NONE**	NONE	NONE
Debris	scalar	Visual*	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	**NONE**	NONE	NONE
Appearance	scalar	Visual*	NORML	**NORML**	NORML	NORML
Odor	scalar	Visual*	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	Visual*	>2	**NEG**	NEG	NEG
Free Water	scalar	Visual*		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	68	**67.0**	67.0	68.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS

Ferrous Alloys



PQ



Non-ferrous Metals



Viscosity @ 40°C



Acid Number



ISO 17025:2017 Accredited Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0328082 **Received** : 27 Oct 2023
Lab Number : 02592414 **Diagnosed** : 27 Oct 2023
Unique Number : 5669493 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.

NEWFOUNDLAND POWER INC.
50 DUFFY PLACE, PO BOX 8910
ST. JOHNS, NL
CA A1B 3P6
Contact: Paul Martin
pmartin@newfoundlandpower.com
T:
F: (709)737-2926