

COOLANT REPORT

NORMAL



1681 - LAKEWOOD PUMP STATION

Component

Coolant

HYBRID (HOAT) COOLANT (--- GAL)

DIAGNOSIS

Recommendation

The fluid is suitable for further service. Resample at the next service interval to monitor.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition

The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.

I			
	w2022	Sep2023	


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0860150	WC0747649	
Sample Date		Client Info		25 Sep 2023	08 Nov 2022	
Machine Age	hrs	Client Info		132	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
PHYSICAL TEST R	RESULTS	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*		1.069	1.068	
pH	Scale 0-14	ASTM D1287*		7.54	7.80	
Nitrites	ppm	Alcan Test Kit*		1080	1000	
Reserve Alkalinity	Scale 0-20	ASTM D1121*		7.0	6.9	
Percentage Glycol	%	ASTM D3321*		51.0	50.5	
Freezing Point	°C	ASTM D3321*		-38	-35	
Carboxylate						
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		9	10	
Phosphorus	ppm	ASTM D5185(m)		11	18	
Boron	ppm	ASTM D5185(m)		1476	1058	
Molybdenum	ppm	ASTM D5185(m)		<1	3	
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>15	2	2	
Aluminum	ppm	ASTM D5185(m)	>10	4	3	
Copper	ppm	ASTM D5185(m)	>10	2	2	
Lead	ppm	ASTM D5185(m)	>10	0	<1	
Tin	ppm	ASTM D5185(m)	>10	0	0	
Silver	ppm	ASTM D5185(m)	>10	1	0	
Zinc	ppm	ASTM D5185(m)		10	10	
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		9315	3696	
Potassium	ppm	ASTM D5185(m)		160	182	
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	>100	3	10	
Magnesium	ppm	ASTM D5185(m)	>40	1	<1	
Hardness	mg/L CaCO3	In-house*	<75	13	27	
VISUAL		method	limit/base	current	history1	history2
Coolant Color		Visual*		Grn/Yellow	Grn/Yellow	
Coolant Appearance		Visual*	Clear	Clear	Clear	
Color				WGOSE	2002	no image

Bottom

no image



COOLANT REPORT





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number Unique Number : 5669843 Test Package : COOL

: WC0860150 : 02592764

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9

Received : 30 Oct 2023 Diagnosed : 31 Oct 2023 Diagnostician : Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Lighthouse Electric 6714 6th Conc South Amherstburg, ON CA N9V 0C8 Contact: Brad Purdie brad_lighthouse@hotmail.com T: (519)730-1310