



FUEL REPORT

Sample Rating Trend


ISO

Area
[328141]

Machine Id
G1

Component
Diesel Fuel

Fluid
No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)



DIAGNOSIS

Recommendation

Les tests de laboratoire indiquent que ce carburant peut être utilisé et qu'il répond à toutes les exigences. Le reniflard d'air doit être réparé. S'il n'est pas classé, nous vous recommandons de le remplacer par un reniflard à air adapté au micron et / ou au dessiccant. Si évalué, nous vous recommandons de réparer / remplacer le reniflard. Nous vous recommandons de filtrer ce fluide avant de l'utiliser. Échantillonner de nouveau dans 30 à 45 jours afin de contrôler la situation.

Corrosion

(sans objet)

Contaminants

Il y a une quantité élevée de matières particulaires (2 à 100 µm de taille) présente dans le carburant. La teneur en eau est négligeable.

Fuel Condition

Tous les essais en laboratoire indiquent que cet échantillon satisfait aux spécifications pour le carburant diesel à ultra-faible teneur de soufre No.2 (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORMATION

| method | limit/base | current | history1 | history2 |
|---------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | CU0021605 | CU0020357 | CU0019166 |
| Sample Date | Client Info | 16 Oct 2023 | 10 May 2023 | 19 Oct 2022 |
| Machine Age | hrs | 357 | 0 | 0 |
| Sample Status | | SEVERE | NORMAL | ABNORMAL |

PHYSICAL PROPERTIES

| method | limit/base | current | history1 | history2 | | |
|----------------------------|-------------|----------------|--------------|------------|-------|------|
| Specific Gravity | ASTM D1298* | 0.839 | 0.825 | 0.826 | 0.826 | |
| Fuel Color | text | Visual Screen* | Yllow | Red | Red | Red |
| Visc @ 40°C | cSt | ASTM D7279(m) | 3.0 | 1.9 | 2.1 | 1.9 |
| Pensky-Martens Flash Point | °C | ASTM D7215* | 52 | 55 | 54 | 55.5 |

SULFUR CONTENT

| method | limit/base | current | history1 | history2 | | |
|--------|------------|---------------|----------|-----------|---|---|
| Sulfur | ppm | ASTM D5185(m) | 10 | 12 | 6 | 0 |

DISTILLATION

| method | limit/base | current | history1 | history2 | | |
|------------------------|------------|-------------|----------|------------|-----|-----|
| Initial Boiling Point | °C | ASTM D2887* | 165 | 163 | 164 | 158 |
| 5% Distillation Point | °C | ASTM D2887* | | 181 | 185 | 181 |
| 10% Distill Point | °C | ASTM D2887* | 201 | 187 | 193 | 188 |
| 15% Distillation Point | °C | ASTM D2887* | | 193 | 200 | 194 |
| 20% Distill Point | °C | ASTM D2887* | 216 | 199 | 206 | 201 |
| 30% Distill Point | °C | ASTM D2887* | 230 | 209 | 217 | 214 |
| 40% Distill Point | °C | ASTM D2887* | 243 | 221 | 228 | 226 |
| 50% Distill Point | °C | ASTM D2887* | 255 | 232 | 240 | 239 |
| 60% Distill Point | °C | ASTM D2887* | 267 | 244 | 253 | 254 |
| 70% Distill Point | °C | ASTM D2887* | 280 | 256 | 267 | 266 |
| 80% Distill Point | °C | ASTM D2887* | 295 | 271 | 283 | 278 |
| 85% Distillation Point | °C | ASTM D2887* | | 283 | 294 | 289 |
| 90% Distill Point | °C | ASTM D2887* | 310 | 294 | 305 | 302 |
| 95% Distillation Point | °C | ASTM D2887* | | 315 | 324 | 326 |
| Final Boiling Point | °C | ASTM D2887* | 341 | 337 | 344 | 342 |

IGNITION QUALITY

| method | limit/base | current | history1 | history2 | |
|--------------|-------------|---------|-----------|----------|----|
| API Gravity | ASTM D1298* | 37.7 | 40 | 39 | 39 |
| Cetane Index | ASTM D4737* | <40.0 | 47 | 49 | 48 |

CONTAMINANTS






| method | limit/base | current | history1 | history2 | | |
|-----------|------------|---------------|----------|--------------|-------|-------|
| Silicon | ppm | ASTM D5185(m) | <1.0 | <1 | 0 | 0 |
| Sodium | ppm | ASTM D5185(m) | <0.1 | 0 | 0 | <1 |
| Potassium | ppm | ASTM D5185(m) | <0.1 | <1 | 0 | 0 |
| Water | % | ASTM D6304* | <0.05 | 0.003 | 0.003 | 0.002 |
| ppm Water | ppm | ASTM D6304* | <500 | 25.6 | 25.1 | 25.0 |

FLUID CLEANLINESS

| method | limit/base | current | history1 | history2 | |
|-----------------|--------------|-----------|-------------------|----------|------------|
| Particles >4µm | ASTM D7647 | >2500 | ▲ 19857 | 2145 | ▲ 14072 |
| Particles >6µm | ASTM D7647 | >640 | ● 7257 | 442 | ▲ 2593 |
| Particles >14µm | ASTM D7647 | >80 | ● 796 | 7 | 68 |
| Particles >21µm | ASTM D7647 | >20 | ● 197 | 0 | 15 |
| Particles >38µm | ASTM D7647 | >4 | ▲ 10 | 0 | 1 |
| Particles >71µm | ASTM D7647 | >3 | 0 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >18/16/13 | ● 21/20/17 | 18/16/10 | ▲ 21/19/13 |






FUEL REPORT



| HEAVY METALS | | method | limit/base | current | history1 | history2 |
|--------------|-----|---------------|------------|---------|----------|----------|
| Aluminum | ppm | ASTM D5185(m) | <0.1 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185(m) | <0.1 | 0 | 0 | 0 |
| Lead | ppm | ASTM D5185(m) | <0.1 | <1 | 0 | ▲ 2 |
| Vanadium | ppm | ASTM D5185(m) | <0.1 | 0 | 0 | 0 |
| Iron | ppm | ASTM D5185(m) | <0.1 | <1 | <1 | <1 |
| Calcium | ppm | ASTM D5185(m) | <0.1 | <1 | <1 | <1 |
| Magnesium | ppm | ASTM D5185(m) | <0.1 | <1 | 0 | <1 |
| Phosphorus | ppm | ASTM D5185(m) | <0.1 | <1 | 0 | <1 |
| Zinc | ppm | ASTM D5185(m) | <0.1 | <1 | <1 | <1 |

| SAMPLE IMAGES | | method | limit/base | current | history1 | history2 |
|---------------|--|--------|------------|---------|----------|----------|
| Color | | | | | | |
| Bottom | | | | | | |

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : CU0021605 **Received** : 30 Oct 2023
Lab Number : 02592770 **Diagnosed** : 01 Nov 2023
Unique Number : 5669849 **Diagnostician** : Kevin Marson
Test Package : FUEL (Additional Tests: CC Flash, GC-PercFuel, PrtCount)

CUMMINS EASTERN CANADA LP
 315 AV LIBERTE
 CANDIAC, QC
 CA J5R 6Z7
 Contact: Thomas Owens
 is275@cummins.com
 T: (450)638-6863
 F: (450)638-1202

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.