




FUEL REPORT

Sample Rating Trend



WATER



Area
System 61 - Diesel
 Machine Id
F-6101B WEST RAW

Component
Diesel Fuel
 Fluid

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- LTR)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We advise that you filter this fluid before use. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition.

Corrosion

(not applicable)

Contaminants

There is a moderate amount of particulates (2 to 100 microns in size) present in the fuel. Free water present. There is no bacteria or fungus (yeast and/or mold) present in the sample. Small amount of bacteria present. No reportable mold present. No reportable yeast present.

Fuel Condition

The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PP	PP	PP
Sample Date	Client Info	14 Oct 2023	23 Jul 2023	07 Jun 2023
Machine Age	hrs	0	0	1930
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

PHYSICAL PROPERTIES

method	limit/base	current	history1	history2		
Specific Gravity	ASTM D1298*	0.839	0.838	0.837	0.837	
Fuel Color	text	Visual Screen*	Yellow	Yellow	Yellow	
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.7	2.7	2.7
Pensky-Martens Flash Point	°C	ASTM D7215*	52	64.6	64.6	63.7
Cloud Point	°C	ASTM D2500*		-15	-15	-14

SULFUR CONTENT

method	limit/base	current	history1	history2		
Sulfur	ppm	ASTM D5185(m)	10	7	6	6

DISTILLATION

method	limit/base	current	history1	history2		
Initial Boiling Point	°C	ASTM D2887*	165	175	175	174
5% Distillation Point	°C	ASTM D2887*		196	196	196
10% Distill Point	°C	ASTM D2887*	201	207	208	207
15% Distillation Point	°C	ASTM D2887*		215	217	216
20% Distill Point	°C	ASTM D2887*	216	224	225	224
30% Distill Point	°C	ASTM D2887*	230	239	241	240
40% Distill Point	°C	ASTM D2887*	243	253	254	253
50% Distill Point	°C	ASTM D2887*	255	266	268	267
60% Distill Point	°C	ASTM D2887*	267	280	282	281
70% Distill Point	°C	ASTM D2887*	280	294	296	295
80% Distill Point	°C	ASTM D2887*	295	309	311	311
85% Distillation Point	°C	ASTM D2887*		320	322	322
90% Distill Point	°C	ASTM D2887*	310	331	332	333
95% Distillation Point	°C	ASTM D2887*		349	350	351
Final Boiling Point	°C	ASTM D2887*	341	365	367	376

IGNITION QUALITY






method	limit/base	current	history1	history2	
API Gravity	ASTM D1298*	37.7	37	37	37
Cetane Index	ASTM D4737*	<40.0	50	51	51

CONTAMINANTS

method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185(m)	<1.0	0	0	0
Sodium	ppm	ASTM D5185(m)	<0.1	0	0	0
Potassium	ppm	ASTM D5185(m)	<0.1	<1	<1	<1
Water	%	ASTM D6304*	<0.05	0.014	0.005	0.005
ppm Water	ppm	ASTM D6304*	<500	143.8	50.7	53.1
Sediment	%	ASTM D1796(e)*	<0.05	0.055	0.093	0.001



FUEL REPORT




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 6277	296	▲ 4123
Particles >6µm	ASTM D7647	>640	▲ 2407	88	▲ 1160
Particles >14µm	ASTM D7647	>80	▲ 220	12	62
Particles >21µm	ASTM D7647	>20	▲ 53	3	12
Particles >38µm	ASTM D7647	>4	1	0	1
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 20/18/15	15/14/11	▲ 19/17/13

MICROBIAL	method	limit/base	current	history1	history2
Bacteria	CFU/ml ASTM D6469*	>=100000	1000	1000	▲ 10000
Yeast	CFU/ml ASTM D6469*	>=100000	0	0	0
Mold	Colonies ASTM D6469*	MODER	NONE	NONE	NONE

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm ASTM D5185(m)	<0.1	0	0	0
Nickel	ppm ASTM D5185(m)	<0.1	0	0	0
Lead	ppm ASTM D5185(m)	<0.1	0	0	0
Vanadium	ppm ASTM D5185(m)	<0.1	0	0	0
Iron	ppm ASTM D5185(m)	<0.1	<1	<1	<1
Calcium	ppm ASTM D5185(m)	<0.1	0	0	0
Magnesium	ppm ASTM D5185(m)	<0.1	0	0	0
Phosphorus	ppm ASTM D5185(m)	<0.1	0	0	0
Zinc	ppm ASTM D5185(m)	<0.1	0	0	0

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 HIBERNIA MGMT & DEVELOPMENT CO. LTD
Sample No. : PP
Lab Number : 02592773
Unique Number : 5669852
Test Package : FUEL (Additional Tests: Bacteria, CC Flash, CldPt, GC-PerFuel, PrtCount, Sediment)
Received : 30 Oct 2023
Diagnosed : 03 Nov 2023
Diagnostician : Kevin Marson
 SUITE 1000,, 100 NEW GOWER STREET ST.JOHNS, NL CA A1C 6K3
 Contact: Sam Nash samantha.m.nash@exxonmobil.com
 T: (709)722-3766

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.