



# FUEL REPORT

Sample Rating Trend

**NORMAL**



Machine Id  
**MPG B**  
Component  
**Diesel Fuel**  
Fluid  
**DIESEL FUEL No. 2 (--- LTR)**



## DIAGNOSIS

### Recommendation

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. Resample at the next service interval to monitor.

### Corrosion

{not applicable}

### Contaminants

There is no bacteria or fungus (yeast and/or mold) present in the sample. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. There is no indication of any contamination in the diesel fuel.

### Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 diesel fuel, low sulfur (US EPA/CGSB-3.517-3 type B).

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PP</b>	---	---
Sample Date	Client Info		<b>29 Oct 2023</b>	---	---
Machine Age	hrs	Client Info	<b>0</b>	---	---
Sample Status			<b>NORMAL</b>	---	---

## PHYSICAL PROPERTIES

	method	limit/base	current	history1	history2
Specific Gravity	ASTM D1298*	0.850	<b>0.837</b>	---	---
Fuel Color	text	Visual Screen*	<b>YELLOW</b>	---	---
Visc @ 40°C	cSt	ASTM D7279(m)	<b>4.1</b>	---	---
Pensky-Martens Flash Point	°C	ASTM D7215*	<b>40</b>	---	---
Cloud Point	°C	ASTM D2500*	<b>-12</b>	---	---

## SULFUR CONTENT

	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	<b>6</b>	---	---

## DISTILLATION

	method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	174	<b>175</b>	---
5% Distillation Point	°C	ASTM D2887*		<b>196</b>	---
10% Distill Point	°C	ASTM D2887*	186	<b>207</b>	---
15% Distillation Point	°C	ASTM D2887*		<b>216</b>	---
20% Distill Point	°C	ASTM D2887*	206	<b>225</b>	---
30% Distill Point	°C	ASTM D2887*	226	<b>240</b>	---
40% Distill Point	°C	ASTM D2887*	245	<b>254</b>	---
50% Distill Point	°C	ASTM D2887*	260	<b>267</b>	---
60% Distill Point	°C	ASTM D2887*	272	<b>281</b>	---
70% Distill Point	°C	ASTM D2887*	285	<b>295</b>	---
80% Distill Point	°C	ASTM D2887*	315	<b>310</b>	---
85% Distillation Point	°C	ASTM D2887*		<b>321</b>	---
90% Distill Point	°C	ASTM D2887*	360	<b>332</b>	---
95% Distillation Point	°C	ASTM D2887*		<b>350</b>	---
Final Boiling Point	°C	ASTM D2887*	>360	<b>366</b>	---

## IGNITION QUALITY

	method	limit/base	current	history1	history2
API Gravity	ASTM D1298*	35.0	<b>37</b>	---	---
Cetane Index	ASTM D4737*	<40.0	<b>51</b>	---	---


## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	<b>0</b>	---
Sodium	ppm	ASTM D5185(m)	<0.1	<b>0</b>	---
Potassium	ppm	ASTM D5185(m)	<0.1	<b>&lt;1</b>	---
Water	%	ASTM D6304*	<0.05	<b>0.002</b>	---
ppm Water	ppm	ASTM D6304*	<500	<b>23.6</b>	---
Sediment	%	ASTM D1796(e)*	<0.05	<b>0.118</b>	---




# FUEL REPORT


Fuel Distillation Curve




Particle Count




Water (KF)



Viscosity @ 40°C



Particle Trend



FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	<b>406</b>	---	---
Particles >6µm	ASTM D7647	>640	<b>156</b>	---	---
Particles >14µm	ASTM D7647	>80	<b>17</b>	---	---
Particles >21µm	ASTM D7647	>20	<b>5</b>	---	---
Particles >38µm	ASTM D7647	>4	<b>1</b>	---	---
Particles >71µm	ASTM D7647	>3	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	<b>16/14/11</b>	---	---

MICROBIAL	method	limit/base	current	history1	history2
Bacteria	CFU/ml ASTM D6469*	>=100000	<b>0</b>	---	---
Yeast	CFU/ml ASTM D6469*	>=100000	<b>0</b>	---	---
Mold	Colonies ASTM D6469*	MODER	<b>NONE</b>	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm ASTM D5185(m)	<0.1	<b>0</b>	---	---
Nickel	ppm ASTM D5185(m)	<0.1	<b>0</b>	---	---
Lead	ppm ASTM D5185(m)	<0.1	<b>0</b>	---	---
Vanadium	ppm ASTM D5185(m)	<0.1	<b>0</b>	---	---
Iron	ppm ASTM D5185(m)	<0.1	<b>&lt;1</b>	---	---
Calcium	ppm ASTM D5185(m)	<0.1	<b>0</b>	---	---
Magnesium	ppm ASTM D5185(m)	<0.1	<b>0</b>	---	---
Phosphorus	ppm ASTM D5185(m)	<0.1	<b>0</b>	---	---
Zinc	ppm ASTM D5185(m)	<0.1	<b>0</b>	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **HIBERNIA MGMT & DEVELOPMENT CO. LTD**  
**Sample No.** : PP **Received** : 30 Oct 2023 SUITE 1000,, 100 NEW GOWER STREET  
**Lab Number** : **02592777** **Diagnosed** : 03 Nov 2023 ST.JOHNS, NL  
**Unique Number** : 5669856 **Diagnostician** : Kevin Marson CA A1C 6K3  
**Test Package** : FUEL ( Additional Tests: Bacteria, CC Flash, CldPt, GC-PerFuel, PrtCount, Sediment ) **Contact:** Sam Nash  
 To discuss this sample report, contact Customer Service at 1-800-268-2131. samantha.m.nash@exxonmobil.com  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T:  
 Validity of results and interpretation are based on the sample and information as supplied. F: (709)722-3766