


COOLANT REPORT

Sample Rating Trend

WEAR

Area
[6100224943]
Machine Id
DETROIT 3D180861

Component
Coolant
Fluid
CONVENTIONAL COOLANT (--- GAL)



DIAGNOSIS

Recommendation

We recommend drain system, and refill with 50/50 antifreeze water mixture. We advise that you replenish the supplemental coolant additives (SCAs) and add per manufacturer's specifications. Recommend that you ensure the same technology coolant is being used for make-up. We recommend an early resample to monitor this condition.

Corrosion

Aluminum and iron and lead ppm levels are severe. PQ levels are severe. Copper ppm levels are abnormal. The iron level is high indicating rust in the system which clogs the cooling system. The high metal levels indicate corrosion in the system.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition

The reserve alkalinity of this fluid is lower than acceptable. The coolant is cloudy indicating either an overconcentration of coolant additives, or a mixing of incompatible coolant technologies. The glycol level is too high which leads to over-heating and additive drop-out. The low nitrite level indicates reduced cavitation protection which leads to corrosion and ammonia formation. The pH is low which causes rust formation. The specific gravity is higher than typical indicating the addition of a different type of coolant.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WA0018426	WA0012724	---
Sample Date	Client Info			01 Dec 2023	04 Nov 2022	---
Machine Age	hrs	Client Info		0	254	---
Oil Age	hrs	Client Info		0	0	---
Oil Changed	Client Info			N/A	Not Changd	---
Sample Status				SEVERE	SEVERE	---

PHYSICAL TEST RESULTS		method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*		▲ 1.101	▲ 1.104	---
pH	Scale 0-14	ASTM D1287*	9.5	▲ 7.30	▲ 7.22	---
Nitrites	ppm	Alcan Test Kit*	1500	▲ 0	▲ 480	---
Reserve Alkalinity	Scale 0-20	ASTM D1121*	8.5	▲ 5.0	▲ 3.8	---
Percentage Glycol	%	ASTM D3321*	50	● 80.5	● 83.9	---
Freezing Point	°C	ASTM D3321*	-40	● -51	● -41	---
Carboxylate				---	---	---


CORROSION INHIBITORS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		182	97	---
Phosphorus	ppm	ASTM D5185(m)		22	16	---
Boron	ppm	ASTM D5185(m)		547	576	---
Molybdenum	ppm	ASTM D5185(m)		9	1	---

CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>15	● 2594	● 595	---
Aluminum	ppm	ASTM D5185(m)	>10	● 151	▲ 28	---
Copper	ppm	ASTM D5185(m)	>10	▲ 9	3	---
Lead	ppm	ASTM D5185(m)	>10	● 21	5	---
Tin	ppm	ASTM D5185(m)	>10	4	1	---
Silver	ppm	ASTM D5185(m)	>10	<1	<1	---
Zinc	ppm	ASTM D5185(m)		8	5	---

CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		4699	2606	---
Potassium	ppm	ASTM D5185(m)		2906	2024	---


SCALE POTENTIAL		method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	>100	22	24	---
Magnesium	ppm	ASTM D5185(m)	>40	2	2	---
Hardness	mg/L CaCO3	In-house*	<75	61	66	---

VISUAL		method	limit/base	current	history1	history2
Coolant Color	Visual*	Green		Other	Other	---
Coolant Appearance	Visual*	Clear		▲ Opaque	▲ Opaque	---



COOLANT REPORT

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WA0018426 **Received** : 05 Dec 2023
Lab Number : 02601068 **Diagnosed** : 07 Dec 2023
Unique Number : 5694153 **Diagnostician** : Kevin Marson
Test Package : COOL (Additional Tests: PQ)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Wajax Power Systems
 70 Raddall Avenue
 Dartmouth, NS
 CA B3B 1T7
 Contact: Danelle Hoffman
 dhoffman@wajax.com
 T: (902)468-6200
 F: (902)468-3325