


FUEL REPORT

SCHENKER OF CANADA [148460] Machine Id 37279836

Component

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)





DIAGNOSIS

Recommendation
Laboratory test indicate that this fuel is suitable for use and meets all test requirements. Resample at the next service interval to monitor.

Corrosion

{not applicable}

Contaminants

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. There is no indication of any contamination in the diesel fuel.


Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

R) (GAL)			[Dec2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		CU0021482		
Sample Date		Client Info		04 Dec 2023		
Machine Age	hrs	Client Info		56		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.840		
Fuel Color	text	Visual Screen*	Yllow	Red		
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.4		
Pensky-Martens Flash Point	°C	ASTM D7215*	52	57.5		
SULFUR CONTE	NΤ	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	8		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	170		
5% Distillation Point	°C	ASTM D2887*		195		
10% Distill Point	°C	ASTM D2887*	201	204		
15% Distillation Point	°C	ASTM D2887*		211		
20% Distill Point	°C	ASTM D2887*	216	217		
30% Distill Point	°C	ASTM D2887*	230	229		
40% Distill Point	°C	ASTM D2887*	243	240		
50% Distill Point	°C	ASTM D2887*	255	252		
60% Distill Point	°C	ASTM D2887*	267	265		
70% Distill Point	°C	ASTM D2887*	280	278		
80% Distill Point	°C	ASTM D2887*	295	293		
85% Distillation Point	°C	ASTM D2887*		304		
90% Distill Point	°C	ASTM D2887*	310	314		
95% Distillation Point	°C	ASTM D2887*		331		
Final Boiling Point	°C	ASTM D2887*	341	343		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	36		
Cetane Index		ASTM D4737*	<40.0	46		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0		
Sodium	ppm	ASTM D5185(m)	< 0.1	<1		
Potassium	ppm	ASTM D5185(m)	<0.1	<1		
Water	%	ASTM D6304*	< 0.05	0.004		
ppm Water	ppm	ASTM D6304*	<500	48		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	2437		
Particles >6µm		ASTM D7647	>640	290		
Particles >14µm		ASTM D7647	>80	14		
Particles >21µm		ASTM D7647	>20	3		
Particles >38µm		ASTM D7647	>4	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>18/16/13	18/15/11		



FUEL REPORT





CALA ISO 17025:2017 Accredited

Laboratory

Laboratory Sample No. Lab Number **Unique Number**

: CU0021482

: 5694451

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CUMMINS CANADA ULC - GENERATOR DIVISION Received : 02601366 Diagnosed

: 06 Dec 2023 : 11 Dec 2023 Diagnostician : Kevin Marson

Test Package : FUEL (Additional Tests: CC Flash, GC-PercFuel, PrtCount)

7175 PACIFIC CIRCLE MISSISSAUGA, ON CA L5T 2A5

Contact: Elisia Johnson elisia.johnson@cummins.com

T: (905)795-0050 F: (905)795-9252

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.