


FUEL REPORT

Sample Rating Trend





LF2195
Component

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you filter this fluid before use. Resample in 30-45 days to monitor this situation.

Corrosion

Iron ppm levels are abnormal. The high metal levels indicate corrosion in the system.

Contaminants

There is a high amount of particulates (2 to 100 microns in size) present in the fuel. The water content is negligible.


Fuel Condition

The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

R) (GAL)				Nov2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0802522		
Sample Date		Client Info		21 Nov 2023		
Machine Age	hrs	Client Info		0		
Sample Status				SEVERE		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.846		
Fuel Color	text	Visual Screen*	Yllow	Red		
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.7		
Pensky-Martens Flash Point	°C	ASTM D7215*	52	57.8		
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	8		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	170		
5% Distillation Point	°C	ASTM D2887*		196		
10% Distill Point	°C	ASTM D2887*	201	206		
15% Distillation Point	°C	ASTM D2887*		213		
20% Distill Point	°C	ASTM D2887*	216	220		
30% Distill Point	°C	ASTM D2887*	230	234		
40% Distill Point	°C	ASTM D2887*	243	247		
50% Distill Point	°C	ASTM D2887*	255	260		
60% Distill Point	°C	ASTM D2887*	267	273		
70% Distill Point	°C	ASTM D2887*	280	287		
80% Distill Point	°C	ASTM D2887*	295	302		
85% Distillation Point	°C	ASTM D2887*		311		
90% Distill Point	°C	ASTM D2887*	310	320		
95% Distillation Point	°C	ASTM D2887*		333		
Final Boiling Point	°C	ASTM D2887*	341	344		
IGNITION QUALIT	ГΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	35		
Cetane Index		ASTM D4737*	<40.0	46		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0		
Sodium	ppm	ASTM D5185(m)	< 0.1	0		
Potassium	ppm	ASTM D5185(m)	<0.1	<1		
Water	%	ASTM D6304*	< 0.05	0.005		
ppm Water	ppm	ASTM D6304*	< 500	59		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	73337		
Particles >6µm		ASTM D7647	>640	53960		
Particles >14µm		ASTM D7647	>80	7420		
Particles >21µm		ASTM D7647	>20	767		
Particles >38µm		ASTM D7647	>4	4		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>18/16/13	23/23/20		



FUEL REPORT





CALA ISO 17025:2017 Accredited

Laboratory Sample No. Lab Number **Unique Number**

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : WC0802522

: 02601368

Received Diagnosed : 5694453

: 06 Dec 2023 : 11 Dec 2023

Diagnostician : Kevin Marson Test Package : FUEL (Additional Tests: CC Flash, GC-PercFuel, PQ, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

HVAC RENTALS 20 SIMPSON ROAD BOLTON, ON **CA L7E 1G9** Contact: Hongwu Zhang hzhang@hvacrentals.ca T: (647)637-1409