



# OIL ANALYSIS REPORT

Sample Rating Trend

FUEL



Machine Id  
**#1711 - CLAIRVIEW PUMP STATION**

Component  
**Diesel Engine**

Fluid  
**DIESEL ENGINE OIL SAE 15W40 (--- GAL)**



## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

Metal levels are typical for a new component breaking in.

### Contamination

Light fuel dilution occurring.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. Fuel is present in the oil and is lowering the viscosity. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0876633</b>	---	---
Sample Date	Client Info		<b>22 Nov 2023</b>	---	---
Machine Age	hrs	Client Info	<b>282</b>	---	---
Oil Age	hrs	Client Info	<b>0</b>	---	---
Oil Changed	Client Info		<b>Not Changed</b>	---	---
Sample Status			<b>ABNORMAL</b>	---	---

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.2	<b>NEG</b>	---	---
Glycol	WC Method		<b>NEG</b>	---	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >100	<b>32</b>	---	---
Chromium	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	---	---
Nickel	ppm	ASTM D5185(m) >4	<b>&lt;1</b>	---	---
Titanium	ppm	ASTM D5185(m)	<b>0</b>	---	---
Silver	ppm	ASTM D5185(m) >3	<b>&lt;1</b>	---	---
Aluminum	ppm	ASTM D5185(m) >20	<b>3</b>	---	---
Lead	ppm	ASTM D5185(m) >40	<b>7</b>	---	---
Copper	ppm	ASTM D5185(m) >330	<b>34</b>	---	---
Tin	ppm	ASTM D5185(m) >15	<b>2</b>	---	---
Antimony	ppm	ASTM D5185(m)	<b>0</b>	---	---
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	---	---
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	---	---
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	---	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 250	<b>2</b>	---	---
Barium	ppm	ASTM D5185(m) 10	<b>5</b>	---	---
Molybdenum	ppm	ASTM D5185(m) 100	<b>3</b>	---	---
Manganese	ppm	ASTM D5185(m)	<b>2</b>	---	---
Magnesium	ppm	ASTM D5185(m) 450	<b>21</b>	---	---
Calcium	ppm	ASTM D5185(m) 3000	<b>2737</b>	---	---
Phosphorus	ppm	ASTM D5185(m) 1150	<b>892</b>	---	---
Zinc	ppm	ASTM D5185(m) 1350	<b>1051</b>	---	---
Sulfur	ppm	ASTM D5185(m) 4250	<b>3338</b>	---	---
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---

## CONTAMINANTS




	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >25	<b>14</b>	---	---
Sodium	ppm	ASTM D5185(m) >158	<b>6</b>	---	---
Potassium	ppm	ASTM D5185(m) >20	<b>4</b>	---	---
Fuel	%	ASTM D7593* >5	<b>▲ 3.3</b>	---	---

## INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	ASTM D7844* >3	<b>0</b>	---	---
Nitration	Abs/cm	ASTM D7624* >20	<b>6.1</b>	---	---
Sulfation	Abs/.1mm	ASTM D7415* >30	<b>17.5</b>	---	---



# OIL ANALYSIS REPORT











FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs./1mm	ASTM D7414*	>25	<b>11.6</b>	---	---
Base Number (BN)	mg KOH/g	ASTM D2896*	8.5	<b>7.89</b>	---	---

VISUAL		method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.2	<b>NEG</b>	---	---
Free Water	scalar	Visual*		<b>NEG</b>	---	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	14.4	<b>▲ 11.5</b>	---	---

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0876633 **Received** : 07 Dec 2023  
**Lab Number** : **02601455** **Diagnosed** : 08 Dec 2023  
**Unique Number** : 5694540 **Diagnostician** : Wes Davis  
**Test Package** : MOB 2 ( Additional Tests: FuelDilution, PercentFuel )

**Lighthouse Electric**  
 6714 6th Conc South  
 Amherstburg, ON  
 CA N9V 0C8  
 Contact: Brad Purdie  
 brad\_lighthouse@hotmail.com  
 T: (519)730-1310  
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.