


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



V411201C FWP C GEN LUBE OIL

Component

Tank Lube System

MOBIL DTE OIL MEDIUM (--- GAL)

•••	•	_	_	•	_	•	-

DIAGNOSIS Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PP13932690	PP13796084	PP13819708
Sample Date		Client Info		25 Nov 2023	06 Nov 2022	05 Nov 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATION	1	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	<1	<1	<1
Chromium	ppm	ASTM D5185(m)	>10	0	0	0
Nickel	ppm	ASTM D5185(m)	>10	0	<1	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		<1	0	0
Aluminum	ppm	ASTM D5185(m)	>10	0	0	0
Lead	ppm	ASTM D5185(m)	>20	<1	<1	<1
Copper	ppm	ASTM D5185(m)	>20	33	33	32
Tin	ppm	ASTM D5185(m)	>10	<1	<1	<1
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		<1	<1	0
Barium	ppm	ASTM D5185(m)		<1	0	0
Molybdenum	ppm	ASTM D5185(m)		0	0	0
Manganese	ppm	ASTM D5185(m)		0	0	0
Magnesium	ppm	ASTM D5185(m)		0	0	0
Calcium	ppm	ASTM D5185(m)		<1	0	0
Phosphorus	ppm	ASTM D5185(m)		91	97	100
Zinc	ppm	ASTM D5185(m)		97	97	97
Sulfur	ppm	ASTM D5185(m)		1168	1223	1232
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	6	6	7
Sodium	ppm	ASTM D5185(m)		<1	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	0	<1	<1
FLUID CLEANLIN	FCC.	method	limit/base	current	history1	history2

ASTM D7647 >5000

ASTM D7647 >1300

ASTM D7647 >160

ASTM D7647 >40

ASTM D7647 >10

ASTM D7647 >3

ISO 4406 (c) >19/17/14

1195

292

21

5

1

0

17/15/12

Particles >4µm

Particles >6µm

Particles >14µm

Particles >21µm

Particles >38µm

Particles >71μm

Oil Cleanliness

18/16/13

1348

436

42

11

0

16/14/11

435

114

13

5

1

0



OIL ANALYSIS REPORT

