

PROBLEM SUMMARY

Sample Rating Trend




LBK G3 GEBR

Component **Bearing** Fluid

ESSO TERESSO ISO 68 (30 LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS											
Sample Status				ATTENTION	ATTENTION	NORMAL					
Copper	ppm	ASTM D5185(m)	>13	<u>^</u> 23	△ 19	10					

Customer Id: NEWSTJ Sample No.: WC0706106 Lab Number: 02601567 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

26 Oct 2023 Diag: Bill Quesnel

WEAR



Resample at the next service interval to monitor. Copper ppm levels are noted. All other component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



26 Apr 2023 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



07 Oct 2022 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service. NOTE: The color of the oil is darker then previous samples.





OIL ANALYSIS REPORT

Sample Rating Trend



LBK G3 GEBR

Component

Bearing

ESSO TERESSO ISO 68 (30 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

Copper ppm levels are noted. All other component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		czuu4 Junzu	07 Feb2009 Dec2010	Jun2013 Jun2015 May2017	Dec2021	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0706106	WC0706102	WC0455703
Sample Date		Client Info		22 Nov 2023	26 Oct 2023	26 Apr 2023
Machine Age	wks	Client Info		0	0	18
Oil Age	wks	Client Info		0	0	18
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION	ATTENTION	NORMAL
CONTAMINATIO	V	method	limit/base	current	history1	history2
Water		WC Method	>2	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m)	>63	2	2	1
Chromium	ppm	ASTM D5185(m)	>20	0	0	0
Nickel	ppm	ASTM D5185(m)	>20	<1	0	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		<1	<1	0
Aluminum	ppm	ASTM D5185(m)	>2	<1	<1	<1
Lead	ppm	ASTM D5185(m)	>161	5	4	4
Copper	ppm	ASTM D5185(m)	>13	<u>^</u> 23	<u> </u>	10
Tin	ppm	ASTM D5185(m)	>27	3	3	2
Antimony	ppm	ASTM D5185(m)		0	0	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	4.5	<1	<1	<1
Barium	ppm	ASTM D5185(m)	0.4	<1	<1	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)		0	0	0
Magnesium	ppm	ASTM D5185(m)	0	0	0	<1
Calcium	ppm	ASTM D5185(m)	0	<1	<1	0
Phosphorus	ppm	ASTM D5185(m)	0.7	23	20	12
Zinc	ppm	ASTM D5185(m)	0	40	37	19
Sulfur	ppm	ASTM D5185(m)	1315	2370	2347	2506
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINANTS	}	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>12	<1	<1	<1
Sodium	ppm	ASTM D5185(m)		1	2	<1
Potassium	ppm	ASTM D5185(m)	>20	<1	0	0
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.02	0.13	0.09	0.13



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number **Unique Number**

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : WC0706106 : 02601567

: 5694652

Received Diagnosed Diagnostician

: 07 Dec 2023 : 08 Dec 2023 : Kevin Marson

Test Package : IND 2 (Additional Tests: TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

NEWFOUNDLAND POWER INC.

50 DUFFY PLACE, PO BOX 8910 ST. JOHNS, NL CA A1B 3P6

Contact: Paul Martin pmartin@newfoundlandpower.com

F: (709)737-2926

T: