




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
[1494767]
 Machine Id
NOVA BUS 1519
 Component
Natural Gas Engine
 Fluid
VALVOLINE PREMIUM BLUE 9200 15W40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0878130	WC0849948	WC0811574
Sample Date	Client Info		06 Dec 2023	30 Aug 2023	31 May 2023
Machine Age	kms	Client Info	455534	436037	418152
Oil Age	kms	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>50	14	17	22
Chromium	ppm	ASTM D5185(m)	>4	2	1	<1
Nickel	ppm	ASTM D5185(m)	>2	<1	<1	<1
Titanium	ppm	ASTM D5185(m)		0	<1	<1
Silver	ppm	ASTM D5185(m)	>3	<1	0	0
Aluminum	ppm	ASTM D5185(m)	>9	1	2	2
Lead	ppm	ASTM D5185(m)	>30	1	2	1
Copper	ppm	ASTM D5185(m)	>35	<1	2	5
Tin	ppm	ASTM D5185(m)	>4	<1	1	1
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		20	8	21
Barium	ppm	ASTM D5185(m)		<1	<1	4
Molybdenum	ppm	ASTM D5185(m)		59	55	48
Manganese	ppm	ASTM D5185(m)		<1	2	8
Magnesium	ppm	ASTM D5185(m)		913	862	784
Calcium	ppm	ASTM D5185(m)		1373	1282	1215
Phosphorus	ppm	ASTM D5185(m)		770	717	741
Zinc	ppm	ASTM D5185(m)		976	894	794
Sulfur	ppm	ASTM D5185(m)		2056	1934	1908
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>+100	11	14	48
Sodium	ppm	ASTM D5185(m)		4	6	22
Potassium	ppm	ASTM D5185(m)	>20	0	<1	2

INFRA-RED


	method	limit/base	current	history1	history2	
Soot %	%	ASTM D7844*		0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	11.3	11.7	9.8
Sulfation	Abs/.1mm	ASTM D7415*	>30	23.7	24.4	20.2

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	ASTM D7414*	>25	20.3	20.4	18.6











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	14.8	14.9	14.6

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0878130
Lab Number : 02601755
Unique Number : 5694840
Test Package : MOB 1

Received : 08 Dec 2023
Diagnosed : 08 Dec 2023
Diagnostician : Wes Davis

CITY OF HAMILTON
 2200 UPPER JAMES., MOUNTAIN TRANSIT STOREROOM
 MOUNT HOPE, ON
 CA L0R 1W0
 Contact: Jeff Parr
 jeff.parr@hamilton.ca
 T: (905)546-2424
 F: (905)679-4502

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.