




# PROBLEM SUMMARY

Sample Rating Trend




## Machine Id MAIN UPPER BEARING

Component  
Upper Bearing

Fluid  
CHEVRON REGAL OIL R&O 46 (--- LTR)

### COMPONENT CONDITION SUMMARY

▲ Silicon (ppm)



### RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	NORMAL
Silicon	ppm	ASTM D5185(m)	>15	▲ 18	▲ 24	<1

Customer Id: BREABB  
 Sample No.: WC0732068  
 Lab Number: 02601874  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We recommend an early resample to monitor this condition.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

## HISTORICAL DIAGNOSIS

### WATER



#### 10 Aug 2023 Diag: Kevin Marson

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. Free water present. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### NORMAL



#### 11 Apr 2023 Diag: Kevin Marson

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id  
**MAIN UPPER BEARING**  
 Component  
**Upper Bearing**  
 Fluid  
**CHEVRON REGAL OIL R&O 46 (--- LTR)**

## DIAGNOSIS

### Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

All component wear rates are normal.

### Contamination

Elemental level of silicon (Si) above normal indicating ingress of seal material.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2	
Sample Number	Client Info	<b>WC0732068</b>	WC0732065	WC0732079	
Sample Date	Client Info	<b>06 Dec 2023</b>	10 Aug 2023	11 Apr 2023	
Machine Age	hrs	Client Info	<b>9088</b>	7995	5434
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info	<b>Not Changed</b>	Not Changd	Not Changed	
Sample Status		<b>ABNORMAL</b>	ABNORMAL	NORMAL	

## CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >2	<b>NEG</b>	NEG	NEG

## WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184*	<b>0</b>	0	0
Iron	ppm ASTM D5185(m) >20	<b>0</b>	<1	<1
Chromium	ppm ASTM D5185(m) >20	<b>0</b>	0	0
Nickel	ppm ASTM D5185(m) >20	<b>&lt;1</b>	<1	<1
Titanium	ppm ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm ASTM D5185(m)	<b>&lt;1</b>	<1	0
Aluminum	ppm ASTM D5185(m) >20	<b>0</b>	<1	0
Lead	ppm ASTM D5185(m) >20	<b>&lt;1</b>	0	<1
Copper	ppm ASTM D5185(m) >20	<b>5</b>	5	5
Tin	ppm ASTM D5185(m) >20	<b>0</b>	0	0
Antimony	ppm ASTM D5185(m)	<b>0</b>	0	0
Vanadium	ppm ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m)	<b>&lt;1</b>	0	0
Barium	ppm ASTM D5185(m)	<b>0</b>	0	0
Molybdenum	ppm ASTM D5185(m)	<b>0</b>	0	0
Manganese	ppm ASTM D5185(m)	<b>0</b>	<1	<1
Magnesium	ppm ASTM D5185(m)	<b>0</b>	0	0
Calcium	ppm ASTM D5185(m)	<b>2</b>	3	<1
Phosphorus	ppm ASTM D5185(m)	<b>29</b>	32	34
Zinc	ppm ASTM D5185(m)	<b>9</b>	10	9
Sulfur	ppm ASTM D5185(m)	<b>71</b>	73	81
Lithium	ppm ASTM D5185(m)	<b>&lt;1</b>	<1	<1


## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m) >15	<b>▲ 18</b>	▲ 24	<1
Sodium	ppm ASTM D5185(m)	<b>&lt;1</b>	<1	0
Potassium	ppm ASTM D5185(m) >20	<b>0</b>	<1	0




# OIL ANALYSIS REPORT


▲ Silicon (ppm)




Particle Count




Acid Number



Viscosity @ 40°C



PQ



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory**

**Sample No.**

**Lab Number**

**Unique Number**

**Test Package**

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9

: WC0732068

: 02601874

: 5694959

: IND 2 ( Additional Tests: PQ, PrtCount )

**Received** : 08 Dec 2023

**Diagnosed** : 12 Dec 2023

**Diagnostician** : Kevin Marson

**Bremner Trio Hydro Corp. (BTHC)**

32125 Sorrento Avenue

Abbotsford, BC

CA V2T 5B7

Contact: Ryan Jones

rjones@cclinfrastucture.com

T:

F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.

**FLUID CLEANLINESS** method limit/base current history1 history2

Particles >4µm	ASTM D7647	>10000	<b>1236</b>	1742	5707
Particles >6µm	ASTM D7647	>2500	<b>324</b>	536	1977
Particles >14µm	ASTM D7647	>160	<b>22</b>	51	157
Particles >21µm	ASTM D7647	>40	<b>9</b>	15	24
Particles >38µm	ASTM D7647	>10	<b>2</b>	1	1
Particles >71µm	ASTM D7647	>3	<b>1</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/14	<b>17/16/12</b>	18/16/13	20/18/14

**FLUID DEGRADATION** method limit/base current history1 history2

Acid Number (AN)	mg KOH/g	ASTM D974*	<b>0.07</b>	0.07	0.11
------------------	----------	------------	-------------	------	------

**VISUAL** method limit/base current history1 history2


White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	VLITE	VLITE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	▲ WGOIL	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>2	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	▲ 1%	NEG

**FLUID PROPERTIES** method limit/base current history1 history2

Visc @ 40°C	cSt	ASTM D7279(m)	43.7	<b>44.5</b>	43.2	43.4
-------------	-----	---------------	------	-------------	------	------

**SAMPLE IMAGES** method limit/base current history1 history2

Color



Bottom

