




PROBLEM SUMMARY



Sample Rating Trend

WATER



Area
Thrusters
 Machine Id
Bow Thruster
 Component
Center Bow Thruster
 Fluid
PETRO CANADA ENDURATEX EP 68 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We advise that you follow the water drain-off procedure for this component. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. (Customer Sample Comment:
 Top Up Amount: ~50-100L)

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	SEVERE
Water	%	ASTM D6304*	>0.2	1.058	1.302
ppm Water	ppm	ASTM D6304*		10586	13023
Particles >4µm		ASTM D7647	>5000	79781	92585
Particles >6µm		ASTM D7647	>1300	9243	8031
Oil Cleanliness		ISO 4406 (c)	>19/17/14	23/20/13	23/20/14
Appearance	scalar	Visual*	NORML	MILKY	MILKY
Emulsified Water	scalar	Visual*	>0.2	.2%	.2%

Customer Id: VMASSEY
 Sample No.: WC0877831
 Lab Number: 02602011
 Test Package: MAR 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Water Access	---	---	?	We advise that you check for the source of water entry.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

HISTORICAL DIAGNOSIS

WATER



14 Nov 2023 Diag: Kevin Marson

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We advise that you follow the water drain-off procedure for this component. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a high concentration of water present in the oil. Free water present. Abnormal water content and sodium (Na) level indicate possible sea water contamination. The AN level is acceptable for this fluid.

[view report](#)



ISO



14 Nov 2023 Diag: Wes Davis

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)



ISO



08 Oct 2023 Diag: Wes Davis

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. The filter change at the time of sampling has been noted. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
Thrusters
 Machine Id
Bow Thruster

Component
Center Bow Thruster
 Fluid

PETRO CANADA ENDURATEX EP 68 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We advise that you follow the water drain-off procedure for this component. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. (Customer Sample Comment:
 Top Up Amount: ~50-100L)

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a high concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0877831	WC0848595	WC0848594
Sample Date	Client Info		06 Dec 2023	14 Nov 2023	14 Nov 2023
Machine Age	hrs	Client Info	22720	22659	22659
Oil Age	hrs	Client Info	1000	0	0
Oil Changed	Client Info		Oil Added	N/A	N/A
Sample Status			SEVERE	SEVERE	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >90	27	23	4
Chromium	ppm	ASTM D5185(m) >10	0	0	0
Nickel	ppm	ASTM D5185(m) >10	<1	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	<1	<1	<1
Aluminum	ppm	ASTM D5185(m) >10	<1	<1	<1
Lead	ppm	ASTM D5185(m) >20	<1	<1	<1
Copper	ppm	ASTM D5185(m) >20	4	3	4
Tin	ppm	ASTM D5185(m) >15	0	0	0
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 69	53	46	63
Barium	ppm	ASTM D5185(m) 1	<1	<1	<1
Molybdenum	ppm	ASTM D5185(m) 1	0	0	0
Manganese	ppm	ASTM D5185(m) 1	0	0	0
Magnesium	ppm	ASTM D5185(m) 1	9	12	<1
Calcium	ppm	ASTM D5185(m) 1	8	7	3
Phosphorus	ppm	ASTM D5185(m) 246	246	246	254
Zinc	ppm	ASTM D5185(m) 1	13	11	4
Sulfur	ppm	ASTM D5185(m) 3670	4335	4299	4195
Lithium	ppm	ASTM D5185(m)	2	2	<1

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >7	3	3	2
Sodium	ppm	ASTM D5185(m)	60	▲ 81	1
Potassium	ppm	ASTM D5185(m) >20	2	3	<1
Water	%	ASTM D6304* >0.2	● 1.058	● 1.302	---
ppm Water	ppm	ASTM D6304*	● 10586	● 13023	---

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	● 79781	● 74521	● 92585
Particles >6µm	ASTM D7647	>1300	▲ 9243	▲ 8031	● 16757
Particles >14µm	ASTM D7647	>160	65	113	36
Particles >21µm	ASTM D7647	>40	9	19	9
Particles >38µm	ASTM D7647	>10	1	4	6
Particles >71µm	ASTM D7647	>3	1	0	5
Oil Cleanliness	ISO 4406 (c)	>19/17/14	● 23/20/13	● 23/20/14	● 24/21/12



OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.4	0.41	0.37	0.35





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	VLITE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	▲ MILKY	▲ MILKY	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	▲ .2%	▲ .2%	NEG
Free Water	scalar	Visual*		NEG	▲ 1%	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	68.0	67.2	67.5	65.6

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0877831
Lab Number : **02602011**
Unique Number : 5695096
Test Package : MAR 2 (Additional Tests: KF, TAN Man)

Canadian Coast Guard
 CCGS Vincent Massey, 101 Boul. Champlain
 Quebec, QC
 CA G1K 7Y7
 Contact: Vincent Massey
 vincentmasseyse@ccgs-ngcc.gc.ca
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.