




# PROBLEM SUMMARY

## Sample Rating Trend




ISO




Area  
**Banbury 2**  
Machine Id  
**BB02 Racine**  
Component  
**Hydraulic System**  
Fluid  
**SHELL TELLUS S 68 (80 GAL)**

## COMPONENT CONDITION SUMMARY


### Particle Trend



### Silicon (ppm)



### Additives



## RECOMMENDATION

Check seals and/or filters for points of contaminant entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	SEVERE	
Silicon	ppm	ASTM D5185(m)	>15	▲ 67	● 183	▲ 111
Particles >4µm		ASTM D7647	>5000	● 305033	● 739166	● 1920991
Particles >6µm		ASTM D7647	>1300	● 190445	● 638522	● 972432
Particles >14µm		ASTM D7647	>160	▲ 654	● 178350	● 2211
Oil Cleanliness		ISO 4406 (c)	>19/17/14	● 25/25/17	● 27/26/25	● 28/27/18

Customer Id: GOONAP  
Sample No.: WC0873593  
Lab Number: 02602400  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

## HISTORICAL DIAGNOSIS

### 25 Aug 2023 Diag: Kevin Marson

DIRT



We advise that you check all areas where contaminants can enter the system. We advise that you check for visible metal particles in the oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. Light concentration of visible metal present. There is a high amount of particulates (2 to 100 microns in size) present in the oil. High concentration of dirt present in the oil. High amount of ingressed dirt has caused abrasive wear to the component. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid.

view report



### 05 Feb 2023 Diag: Kevin Marson

ISO



Check seals and/or filters for points of contaminant entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. Particles >14µm are severely high. Particles >6µm are severely high. Oil Cleanliness are severely high. Particles >4µm are severely high. Silicon ppm levels are abnormally high. Particles >21µm are abnormally high. Elemental level of silicon (Si) above normal indicating ingress of seal material. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 27 Oct 2022 Diag: Kevin Marson

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Lead ppm levels are marginal. All other component wear rates are normal. Particles >14µm are severely high. Particles >21µm are severely high. Particles >38µm are severely high. Particles >6µm are severely high. Particles >4µm are severely high. Oil Cleanliness are severely high. Silicon ppm levels are abnormally high. There is a moderate concentration of dirt present in the oil. Additive levels indicate the addition of a different brand, or type of oil. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**Banbury 2**  
 Machine Id  
**BB02 Racine**

Component  
**Hydraulic System**  
 Fluid  
**SHELL TELLUS S 68 (80 GAL)**

## DIAGNOSIS

### Recommendation

Check seals and/or filters for points of contaminant entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Confirm the source of the lubricant being utilized for top-up/fill. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

All component wear rates are normal.

### Contamination

Particles >6µm are severely high. Oil Cleanliness are severely high. Particles >4µm are severely high. Silicon ppm levels are abnormally high. Particles >14µm are abnormally high. Elemental level of silicon (Si) above normal indicating ingress of seal material.

### Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0873593</b>	WC0841271	WC0754396
Sample Date	Client Info	<b>03 Nov 2023</b>	25 Aug 2023	05 Feb 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>SEVERE</b>	SEVERE	SEVERE

## CONTAMINATION

method	limit/base	current	history1	history2	
Water	WC Method	>0.05	<b>NEG</b>	NEG	NEG

## WEAR METALS

method	limit/base	current	history1	history2		
Iron	ppm	ASTM D5185(m)	>20	<b>10</b>	6	7
Chromium	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	0	0
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	1	<1
Lead	ppm	ASTM D5185(m)	>20	<b>4</b>	3	17
Copper	ppm	ASTM D5185(m)	>20	<b>2</b>	3	9
Tin	ppm	ASTM D5185(m)	>20	<b>0</b>	0	<1
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185(m)		<b>2</b>	3	3
Barium	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185(m)		<b>5</b>	2	5
Manganese	ppm	ASTM D5185(m)		<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1
Calcium	ppm	ASTM D5185(m)		<b>41</b>	49	40
Phosphorus	ppm	ASTM D5185(m)		<b>61</b>	65	69
Zinc	ppm	ASTM D5185(m)	0	<b>50</b>	58	58
Sulfur	ppm	ASTM D5185(m)		<b>375</b>	261	304
Lithium	ppm	ASTM D5185(m)		<b>5</b>	5	7

## CONTAMINANTS






method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185(m)	>15	<b>67</b>	183	111
Sodium	ppm	ASTM D5185(m)		<b>3</b>	4	3
Potassium	ppm	ASTM D5185(m)	>20	<b>0</b>	<1	0

## FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>5000	<b>305033</b>	739166	1920991
Particles >6µm	ASTM D7647	>1300	<b>190445</b>	638522	972432
Particles >14µm	ASTM D7647	>160	<b>654</b>	178350	2211
Particles >21µm	ASTM D7647	>40	<b>38</b>	16935	257
Particles >38µm	ASTM D7647	>10	<b>2</b>	9	10
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	4
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>25/25/17</b>	27/26/25	28/27/18



# OIL ANALYSIS REPORT



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0873593 **Received** : 11 Dec 2023  
**Lab Number** : 02602400 **Diagnosed** : 12 Dec 2023  
**Unique Number** : 5695485 **Diagnostician** : Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: TAN Man )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		<b>0.17</b>	0.12	0.16

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	▲ VLITE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	68.0	<b>68.2</b>	68.3	66.8

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------

Color			
Bottom			
PrtFilter	no image		no image