



FUEL REPORT

Sample Rating Trend


NORMAL



Machine Id
TDT411202A DIESEL DAY TANK FIRE WATER PUMP A

Component
Diesel Fuel
Fluid

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)



DIAGNOSIS

Recommendation

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. Resample at the next service interval to monitor.

Corrosion

{not applicable}

Contaminants

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. There is no indication of any contamination in the diesel fuel.

Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			PP13920747	PP13899605	PP13878485
Sample Date	Client Info			07 Nov 2023	06 Aug 2023	10 Jul 2023
Machine Age	hrs	Client Info		0	0	0
Sample Status				NORMAL	NORMAL	ABNORMAL

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.842	0.841	0.842
Fuel Color	text	Visual Screen*	Yllow	Yllow	Yllow	Yllow
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.8	2.7	2.8
Pensky-Martens Flash Point	°C	ASTM D7215*	52	70.6	71.6	72.8

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	8	7	8

DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	182	183	185
5% Distillation Point	°C	ASTM D2887*		202	203	204
10% Distill Point	°C	ASTM D2887*	201	212	213	213
15% Distillation Point	°C	ASTM D2887*		220	221	221
20% Distill Point	°C	ASTM D2887*	216	228	228	228
30% Distill Point	°C	ASTM D2887*	230	242	242	242
40% Distill Point	°C	ASTM D2887*	243	255	255	254
50% Distill Point	°C	ASTM D2887*	255	267	267	267
60% Distill Point	°C	ASTM D2887*	267	281	280	280
70% Distill Point	°C	ASTM D2887*	280	294	293	293
80% Distill Point	°C	ASTM D2887*	295	310	308	307
85% Distillation Point	°C	ASTM D2887*		321	318	318
90% Distill Point	°C	ASTM D2887*	310	332	329	328
95% Distillation Point	°C	ASTM D2887*		351	346	346
Final Boiling Point	°C	ASTM D2887*	341	379	364	370






IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	36	36	36
Cetane Index		ASTM D4737*	<40.0	49	50	49

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0	0	0
Sodium	ppm	ASTM D5185(m)	<0.1	0	0	0
Potassium	ppm	ASTM D5185(m)	<0.1	<1	<1	<1
Water	%	ASTM D6304*	<0.05	0.003	0.002	0.003
ppm Water	ppm	ASTM D6304*	<500	29	20.8	27.6

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	303	889	224
Particles >6µm		ASTM D7647	>640	71	233	47
Particles >14µm		ASTM D7647	>80	4	18	7
Particles >21µm		ASTM D7647	>20	0	5	2
Particles >38µm		ASTM D7647	>4	0	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>18/16/13	15/13/9	17/15/11	15/13/10




FUEL REPORT






HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185(m)	<0.1	0	0
Nickel	ppm	ASTM D5185(m)	<0.1	0	0
Lead	ppm	ASTM D5185(m)	<0.1	0	0
Vanadium	ppm	ASTM D5185(m)	<0.1	0	0
Iron	ppm	ASTM D5185(m)	<1	<1	<1
Calcium	ppm	ASTM D5185(m)	<0.1	0	0
Magnesium	ppm	ASTM D5185(m)	<0.1	0	0
Phosphorus	ppm	ASTM D5185(m)	<0.1	0	0
Zinc	ppm	ASTM D5185(m)	<0.1	0	0

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PP13920747
Lab Number : 02602448
Unique Number : 5695533
Test Package : FUEL (Additional Tests: CC Flash, GC-PercFuel, PrtCount)

ExxonMobil Canada East Ltd.
 Hebron-Materials and Repair Coordin, Suite 1000, 100 New Gow
 St. John's, NL
 CA A1C 6K3
 Contact: Liam Maher
 liam.m.maher@exxonmobil.com
 T: (709)273-3729
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.