




PROBLEM SUMMARY




Sample Rating Trend

DEGRADATION

Area
[7892398]
 Machine Id
K-MATIC LIFT TABLE (S/N PH83115)
 Component
Hydraulic System
 Fluid
CITGO CITGO GLYCOL FR-40 XD (100 GAL)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Due to the low reserve alkalinity it is advised that you contact CITGO to assist in restoring the proper amine concentration. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	SEVERE	ABNORMAL
Particles >4µm	ASTM D7647	>5000	▲ 14265	● 233391	3750
Particles >6µm	ASTM D7647	>1300	▲ 3992	● 93260	▲ 1900
Particles >14µm	ASTM D7647	>160	▲ 427	● 9710	▲ 480
Particles >21µm	ASTM D7647	>40	▲ 169	● 2638	▲ 60
Particles >38µm	ASTM D7647	>10	▲ 34	● 122	7
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 21/19/16	● 25/24/20	▲ 19/18/16

Customer Id: ESCPOR
 Sample No.: WC0741311
 Lab Number: 02602942
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Contact Required	---	---	?	Due to the low reserve alkalinity it is advised that you contact CITGO to assist in restoring the proper amine concentration.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

02 Mar 2023 Diag: Kevin Marson

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. Viscosity of sample indicates oil is within ISO 68 range, advise investigate. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The water concentration level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



06 Jul 2022 Diag: Kevin Marson

VISCOSITY



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >14µm and oil cleanliness are abnormally high. Particles >21µm are notably high. Particles >6µm are notably high. Viscosity of sample indicates oil is within ISO 68 range, advise investigate. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The water concentration level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



06 Apr 2022 Diag: Kevin Marson

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >14µm are severely high. Particles >6µm are severely high. Particles >21µm are abnormally high. Particles >4µm are abnormally high. Particles >38µm are abnormally high. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The water concentration level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





COOLANT REPORT

Sample Rating Trend



DEGRADATION



Area
[7892398]
 Machine Id
K-MATIC LIFT TABLE (S/N PH83115)
 Component
Hydraulic System
 Fluid
CITGO CITGO GLYCOL FR-40 XD (100 GAL)

DIAGNOSIS

Recommendation

Due to the low reserve alkalinity it is advised that you contact CITGO to assist in restoring the proper amine concentration. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates (2 to 100 microns in size) present in the oil.

Fluid Condition

The reserve alkalinity of this fluid is lower than acceptable. The pH is low indicating a high acidity of the fluid. Viscosity of sample indicates oil is within ISO 100 range, advise investigate. The AN level is acceptable for this fluid. The water concentration level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0741311	WC0741332	WC0566153
Sample Date	Client Info		03 Nov 2023	02 Mar 2023	06 Jul 2022
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	SEVERE	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>50	NEG	NEG	NEG

CORROSION INHIBITORS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1	2	<1
Phosphorus	ppm	ASTM D5185(m)	2	2	<1
Boron	ppm	ASTM D5185(m)	0	2	2
Molybdenum	ppm	ASTM D5185(m)	0	<1	<1

CORROSION

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>20	0	3	<1
Aluminum	ppm	ASTM D5185(m)	>20	0	<1	2
Copper	ppm	ASTM D5185(m)	>20	0	3	<1
Lead	ppm	ASTM D5185(m)	>20	0	4	<1
Tin	ppm	ASTM D5185(m)	>20	0	<1	0
Silver	ppm	ASTM D5185(m)		<1	<1	<1
Zinc	ppm	ASTM D5185(m)		0	3	1

CONTAMINANTS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ 14265	233391	3750
Particles >6µm	ASTM D7647	>1300	▲ 3992	93260	▲ 1900
Particles >14µm	ASTM D7647	>160	▲ 427	9710	▲ 480
Particles >21µm	ASTM D7647	>40	▲ 169	2638	▲ 60
Particles >38µm	ASTM D7647	>10	▲ 34	122	7
Particles >71µm	ASTM D7647	>3	0	▲ 11	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 21/19/16	25/24/20	▲ 19/18/16

CARRIER SALTS

	method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)	10	14	14
Potassium	ppm	ASTM D5185(m)	27	62	45


SCALE POTENTIAL

	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	<1	5	<1
Magnesium	ppm	ASTM D5185(m)	<1	1	1




COOLANT REPORT


Reserve Alkalinity




Particle Trend




Water (KF)



Particle Trend



Acid Number



VISUAL

Color



Bottom




PrtFilter




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Particle Count



Viscosity @ 40°C



Acid Number



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0741311 **Received** : 13 Dec 2023
Lab Number : 02602942 **Diagnosed** : 18 Dec 2023
Unique Number : 5696027 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: KF, pH, ReserveAlk, TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

ESCO LTD.
 P.O. BOX 270, 185 HOPE STREET SOUTH
 PORT HOPE, ON
 CA L1A 3W4
 Contact: Paul Dundas
 paul.dundas@mail.weir
 T: (647)725-8153
 F: (905)885-7600