

COMPONENT CONDITION SUMMARY

No relevant graphs to display

condition.

RECOMMENDATION	PROBLEMATIC TEST RESULTS						
Recommend replacement of any filter driers	Sample Status			ABNORMAL	NORMAL	NORMAL	
because of the increased moisture level. We	Tin	ppm	ASTM D5185(m)	>4	<u> </u>	<1	<1
recommend an early resample to monitor this	ppm Water	ppm	ASTM D6304*	>100	<u> </u>	62	52

Customer Id: GTT0000224 Sample No.: GTT0001179 Lab Number: 02602975 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Bill Quesnel CLS,OMA II,MLA-III,LLA-I +1 (289)291-4641 x4641 Bill.Quesnel@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com WATER

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Resample			?	We recommend an early resample to monitor this condition.			

HISTORICAL DIAGNOSIS





The acid number is slightly high. All wear metals and moisture are in satisfactory ranges for this model unit and the running time reported. DO NOT change the oil. Resample in 3-4 months or 2500 hours.



view report

25 Jan 2022 Diag: Wes Davis

21 Mar 2023 Diag: Wes Davis



The acid number is slightly high. All wear metals and moisture are in satisfactory ranges for this model unit and the running time reported. DO NOT change the oil. Resample in 3-4 months or 2500 hours.

18 Nov 2020 Diag: Wes Davis

NORMAL



The test results indicate normal wear patterns for this type of unit with the moisture and acidity also in the acceptable range.








DIAGNOSIS

OIL ANALYSIS REPORT

MGM 825 Coxwell #2 [4500057327] **CARRIER 0607Q73674** Component Chiller



Fluid ICI EMKARATE RL 68H (--- GAL)

DIAGNOSIS	SAMPLE INFOR	MATION	method	limit/base	current	history i	history2
A Recommendation	Sample Number		Client Info		GTT0001179	GTT1527	GTT1528
Recommend replacement of any filter driers	Sample Date		Client Info		23 Jun 2023	21 Mar 2023	25 Jan 2022
because of the increased moisture level. We	Machine Age	hrs	Client Info		0		
recommend an early resample to monitor this	Oil Age	hrs	Client Info		0		
condition.	Oil Changed		Client Info		N/A	N/A	N/A
A Wear	Sample Status				ABNORMAL	NORMAL	NORMAL
Tin ppm levels are marginal. The tin reading shows moderate wear occurring on the compressor	WEAR METALS		method	limit/base	current	history1	history2
bearings or motor bearings.	Iron	ppm	ASTM D5185(m)	>8	0	<1	<1
Contamination	Chromium	ppm	ASTM D5185(m)	>2	0	<1	<1
There is a moderate concentration of water present	Nickel	ppm	ASTM D5185(m)		<1		
in the oil.	Titanium	ppm	ASTM D5185(m)		0		
Fluid Condition	Silver	ppm	ASTM D5185(m)	>2	<1		
The AN level is acceptable for this fluid.	Aluminum	ppm	ASTM D5185(m)	>3	0	<1	<1
	Lead	ppm	ASTM D5185(m)	>2	<1	<1	<1
	Copper	ppm	ASTM D5185(m)	>8	1	2	2
	Tin	ppm	ASTM D5185(m)	>4	<u> </u>	<1	<1
	Antimony	ppm	ASTM D5185(m)		0		
	Vanadium	ppm	ASTM D5185(m)		0		
	Beryllium	ppm	ASTM D5185(m)		0		
	Cadmium	ppm	ASTM D5185(m)		0		
	ADDITIVES		method	limit/base	current	history1	history2
	Boron	ppm	ASTM D5185(m)	0	<1		
	Barium	ppm	ASTM D5185(m)	0	0		
	Molybdenum	ppm	ASTM D5185(m)	0	0		
	Manganese	ppm	ASTM D5185(m)		0		
	Magnesium	ppm	ASTM D5185(m)	0	0		
	Calcium	ppm	ASTM D5185(m)	0	0		
	Phosphorus	ppm	ASTM D5185(m)	1900	1979		
	Zinc	ppm	ASTM D5185(m)	0	2	1	2
	Sulfur	ppm	ASTM D5185(m)	25	31		
	Lithium	ppm	ASTM D5185(m)		<1		
	CONTAMINANT	S	method	limit/base	current	history1	history2
	Silicon	ppm	ASTM D5185(m)	>15	29		
	Sodium	ppm	ASTM D5185(m)		2		
	Potassium	ppm	ASTM D5185(m)	>20	6		
	ppm Water	ppm	ASTM D6304*	>100	<u> </u>	62	52
	FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
	Acid Number (AN)	mg KOH/g	ASTM D974*	0.02	0.02	0.115	0.115



OIL ANALYSIS REPORT

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML		
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	72.3	42.3		
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image
GRAPHS						



Sample No. : GTT0001179 Recieved : 13 Dec 2023 C/O Conduent Div of Carrier Canada, 1-2740 Matheson Blvd : 02602975 Lab Number Diagnosed : 15 Dec 2023 Unique Number : 5696060 Diagnostician : Bill Quesnel Test Package : IND 2 (Additional Tests: KV40) Contact: Brian Raymundo To discuss this sample report, contact Customer Service at 1-905-847-9300 Ext 26. Brian.Raymundo@carrier.com Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Damages: Seller shall in no event be liable for special, incidental, or consequential damages, of a commercial nature, resulting from any cause.

Contact/Location: Brian Raymundo - GTT0000224

Carrier Commerical Service

Mississauga, ON

CA L4W 4X3

T:

F: