




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Area  
**2 Phoenix/020 ISO Dewax/C Compressor/101 H2 Makeup Comp**  
 Machine Id  
**N/A 20C101 (South)**  
 Component  
**Reciprocating Compressor**  
 Fluid  
**PETRO CANADA COMPRO COMPRESSOR FLUID 100 (254 LTR)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0883390</b>	WC0822065	WC0851459
Sample Date	Client Info		<b>13 Dec 2023</b>	28 Oct 2023	15 Sep 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>NORMAL</b>	NORMAL	ATTENTION

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>50	<b>0</b>	0	<1
Chromium	ppm	ASTM D5185(m)	>10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)		<b>0</b>	0	<1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1
Aluminum	ppm	ASTM D5185(m)	>25	<b>0</b>	0	0
Lead	ppm	ASTM D5185(m)	>25	<b>0</b>	<1	0
Copper	ppm	ASTM D5185(m)	>50	<b>&lt;1</b>	<1	1
Tin	ppm	ASTM D5185(m)	>15	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	0	<b>&lt;1</b>	0	<1
Barium	ppm	ASTM D5185(m)	0	<b>&lt;1</b>	0	<1
Molybdenum	ppm	ASTM D5185(m)	0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)		<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m)	0	<b>0</b>	0	0
Calcium	ppm	ASTM D5185(m)	0	<b>&lt;1</b>	<1	<1
Phosphorus	ppm	ASTM D5185(m)	50	<b>2</b>	3	2
Zinc	ppm	ASTM D5185(m)	0	<b>&lt;1</b>	<1	1
Sulfur	ppm	ASTM D5185(m)	1500	<b>2976</b>	2873	3299
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

## CONTAMINANTS






	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>25	<b>0</b>	0	0
Sodium	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	<1
Potassium	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Water	%	ASTM D6304*	>0.1	<b>0.002</b>	0.002	0.002
ppm Water	ppm	ASTM D6304*	>1000	<b>21</b>	17.9	18.2

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	<b>2016</b>	3643	▲ 10385
Particles >6µm	ASTM D7647	>2500	<b>422</b>	812	2010
Particles >14µm	ASTM D7647	>320	<b>15</b>	39	65
Particles >21µm	ASTM D7647	>80	<b>3</b>	10	16
Particles >38µm	ASTM D7647	>20	<b>0</b>	1	2
Particles >71µm	ASTM D7647	>4	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	<b>18/16/11</b>	19/17/12	▲ 21/18/13



# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.3	<b>0.08</b>	0.07	0.07






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	101.0	<b>100</b>	100	99.9

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



## GRAPHS



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0883390  
**Lab Number** : 02603234  
**Unique Number** : 5696319  
**Test Package** : IND 2 ( Additional Tests: KF, TAN Man )

**Received** : 14 Dec 2023  
**Diagnosed** : 15 Dec 2023  
**Diagnostician** : Wes Davis

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**Petro Canada Lubricants Inc.**  
 385 Southdown Road  
 Mississauga, ON  
 CA L5J 2Y3  
 Contact: Kyle Blezard  
 kyle.blezard@HFSinclair.com  
 T: (905)403-6768  
 F: (905)822-6025