

COOLANT REPORT

DOOSAN DL250-5

Component

Rear Coolant

DOOSAN 50/50 COOLANT (--- GAL)

Sample Rating Trend



DIAGNOSIS

Recommendation

The coolant change at the time of sampling has been noted. Resample at the next service interval to monitor.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition

The nitrite level is acceptable. The pH is low which causes rust formation.

				Dec2023		
CAMPLE INCOR	AATION					
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0851985		
Sample Date		Client Info		12 Dec 2023		
Machine Age	hrs	Client Info		2500		
Oil Age	hrs	Client Info		2500		
Oil Changed		Client Info		Changed		
Sample Status				ABNORMAL		
PHYSICAL TEST F	RESULTS	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*		1.068		
рН	Scale 0-14	ASTM D1287*		7.54		
Nitrites	ppm	Alcan Test Kit*		880		
Reserve Alkalinity	Scale 0-20	ASTM D1121*		6.1		
Percentage Glycol	%	ASTM D3321*		50.2		
Freezing Point	°C	ASTM D3321*		-35		
Carboxylate						
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		16		
Phosphorus	ppm	ASTM D5185(m)		839		
Boron	ppm	ASTM D5185(m)		17		
Molybdenum	ppm	ASTM D5185(m)		25		
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>15	0		
Aluminum	ppm	ASTM D5185(m)	>10	<1		
Copper	ppm	ASTM D5185(m)	>10	5		
Lead	ppm	ASTM D5185(m)	>10	0		
Tin	ppm	ASTM D5185(m)	>10	0		
Silver	ppm	ASTM D5185(m)	>10	<1		
Zinc	ppm	ASTM D5185(m)		0		
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		1166		
Potassium	ppm	ASTM D5185(m)		34748		
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	>100	<1		
Magnesium	ppm	ASTM D5185(m)	>40	0		
Hardness	mg/L CaCO3	In-house*	<75	2		
VISUAL		method	limit/base	current	history1	history2
Coolant Color		Visual*		Green		
Coolant Appearance		Visual*	Clear	Clear		
Color					no image	no image
Bottom					no image	no image



COOLANT REPORT





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number Unique Number : 5696430 Test Package : COOL

: WC0851985 : 02603345

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Recieved Diagnosed

Diagnostician : Kevin Marson

: 14 Dec 2023 : 18 Dec 2023

CA NOM 2TO Contact: CG Equipment CG Guelph cory@cgequipment.com T: (519)826-0550

7367 Wellington Rd. 30, Unit A

F: (519)837-2055

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

C.G. EQUIPMENT

Guelph, ON