




PROBLEM SUMMARY

Sample Rating Trend

ISO




Area
BOF/OG SYSTEM
 Machine Id
D - O.G. Fan Lube System # 8
 Component
Lube System
 Fluid
PETRO CANADA HYDREX AW 100 (135 GAL)




COMPONENT CONDITION SUMMARY

Particle Trend



Water (KF)



RECOMMENDATION

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	SEVERE
Water	%	ASTM D6304*	>0.05	▲ 0.056	▲ 0.072	---
ppm Water	ppm	ASTM D6304*	>500	▲ 569	▲ 720	---
Particles >4µm		ASTM D7647	>5000	● 52837	▲ 15475	● 48216
Particles >6µm		ASTM D7647	>1300	● 18364	▲ 2452	● 15529
Particles >14µm		ASTM D7647	>160	● 2070	▲ 165	▲ 1274
Particles >21µm		ASTM D7647	>40	● 566	31	● 329
Particles >38µm		ASTM D7647	>10	▲ 32	0	7
Oil Cleanliness		ISO 4406 (c)	>19/17/14	● 23/21/18	▲ 21/18/15	● 23/21/17
Appearance	scalar	Visual*	NORML	▲ WGOIL	▲ WGOIL	NORML
Emulsified Water	scalar	Visual*	>0.05	▲ .5%	▲ .2%	NEG
Free Water	scalar	Visual*		▲ 1%	▲ 5%	NEG

Customer Id: LEWBOSC
 Sample No.: WC0890391
 Lab Number: 02603482
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

WATER



16 Oct 2023 Diag: Kevin Marson

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. There is a moderate concentration of water present in the oil. The sample contained a visible layer of foreign fluid contaminant, the origin and/or type of fluid is unknown. NOTE: Contaminant present displays similar properties/color to fire resistant fluid, advise investigate. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)



ISO



16 Aug 2023 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

[view report](#)



WATER



20 Jun 2023 Diag: Kevin Marson

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. Free water present. The oil viscosity is lower than typical, possibly indicating the addition of lighter grade oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
BOF/OG SYSTEM
 Machine Id
D - O.G. Fan Lube System # 8
 Component
Lube System
 Fluid
PETRO CANADA HYDREX AW 100 (135 GAL)

DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample in 30-45 days to monitor this situation.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. There is a light concentration of water present in the oil. Free water present.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0890391	WC0871207	WC0850092
Sample Date	Client Info	15 Dec 2023	16 Oct 2023	16 Aug 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		SEVERE	ABNORMAL	SEVERE

WEAR METALS

method	limit/base	current	history1	history2		
PQ	ASTM D8184*	>99999	0	0		
Iron	ppm	ASTM D5185(m)	>20	<1	<1	4
Chromium	ppm	ASTM D5185(m)	>20	0	0	
Nickel	ppm	ASTM D5185(m)	>20	<1	0	<1
Titanium	ppm	ASTM D5185(m)		0	0	
Silver	ppm	ASTM D5185(m)		<1	<1	
Aluminum	ppm	ASTM D5185(m)	>20	0	0	<1
Lead	ppm	ASTM D5185(m)	>20	<1	<1	0
Copper	ppm	ASTM D5185(m)	>20	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>20	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185(m)	0	<1	<1	<1
Barium	ppm	ASTM D5185(m)	0	<1	<1	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0	0
Magnesium	ppm	ASTM D5185(m)	0	<1	0	<1
Calcium	ppm	ASTM D5185(m)	50	47	47	49
Phosphorus	ppm	ASTM D5185(m)	330	333	331	353
Zinc	ppm	ASTM D5185(m)	430	429	428	433
Sulfur	ppm	ASTM D5185(m)	760	2633	2613	2799
Lithium	ppm	ASTM D5185(m)		<1	<1	<1






CONTAMINANTS

method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185(m)	>15	4	4	5
Sodium	ppm	ASTM D5185(m)		<1	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	0	0	0
Water	%	ASTM D6304*	>0.05	▲ 0.056	▲ 0.072	---
ppm Water	ppm	ASTM D6304*	>500	▲ 569	▲ 720	---

FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>5000	● 52837	▲ 15475	● 48216
Particles >6µm	ASTM D7647	>1300	● 18364	▲ 2452	● 15529
Particles >14µm	ASTM D7647	>160	● 2070	▲ 165	▲ 1274
Particles >21µm	ASTM D7647	>40	● 566	31	● 329
Particles >38µm	ASTM D7647	>10	▲ 32	0	7
Particles >71µm	ASTM D7647	>3	1	0	1
Oil Cleanliness	ISO 4406 (c)	>19/17/14	● 23/21/18	▲ 21/18/15	● 23/21/17

OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.60	0.48	0.51	0.52






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	VLITE	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	VLITE	NONE	NONE
Appearance	scalar	Visual*	NORML	WGOIL	WGOIL	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	.5%	.2%	NEG
Free Water	scalar	Visual*		1%	5%	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	101	90.3	92.9	92.3

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **STELCO - BOSC - Basic Oxygen Slab Caster**
Sample No. : WC0890391 **Received** : 15 Dec 2023 2330 Regional Road #3, Door: BOSC8
Lab Number : **02603482** **Diagnosed** : 20 Dec 2023 NANTICOKE, ON
Unique Number : 5696567 **Diagnostician** : Kevin Marson CA N0A 1L0
Test Package : IND 2 (Additional Tests: KF, PQ)
 Contact: Tom Walden
 Thomas.Walden@stelco.com
 T: (519)587-4541
 F: (519)587-7702

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.