




# PROBLEM SUMMARY

## Sample Rating Trend

ISO




Area  
**Caster/Hydraulics**  
 Machine Id  
**D - Strand 2-1 Hydraulic Tank**  
 Component  
**Hydraulic System**  
 Fluid  
**FORSYTHE NO FIRE WG 200R (5000 LTR)**



## COMPONENT CONDITION SUMMARY

### Particle Trend



## RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>5000	▲ 34571	▲ 9302	▲ 20105
Particles >6µm	ASTM D7647	>1300	● 11804	▲ 2163	▲ 6945
Particles >14µm	ASTM D7647	>160	▲ 715	▲ 193	▲ 669
Particles >21µm	ASTM D7647	>40	▲ 103	▲ 85	▲ 149
Oil Cleanliness	ISO 4406 (c)	>19/17/14	● 22/21/17	▲ 20/18/15	▲ 22/20/17

Customer Id: LEWBOSC  
 Sample No.: WC0890395  
 Lab Number: 02603620  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	NOTE: We recommend using IND 3 test kits,
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

## HISTORICAL DIAGNOSIS

### 16 Oct 2023 Diag: Kevin Marson

ISO



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The water concentration level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 16 Aug 2023 Diag: Kevin Marson

ISO



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The water concentration level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 13 Jul 2023 Diag: Kevin Marson

ISO



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of particulates (2 to 100 microns in size) present in the oil. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The water concentration level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report






# COOLANT REPORT

Sample Rating Trend

ISO



Area  
**Caster/Hydraulics**  
 Machine Id  
**D - Strand 2-1 Hydraulic Tank**  
 Component  
**Hydraulic System**  
 Fluid  
**FORSYTHE NO FIRE WG 200R (5000 LTR)**



## DIAGNOSIS

### Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

### Wear

Component wear rates appear to be normal (unconfirmed).

### Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable. The water concentration level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

Sample Number	Client Info	method	limit/base	current	history1	history2
WC0890395					WC0871200	WC0850100
Sample Date	Client Info			<b>15 Dec 2023</b>	16 Oct 2023	16 Aug 2023
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>SEVERE</b>	ABNORMAL	ABNORMAL

## CONTAMINATION

Water	WC Method	method	limit/base	current	history1	history2
				<b>NEG</b>	NEG	NEG

## CORROSION INHIBITORS

Silicon	ppm	ASTM D5185(m)	limit/base	current	history1	history2
				<b>&lt;1</b>	<1	0
Phosphorus	ppm	ASTM D5185(m)		<b>1</b>	<1	0
Boron	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	0
Molybdenum	ppm	ASTM D5185(m)		<b>0</b>	0	0

## CORROSION

Iron	ppm	ASTM D5185(m)	limit/base	current	history1	history2
			>20	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Copper	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Lead	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Tin	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	0
Zinc	ppm	ASTM D5185(m)		<b>0</b>	0	0

## CONTAMINANTS

Particles >4µm	method	limit/base	current	history1	history2
	ASTM D7647	>5000	<b>▲ 34571</b>	▲ 9302	▲ 20105
Particles >6µm	ASTM D7647	>1300	<b>● 11804</b>	▲ 2163	▲ 6945
Particles >14µm	ASTM D7647	>160	<b>▲ 715</b>	▲ 193	▲ 669
Particles >21µm	ASTM D7647	>40	<b>▲ 103</b>	▲ 85	▲ 149
Particles >38µm	ASTM D7647	>10	<b>0</b>	▲ 15	2
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>● 22/21/17</b>	▲ 20/18/15	▲ 22/20/17


## CARRIER SALTS

Sodium	ppm	ASTM D5185(m)	limit/base	current	history1	history2
				<b>188</b>	168	158
Potassium	ppm	ASTM D5185(m)		<b>11</b>	15	0

## SCALE POTENTIAL

Calcium	ppm	ASTM D5185(m)	limit/base	current	history1	history2
				<b>1</b>	<1	2
Magnesium	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	<1


## Particle Trend




VISUAL	method	limit/base	current	history1	history2
--------	--------	------------	---------	----------	----------

Color

Bottom




## Water (KF)




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C




### Particle Count




## Reserve Alkalinity



## PQ



## Reserve Alkalinity



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **STELCO - BOSC - Basic Oxygen Slab Caster**  
**Sample No.** : WC0890395 **Received** : 15 Dec 2023 2330 Regional Road #3, Door: BOSC8  
**Lab Number** : 02603620 **Diagnosed** : 21 Dec 2023 NANTICOKE, ON  
**Unique Number** : 5696705 **Diagnostician** : Kevin Marson CA N0A 1L0  
**Test Package** : IND 2 ( Additional Tests: KF, pH, PQ, ReserveAlk, TAN Man )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

Contact: Tom Walden  
 Thomas.Walden@stelco.com  
 T: (519)587-4541  
 F: (519)587-7702