




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
(ZONE3) BRUCE A/1/34720
Machine Id
1-34720-P1-PM Up Brg
Component
Upper Bearing
Fluid
ESSO NUTO H ISO 46 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.
NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0871692	WC22121565	---
Sample Date	Client Info		04 Dec 2023	22 Nov 2016	---
Machine Age	hrs	Client Info	0	0	---
Oil Age	hrs	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			NORMAL	NORMAL	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >10	0	<1	---
Chromium	ppm	ASTM D5185(m) >5	0	0	---
Nickel	ppm	ASTM D5185(m) >5	<1	0	---
Titanium	ppm	ASTM D5185(m) >5	0	0	---
Silver	ppm	ASTM D5185(m)	<1	0	---
Aluminum	ppm	ASTM D5185(m) >5	0	<1	---
Lead	ppm	ASTM D5185(m) >5	<1	<1	---
Copper	ppm	ASTM D5185(m) >5	<1	1	---
Tin	ppm	ASTM D5185(m) >5	0	0	---
Antimony	ppm	ASTM D5185(m)	0	0	---
Vanadium	ppm	ASTM D5185(m)	0	0	---
Beryllium	ppm	ASTM D5185(m)	0	0	---
Cadmium	ppm	ASTM D5185(m)	0	<1	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0	<1	0	---
Barium	ppm	ASTM D5185(m) 0	<1	<1	---
Molybdenum	ppm	ASTM D5185(m) 0	0	0	---
Manganese	ppm	ASTM D5185(m)	0	0	---
Magnesium	ppm	ASTM D5185(m) 5	0	0	---
Calcium	ppm	ASTM D5185(m) 50	53	43	---
Phosphorus	ppm	ASTM D5185(m) 330	344	337	---
Zinc	ppm	ASTM D5185(m) 410	449	452	---
Sulfur	ppm	ASTM D5185(m) 2700	4966	2655	---
Lithium	ppm	ASTM D5185(m)	<1	<1	---

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >5	<1	<1	---
Sodium	ppm	ASTM D5185(m) >5	<1	3	---
Potassium	ppm	ASTM D5185(m) >20	0	0	---
Water	%	ASTM D6304* >0.005	0.003	0.002	---
ppm Water	ppm	ASTM D6304* >50	37	22.5	---

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	798	7033	---
Particles >6µm	ASTM D7647	>1300	151	1145	---
Particles >14µm	ASTM D7647	>320	9	57	---
Particles >21µm	ASTM D7647	>80	4	9	---
Particles >38µm	ASTM D7647	>20	0	0	---
Particles >71µm	ASTM D7647	>4	0	0	---
Oil Cleanliness	ISO 4406 (c)	>19/17/15	17/14/10	20/17/13	---




OIL ANALYSIS REPORT








FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.45	0.52	0.52	---
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	NORML	---
Emulsified Water	scalar	Visual*	>0.005	NEG	NEG	---
Free Water	scalar	Visual*		NEG	NEG	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46	44.6	46.8	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0871692 **Received** : 18 Dec 2023
Lab Number : 02603827 **Diagnosed** : 20 Dec 2023
Unique Number : 5696912 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: TAN Man)

Bruce Power - Bruce A PdM
P.O.Box 1540, 177 Tie Road., RM-222 U2 Column 2N11 615
Tiverton, ON
CA N0G 2T0
Contact: Pierre Adouki
pierre.adouki@brucepower.com
T: (519)361-2673
F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.