




# PROBLEM SUMMARY

Sample Rating Trend




ISO



Area  
**(ZONE3) BRUCE A/4/34710**  
 Machine Id  
**4-34710-P1-P IB Brg**  
 Component  
**Inboard Bearing**  
 Fluid  
**MOBIL DTE 732 (--- GAL)**

## COMPONENT CONDITION SUMMARY

### Particle Trend



## RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ATTENTION	NORMAL
Particles >4µm	ASTM D7647	>5000	114994	5238	---
Particles >6µm	ASTM D7647	>1300	32188	1333	---
Particles >14µm	ASTM D7647	>320	3267	128	---
Particles >21µm	ASTM D7647	>80	843	38	---
Oil Cleanliness	ISO 4406 (c)	>19/17/15	24/22/19	20/18/14	---

Customer Id: BRUTIV  
 Sample No.: WC  
 Lab Number: 02603828  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

**RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

**HISTORICAL DIAGNOSIS**

**27 Sep 2023 Diag: Kevin Marson**

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



**23 Mar 2023 Diag: Kevin Marson**

NORMAL



Due to this condition we recommend the following action... We advise an early resample to confirm this situation. {not applicable} Insufficient sample was received to conduct all the routine laboratory tests. {not applicable}

view report



**16 Jun 2022 Diag: Kevin Marson**

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. Particles >6µm are severely high. Oil Cleanliness are severely high. Particles >4µm are severely high. Particles >38µm are abnormally high. Particles >14µm are abnormally high. Particles >21µm are abnormally high. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**(ZONE3) BRUCE A/4/34710**  
Machine Id  
**4-34710-P1-P IB Brg**  
Component  
**Inboard Bearing**  
Fluid  
**MOBIL DTE 732 (--- GAL)**

## DIAGNOSIS

### Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

All component wear rates are normal. The ferrography results are normal indicating no abnormal wear in the system.

### Contaminants

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

### Oil Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC</b>	WC0815680	WC
Sample Date	Client Info		<b>24 Nov 2023</b>	27 Sep 2023	23 Mar 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	ATTENTION	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >10	<b>2</b>	<1	3
Chromium	ppm	ASTM D5185(m) >5	<b>&lt;1</b>	0	<1
Nickel	ppm	ASTM D5185(m) >5	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185(m) >5	<b>0</b>	0	<1
Silver	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	0
Aluminum	ppm	ASTM D5185(m) >5	<b>0</b>	<1	<1
Lead	ppm	ASTM D5185(m) >5	<b>&lt;1</b>	<1	<1
Copper	ppm	ASTM D5185(m) >5	<b>&lt;1</b>	<1	2
Tin	ppm	ASTM D5185(m) >5	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1
Barium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	0
Molybdenum	ppm	ASTM D5185(m)	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m)	<b>1</b>	<1	1
Calcium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	0
Phosphorus	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	0
Zinc	ppm	ASTM D5185(m)	<b>1</b>	<1	<1
Sulfur	ppm	ASTM D5185(m)	<b>62</b>	54	415
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1






## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >5	<b>&lt;1</b>	0	1
Sodium	ppm	ASTM D5185(m) >5	<b>0</b>	0	<1
Potassium	ppm	ASTM D5185(m) >20	<b>0</b>	0	0
Water	%	ASTM D6304* >0.005	<b>0.005</b>	0.004	---
ppm Water	ppm	ASTM D6304* >50	<b>58</b>	48	---

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>114994</b>	5238	---
Particles >6µm	ASTM D7647	>1300	<b>32188</b>	1333	---
Particles >14µm	ASTM D7647	>320	<b>3267</b>	128	---
Particles >21µm	ASTM D7647	>80	<b>843</b>	38	---
Particles >38µm	ASTM D7647	>20	<b>32</b>	2	---
Particles >71µm	ASTM D7647	>4	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c)	>19/17/15	<b>24/22/19</b>	20/18/14	---

# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.10	<b>0.09</b>	0.12	---






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	VLITE	VLITE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>VLITE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>LIGHT</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.005	<b>.5%</b>	.5%	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	30.0	<b>32.8</b>	30.6	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC  
**Lab Number** : 02603828  
**Unique Number** : 5696913  
**Test Package** : IND 2 ( Additional Tests: A-FERR, BottomAnalysis, DR-FERR, FILTERPATCH, TAN Man )  
**Received** : 18 Dec 2023  
**Diagnosed** : 22 Dec 2023  
**Diagnostician** : Kevin Marson  
**Revised** : 18 Dec 2023  
**Diagnosed** : 22 Dec 2023  
**Diagnostician** : Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: A-FERR, BottomAnalysis, DR-FERR, FILTERPATCH, TAN Man )

**Bruce Power - Bruce A PdM**  
 P.O.Box 1540, 177 Tie Road., RM-222 U2 Column 2N11 615'  
 Tiverton, ON  
 CA N0G 2T0  
 Contact: Pierre Adouki  
 pierre.adouki@brucepower.com  
 T: (519)361-2673  
 F:


To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.




# FERROGRAPHY REPORT

Area  
**(ZONE3) BRUCE A/4/34710**  
 Machine Id  
**4-34710-P1-P IB Brg**  
 Component  
**Inboard Bearing**  
 Fluid  
**MOBIL DTE 732 (--- GAL)**


Magn: 200x Illum: BC



Magn: 50x Illum: RW



Magn: 100x Illum: RW




DR-FERROGRAPHY		method	limit/base	current	history1	history2
Large Particles		DR-Ferr*		<b>71.1</b>	---	---
Small Particles		DR-Ferr*		<b>28.3</b>	---	---
Total Particles		DR-Ferr*	>---	<b>99.4</b>	---	---
Large Particles Percentage	%	DR-Ferr*		<b>43.1</b>	---	---
Severity Index		DR-Ferr*		<b>3043</b>	---	---

FERROGRAPHY		method	limit/base	current	history1	history2
Ferrous Rubbing	Scale 0-10	ASTM D7684*		<b>2</b>		
Ferrous Sliding	Scale 0-10	ASTM D7684*				
Ferrous Cutting	Scale 0-10	ASTM D7684*				
Ferrous Rolling	Scale 0-10	ASTM D7684*		<b>1</b>		
Ferrous Break-in	Scale 0-10	ASTM D7684*				
Ferrous Spheres	Scale 0-10	ASTM D7684*				
Ferrous Black Oxides	Scale 0-10	ASTM D7684*		<b>1</b>		
Ferrous Red Oxides	Scale 0-10	ASTM D7684*				
Ferrous Corrosive	Scale 0-10	ASTM D7684*		<b>1</b>		
Ferrous Other	Scale 0-10	ASTM D7684*				
Nonferrous Rubbing	Scale 0-10	ASTM D7684*				
Nonferrous Sliding	Scale 0-10	ASTM D7684*				
Nonferrous Cutting	Scale 0-10	ASTM D7684*				
Nonferrous Rolling	Scale 0-10	ASTM D7684*				
Nonferrous Other	Scale 0-10	ASTM D7684*				
Carbonaceous Material	Scale 0-10	ASTM D7684*				
Lubricant Degradation	Scale 0-10	ASTM D7684*				
Sand/Dirt	Scale 0-10	ASTM D7684*		<b>1</b>		
Fibres	Scale 0-10	ASTM D7684*				
Spheres	Scale 0-10	ASTM D7684*				
Other	Scale 0-10	ASTM D7684*		<b>2</b>		

## WEAR

All component wear rates are normal.  
 The ferrography results are normal  
 indicating no abnormal wear in the  
 system.

## DR Ferrography



*This page left intentionally blank*