



PROBLEM SUMMARY


Sample Rating Trend



Area
(ZONE3) BRUCE A/1/34720
 Machine Id
1-34720-P2-PM Up Brg
 Component
Upper Bearing
 Fluid
ESSO NUTO H ISO 46 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

Sample Status		ATTENTION	ATTENTION	---
Particles >4µm	ASTM D7647 >5000	▲ 5959	▲ 17555	---
Oil Cleanliness	ISO 4406 (c) >19/17/15	▲ 20/17/10	▲ 21/19/15	---

Customer Id: BRUTIV
 Sample No.: WC0871703
 Lab Number: 02603834
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

HISTORICAL DIAGNOSIS

22 Nov 2016 Diag: Wes Davis

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
(ZONE3) BRUCE A/1/34720
 Machine Id
1-34720-P2-PM Up Brg
 Component
Upper Bearing
 Fluid
ESSO NUTO H ISO 46 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0871703	WC2212154	---
Sample Date	Client Info		04 Dec 2023	22 Nov 2016	---
Machine Age	hrs	Client Info	0	0	---
Oil Age	hrs	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			ATTENTION	ATTENTION	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >10	<1	2	---
Chromium	ppm	ASTM D5185(m) >5	0	0	---
Nickel	ppm	ASTM D5185(m) >5	<1	0	---
Titanium	ppm	ASTM D5185(m) >5	0	0	---
Silver	ppm	ASTM D5185(m)	<1	0	---
Aluminum	ppm	ASTM D5185(m) >5	0	<1	---
Lead	ppm	ASTM D5185(m) >5	<1	<1	---
Copper	ppm	ASTM D5185(m) >5	<1	2	---
Tin	ppm	ASTM D5185(m) >5	0	0	---
Antimony	ppm	ASTM D5185(m)	0	0	---
Vanadium	ppm	ASTM D5185(m)	0	0	---
Beryllium	ppm	ASTM D5185(m)	0	0	---
Cadmium	ppm	ASTM D5185(m)	0	<1	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0	<1	0	---
Barium	ppm	ASTM D5185(m) 0	<1	<1	---
Molybdenum	ppm	ASTM D5185(m) 0	0	0	---
Manganese	ppm	ASTM D5185(m)	0	0	---
Magnesium	ppm	ASTM D5185(m) 5	0	0	---
Calcium	ppm	ASTM D5185(m) 50	59	39	---
Phosphorus	ppm	ASTM D5185(m) 330	347	304	---
Zinc	ppm	ASTM D5185(m) 410	456	423	---
Sulfur	ppm	ASTM D5185(m) 2700	5768	2316	---
Lithium	ppm	ASTM D5185(m)	<1	<1	---

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >5	0	<1	---
Sodium	ppm	ASTM D5185(m) >5	0	1	---
Potassium	ppm	ASTM D5185(m) >20	0	0	---
Water	%	ASTM D6304* >0.005	0.003	0.002	---
ppm Water	ppm	ASTM D6304* >50	35	21.3	---

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ 5959	▲ 17555	---
Particles >6µm	ASTM D7647	>1300	730	▲ 2682	---
Particles >14µm	ASTM D7647	>320	8	▲ 189	---
Particles >21µm	ASTM D7647	>80	2	41	---
Particles >38µm	ASTM D7647	>20	0	4	---
Particles >71µm	ASTM D7647	>4	0	2	---
Oil Cleanliness	ISO 4406 (c)	>19/17/15	▲ 20/17/10	▲ 21/19/15	---



OIL ANALYSIS REPORT




FLUID DEGRADATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.45	0.50	0.47	---





VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	VLITE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	NORML	---
Emulsified Water	scalar	Visual*	>0.005	NEG	NEG	---
Free Water	scalar	Visual*		NEG	NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	46	43.8	46.4	---

SAMPLE IMAGES



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0871703 **Received** : 18 Dec 2023
Lab Number : **02603834** **Diagnosed** : 20 Dec 2023
Unique Number : 5696919 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: TAN Man)

Bruce Power - Bruce A PdM
 P.O.Box 1540, 177 Tie Road., RM-222 U2 Column 2N11 615
 Tiverton, ON
 CA N0G 2T0
 Contact: Andrew Roffey
 andrew.roffey@brucepower.com
 T: (519)361-2673 x:17186
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.