




PROBLEM SUMMARY

Sample Rating Trend


ADDITIVES

Area
BRUCE A/4/75120
 Machine Id
4-75120-CP1 Ld (LP/HP-MK2)-Lube Oil Level
 Component
Reciprocating Compressor
 Fluid
SHELL CORENA P 68 (--- GAL)



COMPONENT CONDITION SUMMARY

▲ Additives



RECOMMENDATION

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. NOTE: Fluid appears to match the fluid ATLAS COPCO ROTO Z FLUID, advise investigate.

PROBLEMATIC TEST RESULTS

Sample Status				ATTENTION	SEVERE	ABNORMAL
Phosphorus	ppm	ASTM D5185(m)	100	▲ 467	170	166
Zinc	ppm	ASTM D5185(m)	115	▲ 3	193	186
Sulfur	ppm	ASTM D5185(m)	1300	▲ 625	1362	1421

Customer Id: BRUTIV
 Sample No.: WC0871699
 Lab Number: 02603835
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.

HISTORICAL DIAGNOSIS

05 Sep 2014 Diag: Kevin Marson

WEAR



We recommend that you drain the oil from the component if this has not already been done. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Iron ppm levels are severe. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. Particles >6µm are abnormally high. The water content is negligible. Viscosity of sample indicates oil is within ISO 100 range, advise investigate. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



28 Jan 2014 Diag: Kevin Marson

VISCOSITY



We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. Viscosity of sample indicates oil is within ISO 100 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



04 Jun 2013 Diag: Kevin Marson

WEAR



The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Iron ppm levels are severe. Copper ppm levels are abnormal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ADDITIVES



Area
BRUCE A/4/75120
 Machine Id
4-75120-CP1 Ld (LP/HP-MK2)-Lube Oil Level
 Component
Reciprocating Compressor
 Fluid
SHELL CORENA P 68 (--- GAL)

DIAGNOSIS

Recommendation

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. NOTE: Fluid appears to match the fluid ATLAS COPCO ROTO Z FLUID, advise investigate.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0871699	WC22108377	WC22106273
Sample Date	Client Info		06 Dec 2023	05 Sep 2014	28 Jan 2014
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ATTENTION	SEVERE	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >5	0	12	3
Chromium	ppm	ASTM D5185(m) >5	0	0	0
Nickel	ppm	ASTM D5185(m) >5	<1	0	0
Titanium	ppm	ASTM D5185(m) >5	0	0	0
Silver	ppm	ASTM D5185(m)	<1	<1	0
Aluminum	ppm	ASTM D5185(m) >5	<1	<1	<1
Lead	ppm	ASTM D5185(m) >5	<1	1	<1
Copper	ppm	ASTM D5185(m) >5	<1	4	<1
Tin	ppm	ASTM D5185(m) >5	0	<1	0
Antimony	ppm	ASTM D5185(m)	0	<1	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0	<1	<1	<1
Barium	ppm	ASTM D5185(m) 0	<1	0	0
Molybdenum	ppm	ASTM D5185(m) 0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	<1	<1
Magnesium	ppm	ASTM D5185(m) 0	0	<1	<1
Calcium	ppm	ASTM D5185(m) 20	1	60	64
Phosphorus	ppm	ASTM D5185(m) 100	▲ 467	170	166
Zinc	ppm	ASTM D5185(m) 115	▲ 3	193	186
Sulfur	ppm	ASTM D5185(m) 1300	▲ 625	1362	1421
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >5	0	<1	<1
Sodium	ppm	ASTM D5185(m)	<1	<1	<1
Potassium	ppm	ASTM D5185(m) >20	0	2	1
Water	%	ASTM D6304* >0.1	0.004	0.004	0.001
ppm Water	ppm	ASTM D6304* >1000	48	41.0	14.5


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	680	76882	45076
Particles >6µm	ASTM D7647	>2500	293	▲ 16701	▲ 2819
Particles >14µm	ASTM D7647	>320	19	88	94
Particles >21µm	ASTM D7647	>80	4	13	23
Particles >38µm	ASTM D7647	>20	1	1	0
Particles >71µm	ASTM D7647	>4	0	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	17/15/11	▲ 23/21/14	▲ 23/19/14




OIL ANALYSIS REPORT


Additives




Water (KF)




Particle Trend



Water (KF)



Viscosity @ 40°C




FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D974* 0.3	0.31	0.253	0.32
White Metal	scalar Visual* NONE	NONE	NONE	NONE
Yellow Metal	scalar Visual* NONE	NONE	NONE	NONE
Precipitate	scalar Visual* NONE	NONE	NONE	NONE
Silt	scalar Visual* NONE	NONE	NONE	NONE
Debris	scalar Visual* NONE	NONE	VLITE	LIGHT
Sand/Dirt	scalar Visual* NONE	NONE	NONE	NONE
Appearance	scalar Visual* NORML	NORML	NORML	NORML
Odor	scalar Visual* NORML	NORML	NORML	NORML
Emulsified Water	scalar Visual* >0.1	NEG	NEG	NEG
Free Water	scalar Visual*	NEG	NEG	NEG

FLUID PROPERTIES


method	limit/base	current	history1	history2
Visc @ 40°C cSt	ASTM D7279(m) 69	66.5	▲ 97.1	▲ 94.7

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0871699
Lab Number : **02603835**
Unique Number : 5696920
Test Package : IND 2 (Additional Tests: TAN Man)

Received : 18 Dec 2023
Diagnosed : 19 Dec 2023
Diagnostician : Kevin Marson

Bruce Power - Bruce A PdM
P.O.Box 1540, 177 Tie Road., RM-222 U2 Column 2N11 615
Tiverton, ON
CA N0G 2T0
Contact: Pierre Adouki
pierre.adouki@brucepower.com
T: (519)361-2673
F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.