

# **OIL ANALYSIS REPORT**

Sample Status

### Sample Rating Trend



NORMAL

Machine Id

# FORCED DRAFT FAN F1 - inboard bearing (S/N 1-32300-F1)

Component

**Inboard Bearing** 

DIAGNOSIS

Recommendation

ESSO TERESSO ISO 68 (--- LTR)

Resample at the next service interval to monitor.

reservoir capacity, filter type and micron rating with

NOTE: Please provide information regarding

# 0-F1)



**NORMAL** 

NORMAL

### Wear

All component wear rates are normal.

#### Contamination

next sample.

The water content is negligible. There is no indication of any contamination in the oil.

#### **Fluid Condition**

The condition of the oil is acceptable for the time in service.


Iron ppm ASTM D5185(m) >20 0 0 <1	
Nickel ppm ASTM D5185(m) >20 0 0 0   Titanium ppm ASTM D5185(m) 0 0 0	
Titanium ppm ASTM D5185(m) 0 0	
Silver ppm ASTM D5185/m) -1 0	
Onvoi ppin noiw boloojiij Ci 0 0	
<b>Aluminum</b> ppm ASTM D5185(m) >20 <b>0</b> 0	
<b>Lead</b> ppm ASTM D5185(m) >20 <b>2</b> 1 2	
Copper ppm ASTM D5185(m) >20 1 1	
Tin ppm ASTM D5185(m) >20 <b>0</b> 0 <1	
Antimony ppm ASTM D5185(m) 0 <1	
Vanadium ppm ASTM D5185(m) 0 0	
Beryllium ppm ASTM D5185(m) 0 0	
Cadmium ppm ASTM D5185(m) 0 0 0	

ADDITIVES		method				history2
Boron	ppm	ASTM D5185(m)	4.5	<1	0	0
Barium	ppm	ASTM D5185(m)	0.4	<1	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)		0	0	0
Magnesium	ppm	ASTM D5185(m)	0	0	<1	0
Calcium	ppm	ASTM D5185(m)	0	2	3	<1
Phosphorus	ppm	ASTM D5185(m)	0.7	11	11	11
Zinc	ppm	ASTM D5185(m)	0	6	8	8
Sulfur	ppm	ASTM D5185(m)	1315	4796	4758	4750
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS		method				history2
Silicon	ppm	ASTM D5185(m)	>15	3	2	2
Sodium	ppm	ASTM D5185(m)		<1	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	0	<1	0
Water	%	ASTM D6304*	>2	0.00		
ppm Water	ppm	ASTM D6304*		0		




## **OIL ANALYSIS REPORT**




VISUAL		method	limit/base	current	history1	history2
VIOOAL		method	IIIIII basc	Carrent	Thatary	HISTOTYZ
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	VLITE	VLITE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	Visual*	>2	.2%	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG
FLUID PROPERT	TIES	method				history2
Visc @ 40°C	cSt	ASTM D7279(m)	68	67.2	66.9	66.8


Color



**Bottom** 

SAMPLE IMAGES







CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number Unique Number : 5697242

: WC0861491 : 02604157

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Recieved Diagnosed

: 19 Dec 2023 Diagnostician : Kevin Marson

: 20 Dec 2023

Test Package : IND 1 (Additional Tests: KF) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

**Ontario Power Generation** ATIKOKAN T.G.S., BOX 1900

ATIKOKAN, ON CA POT 1C0

Contact: Dale Anthony dale.anthony@opg.com

F: (807)597-1198

Submitted By: ?