

PROBLEM SUMMARY

Sample Rating Trend

VISCOSITY


SILO 1 DISCHARGE SCREW CONVEYOR 2 GEARBOX (S/N 0-37200-S002)

Component

Gearbox

GEAR OIL (PAO) ISO 150 (37 LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

PROBLEMATIC TEST RESULTS							
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
Visc @ 40°C	cSt	ASTM D7279(m)	150	4 394	<u>417</u>	<u>452</u>	

Customer Id: ONTATI **Sample No.:** WC0851407 Lab Number: 02604226 Test Package: IND 1



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Information Required			?	Please specify the brand, type, and viscosity of the oil on your next sample.

HISTORICAL DIAGNOSIS

08 Mar 2023 Diag: Kevin Marson

VISCOSITY



Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 460 range, advise investigate. The condition of the oil is acceptable for the time in service.



08 Sep 2022 Diag: Kevin Marson

VISCOSITY



Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 460 range, advise investigate. The condition of the oil is acceptable for the time in service.

view report

01 Sep 2021 Diag: Kevin Marson

VISCOSITY



Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. The fluid was specified as (GENERIC) GEAR OIL (PAO) ISO 150, however, a fluid match indicates that this fluid is ISO 460 Gear Oil. Please confirm the oil type and grade on your next sample. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 460 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT

Sample Rating Trend

VISCOSITY

Machine Id

SILO 1 DISCHARGE SCREW CONVEYOR 2 GEARBOX (S/N 0-37200-S002)

Component

Gearbox

GEAR OIL (PAO) ISO 150 (37 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

Viscosity of sample indicates oil is within ISO 460 range, advise investigate. The condition of the oil is acceptable for the time in service.

	M _M 2019 S ₈₀₀ 2019 Fab2020 S ₈₀₀ 2020 Apr2021 S ₈₀₀ 2022 M ₈₀₂ 2022 M ₈₀₂ 2022 S ₈₀₀ 2023 S ₈₀₀ 2023						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		WC0851407	WC0794194	WC0736560	
Sample Date		Client Info		10 Sep 2023	08 Mar 2023	08 Sep 2022	
Machine Age	hrs	Client Info		0	0	0	
Oil Age	hrs	Client Info		0	0	0	
Oil Changed		Client Info		N/A	N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
CONTAMINATION		method	limit/base	current	history1	history2	
Water		WC Method	>0.2	NEG	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>200	5	3	3	
Chromium	ppm	ASTM D5185(m)	>15	0	0	0	
Nickel	ppm	ASTM D5185(m)	>15	<1	<1	<1	
Titanium	ppm	ASTM D5185(m)		0	0	0	
Silver	ppm	ASTM D5185(m)		<1	<1	0	
Aluminum	ppm	ASTM D5185(m)	>25	<1	0	0	
Lead	ppm	ASTM D5185(m)	>100	<1	0	0	
Copper	ppm	ASTM D5185(m)	>200	<1	0	<1	
Tin	ppm	ASTM D5185(m)	>25	0	0	0	
Antimony	ppm	ASTM D5185(m)	>5	0	<1	<1	
Vanadium	ppm	ASTM D5185(m)		0	0	0	
Beryllium	ppm	ASTM D5185(m)		0	0	0	
Cadmium	ppm	ASTM D5185(m)		0	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	25	23	29	31	
Barium	ppm	ASTM D5185(m)	12	<1	0	0	
Molybdenum	ppm	ASTM D5185(m)	5	0	0	0	
Manganese	ppm	ASTM D5185(m)		0	0	0	
Magnesium	ppm	ASTM D5185(m)	25	11	1	2	
Calcium	ppm	ASTM D5185(m)	25	11	9	9	
Phosphorus	ppm	ASTM D5185(m)	375	317	360	357	
Zinc	ppm	ASTM D5185(m)	25	4	2	3	
Sulfur	ppm	ASTM D5185(m)	4900	13683	14427	15211	
Lithium	ppm	ASTM D5185(m)		<1	<1	<1	
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>50	17	1	3	
Sodium	ppm	ASTM D5185(m)		2	0	0	
Potassium	ppm	ASTM D5185(m)	>20	<1	0	<1	




OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG
FLUID PROPERT	ΓIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	150	△ 394	▲ 417	△ 452
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color						3
Bottom						

GRAPHS





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number Unique Number : 5697311 Test Package : IND 1

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : WC0851407 : 02604226

Recieved Diagnosed

: 19 Dec 2023 : 20 Dec 2023 Diagnostician : Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Ontario Power Generation ATIKOKAN T.G.S., BOX 1900 ATIKOKAN, ON

CA POT 1C0 Contact: Dale Anthony dale.anthony@opg.com

F: (807)597-1198