

COOLANT REPORT

[6100242162] Machine Id NO UNIT WA0018424

Component

Coolant

EXTENDED LIFE COOLANT (--- GAL)

Sample Rating Trend WEAR Deadless

DIAGNOSIS

Recommendation

We recommend that you drain the system and refill with a 50/50 long-life coolant/water mixture. We recommend an early resample to monitor this condition.

Corrosion

Copper ppm levels are abnormal. The high metal levels indicate corrosion in the system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition

The reserve alkalinity of this fluid is acceptable.

				Dec2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WA0018424		
Sample Date		Client Info		18 Dec 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*		1.067		
рН	Scale 0-14	ASTM D1287*	9.0	6.99		
Nitrites	ppm	Alcan Test Kit*		320		
Reserve Alkalinity	Scale 0-20	ASTM D1121*		2.6		
Percentage Glycol	%	ASTM D3321*	50	50.0		
Freezing Point	°C	ASTM D3321*	-40	-35		
Carboxylate						
CORROSION INHI	BITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		10		
Phosphorus	ppm	ASTM D5185(m)		6		
Boron	ppm	ASTM D5185(m)		76		
Molybdenum	ppm	ASTM D5185(m)		51		
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>15	<1		
Aluminum	ppm	ASTM D5185(m)	>10	3		
Copper	ppm	ASTM D5185(m)	>10	△ 36		
Lead	ppm	ASTM D5185(m)	>10	0		
Tin	ppm	ASTM D5185(m)	>10	0		
Silver	ppm	ASTM D5185(m)	>10	1		
Zinc	ppm	ASTM D5185(m)		13		
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		1987		
Potassium	ppm	ASTM D5185(m)		9479		
SCALE POTENTIA	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	>100	17		
Magnesium	ppm	ASTM D5185(m)	>40	3		
Hardness	mg/L CaCO3	In-house*	<75	55		
VISUAL		method	limit/base	current	history1	history2
Coolant Color		Visual*	Orange/R	Orange		
Coolant Appearance		Visual*	Clear	Clear		
Color					no image	no image
Bottom					no image	no image



COOLANT REPORT





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number Unique Number : 5697347

Test Package : COOL

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : 02604262

: WA0018424

Recieved Diagnosed

: 20 Dec 2023

Diagnostician : Kevin Marson

: 19 Dec 2023

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Wajax Power Systems 70 Raddall Avenue Dartmouth, NS **CA B3B 1T7**

Contact: Danelle Hoffman dhoffman@wajax.com T: (902)468-6200

F: (902)468-3325