

OIL ANALYSIS REPORT

Sample Rating Trend

WATER

Area Arcelor Mittal - D00400 Machine Id AM956

Component Unknown Component Fluid MORG OIL 220 (--- GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

Wear

Iron ppm levels are noted.

Contamination

Water contamination levels are abnormally high. Water contamination levels are abnormally high... Water contamination levels are abnormally high... ppm Water contamination levels are abnormally high. Oil Cleanliness are abnormally high. Particles >4 μ m are abnormally high. Particles >6 μ m are abnormally high. Particles >14 μ m are abnormally high. Particles >21 μ m are abnormally high.


Fluid Condition


Acid Number (AN) is abnormally high. Visc @ 100°C is abnormally high.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Department		Client Info		Sales		
Sample From		Client Info		Machine		
Production Stage		Client Info		Initial		
Sent to WC		Client Info		12/15/2023		
Sample Number		Client Info		E30000701		
Sample Date		Client Info		13 Dec 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)		50		
Chromium	ppm	ASTM D5185(m)		<1		
Nickel	ppm	ASTM D5185(m)		<1		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)		<1		
Aluminum	ppm	ASTM D5185(m)		1		
Lead	ppm	ASTM D5185(m)		<1		
Copper	ppm	ASTM D5185(m)		2		
Tin	ppm	ASTM D5185(m)		2		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		4		
Barium	ppm	ASTM D5185(m)		0		
Molybdenum	ppm	ASTM D5185(m)		0		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)		6		
Calcium	ppm	ASTM D5185(m)		11		
Phosphorus	ppm	ASTM D5185(m)		8		
Zinc	ppm	ASTM D5185(m)		8		
Sulfur	ppm	ASTM D5185(m)		3589		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		2		
Sodium	ppm	ASTM D5185(m)		3		
Potassium	ppm	ASTM D5185(m)	>20	1		
Water	%	ASTM D6304*		A 3.586		
ppm Water	ppm	ASTM D6304*		A 35861		



OIL ANALYSIS REPORT





0

 \mathbf{z}

ΰ

lec]

FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	A 396318		
Particles >6µm		ASTM D7647	>2500	116612		
Particles >14µm		ASTM D7647	>320	▲ 2434		
Particles >21µm		ASTM D7647	>80	A 326		
Particles >38µm		ASTM D7647	>20	3		
Particles >71µm		ASTM D7647	>4	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	4 26/24/18		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		0.16		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	VLITE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	MILKY		
Odor	scalar	Visual*	NORML	NORML		
Emulsified Water	scalar	Visual*		<u>∧</u> .2%		
Free Water	scalar	Visual*		<u> </u>		
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)		238		
Visc @ 100°C	cSt	ASTM D7279(m)		<u> </u>		
SAMPLE IMAGES		method	limit/base		historyd	history?
		method	IIIIII/Dase	current	history1	history2
Color					no image	no image
	-				no image	no image
					no image	no image
					no image no image	no image no image
Color						
Color						
Color						
Color						
Color						
Color						
Color						
Color						
Color						
Color						
Color						
Color						
Color						
Color						
Color Bottom					no image	no image
Color Bottom	75 Apple		-	L7L 5H9 Envi	no image	no image
Color Bottom	75 Apple Recieved	1 : 19 I	Dec 2023	L7L 5H9 Envi	no image	no image Solutions Ltd.
Color Bottom	75 Apple	d : 19 l ed : 22 l	-		no image	no image

Report Id: CHECOB [WCAMIS] 02604276 (Generated: 12/22/2023 09:23:09) Rev: 1

Laboratory

Sample No.

Lab Number

Unique Number Test Package

CALA

ISO 17025:2017 Accredited Laboratory Dec13/23

To discuss this sample report, contact Customer Service at 1-905-372-2251.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.

Contact/Location: Tatiana Sorkina - CHECOB

tsorkina@e360s.ca

T: (800)263-3939

F: (905)373-4950