

# **OIL ANALYSIS REPORT**

Sample Rating Trend





CATERPILLAR 740GL HDTR0836

Hydraulic System

### TDH FLUID SAE 70W80 (--- GAL)

## DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) TDH FLUID SAE 70W80. Please confirm.

Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MOB 2 test kits, this testkit includes Particle Count to determine the ISO cleanliness of the fluid.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the component(unconfirmed).


#### **Fluid Condition**

The condition of the oil is acceptable for the time in service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0879749		
Sample Date		Client Info		10 Dec 2023		
Machine Age	hrs	Client Info		725		
Oil Age	hrs	Client Info		725		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION	٧	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	3		
Chromium	ppm	ASTM D5185(m)	>10	0		
Nickel	ppm	ASTM D5185(m)	>10	0		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)		0		
Aluminum	ppm	ASTM D5185(m)	>10	2		
Lead	ppm	ASTM D5185(m)	>10	<1		
Copper	ppm	ASTM D5185(m)	>75	1		
Tin	ppm	ASTM D5185(m)	>10	0		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	10	1		
Barium	ppm	ASTM D5185(m)	10	2		
Molybdenum	ppm	ASTM D5185(m)	10	0		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)	100	13		
Calcium	ppm	ASTM D5185(m)	3500	3087		
Phosphorus	ppm	ASTM D5185(m)	1150	1010		
Zinc	ppm	ASTM D5185(m)	1150	1180		
Sulfur	ppm	ASTM D5185(m)	5000	3633		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>20	6		
Sodium	ppm	ASTM D5185(m)		2		
Potassium	ppm	ASTM D5185(m)	>20	2		



# **OIL ANALYSIS REPORT**



С		VISUAL		method	limit/base	current	history1	history2
	-	White Metal	scalar	Visual*	NONE	NONE		
		Yellow Metal	scalar	Visual*	NONE	NONE		
		Precipitate	scalar	Visual*	NONE	NONE		
		Silt	scalar	Visual*	NONE	NONE		
		Debris	scalar	Visual*	NONE	NONE		
		Sand/Dirt	scalar	Visual*	NONE	NONE		
	Dec10/23	Appearance	scalar	Visual*	NORML	NORML		
	De	Odor	scalar	Visual*	NORML	NORML		
		Emulsified Water	scalar	Visual*	>0.1	NEG		
		Free Water	scalar	Visual*		NEG		
		FLUID PROPERT	IES	method	limit/base	current	history1	history2
		Visc @ 40°C	cSt	ASTM D7279(m)	50	35.9		
		SAMPLE IMAGES	5	method	limit/base	current	history1	history2
		Color					no image	no image
		Bottom					no image	no image
		GRAPHS						
		Iron (ppm) <sup>40</sup> T Severe			30-	Lead (ppm)		
	5	1				Severe		
		20 - Abnormal			E 20	Abnormal		
		0			- 53	23		23
		Dec10/23			Dec10/23	Dec10/23		Dec10/23
		 Aluminum (ppm)				nromium (ppm)		
		<sup>30</sup> Severe		30				
	E	= 20		트 <sup>20</sup>				
	Ē	abnormal				Abnormal		
						/23		/23
		Dec10/23			Dec10/23	Dec10/23		Dec10/23
		Copper (ppm)				_ Silicon (ppm)		
		<sup>300</sup>			60	Severe		
	udo	200 - Abnormal			특 <sup>40</sup> 문 <sub>20</sub>	Abnormal		
		100 - Abnormal				- Q		
		Dec1 0/23			Dec10/23	0/23 -		Dec10/23 -
		Decl			Dec1	Dec10/23		Decl
		Viscosity @ 40°C			4000	Additives		
	ç	Solution Abnormal Base			4000	calcium		
	U7/ +5	5 50 - <b>Base</b> 5 40 - <b>Abnormal</b>			E 3000	nanananan phosphorus zinc		
	c.	30			1000	~	, 	
		Dec10/23			Dec10/23	Dec10/23		Dec10/23
		De			De	De		De
ISO 17025:2017 Accredited	Laboratory Sample No. Lab Number Unique Number Test Package	: 02605307 : 5698392 : MOB 1	Recieved Diagnose Diagnost	d : 27   ed : 27   tician : We	Dec 2023 Dec 2023 s Davis	1350 Gove	rnment Rd. W, MA Kirk Contact: Mito	land Lake, ON CA P2N 3J1 h Lamontagne
Test denoted (*	) outside scope	contact Customer Servi of accreditation, (m) m tion are based on the s	ethod ma	odified, (e) te	sted at extern	al lab.		ts@agnicoeagle.com (705)567-5208 (705)567-5221

Contact/Location: Mitch Lamontagne - KIR370KIR