




OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
FSCC Ch#4
Machine Id
YORK SLXM039820
Component
Chiller
Fluid
YORK TYPE H (--- GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor. No other corrective action is recommended at this time.

Wear
Iron ppm levels are noted. The high metal levels indicate corrosion in the system.

Contamination
There is no indication of any contamination in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		GTT0001302	GTT0000803	GTT68043
Sample Date	Client Info		18 Dec 2023	20 Nov 2023	15 Mar 2023
Machine Age	hrs	Client Info	0	0	---
Oil Age	hrs	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ATTENTION	ABNORMAL	ATTENTION

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >8	▲ 23	▲ 24	1
Chromium	ppm	ASTM D5185(m) >2	0	0	<1
Nickel	ppm	ASTM D5185(m)	<1	0	---
Titanium	ppm	ASTM D5185(m)	0	0	---
Silver	ppm	ASTM D5185(m) >2	0	<1	---
Aluminum	ppm	ASTM D5185(m) >3	<1	<1	<1
Lead	ppm	ASTM D5185(m) >2	<1	<1	<1
Copper	ppm	ASTM D5185(m) >8	0	<1	<1
Tin	ppm	ASTM D5185(m) >4	0	0	<1
Antimony	ppm	ASTM D5185(m)	0	0	---
Vanadium	ppm	ASTM D5185(m)	0	0	---
Beryllium	ppm	ASTM D5185(m)	0	0	---
Cadmium	ppm	ASTM D5185(m)	0	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 0	0	1	---
Barium	ppm	ASTM D5185(m) 0	0	0	---
Molybdenum	ppm	ASTM D5185(m) 0	0	0	---
Manganese	ppm	ASTM D5185(m) 0	<1	<1	---
Magnesium	ppm	ASTM D5185(m) 0	<1	0	---
Calcium	ppm	ASTM D5185(m) 0	0	0	---
Phosphorus	ppm	ASTM D5185(m) 10	0	0	---
Zinc	ppm	ASTM D5185(m) 0	1	1	<1
Sulfur	ppm	ASTM D5185(m) 35	0	14	---
Lithium	ppm	ASTM D5185(m)	<1	<1	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	16	11	---
Sodium	ppm	ASTM D5185(m)	1	1	---
Potassium	ppm	ASTM D5185(m) >20	0	<1	---
ppm Water	ppm	ASTM D6304* >300	2	217	▲ 441





FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974* 0.02	0.09	0.07	0.045

OIL ANALYSIS REPORT

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE ---
Yellow Metal	scalar	Visual*	NONE	NONE	NONE ---
Precipitate	scalar	Visual*	NONE	NONE	NONE ---
Silt	scalar	Visual*	NONE	NONE	NONE ---
Debris	scalar	Visual*	NONE	NONE	NONE ---
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE ---
Appearance	scalar	Visual*	NORML	NORML	NORML ---
Odor	scalar	Visual*	NORML	NORML	NORML ---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	68.0	36.2	43.0 ---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					no image
Bottom					no image

GRAPHS



Sample No. : GTT0001302 **Recieved** : 28 Dec 2023
Lab Number : **02605632** **Diagnosed** : 06 Jan 2024
Unique Number : 5698717 **Diagnostician** : Bill Quesnel
Test Package : IND 2 (Additional Tests: KV40)

To discuss this sample report, contact Customer Service at 1-905-847-9300 Ext 26.

Test denoted () outside scope of accreditation, (m) method modified, (e) tested at external lab.*

Damages: Seller shall in no event be liable for special, incidental, or consequential damages, of a commercial nature, resulting from any cause.

Advantage Airtech Ltd.
 135-1895 Clements Rd
 Pickering, ON
 CA L1W 3V5
 Contact: Service Manager
 admin@advantageairtechltd.com
 T: (905)683-4442
 F: